

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001
Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2018/SZ/ 2246

Dated: 5.10.18

FIRE SAFETY CERTIFICATE

Certified that Jose Marti Sarvodaya Vidyalaya located at R.K.Puram, Sector-12, New Delhi-110022 comprised of ground plus two upper floors (Except Auditorium) was granted Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2015/SZ/1510 dated 19/08/2015. The premises was re-inspected by officer concerned of this department on 14/09/2018 in presence of Mr. Yaadram Sharma (Principal) and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 5/10/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, Jose Marti Sarvodaya Vidyalaya, R.K.Puram, sector-12, New Delhi-110022
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated as regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in.
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT


| | | | | |
|---------------|--|---|-------------------------|-----------------------|
| 1 | Name & Address of the Building | Jose Marti Sarvodaya Vidyalaya, R.K.Puram Sec-12, New Delhi-110022 | | |
| 2 | Type of Occupancy | Educational, Group-B (School) | | |
| 3 | Building Comprised of | G+02 upper floor Except Auditorium | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/School/2015/SZ/1510 Dated 19/08/2015 | | |
| 6 | Fire Safety Directives Letter No | Nil | | |
| 7 | Date of Inspection | 14-09-2018 | | |
| 8 | Name of the Inspecting Officers | Mehmood, ADO (SJ) | | |
| 9 | Name & Designation of Officers from the building side | Mr. Yaadram Sharma (Principal) | | |
| 10 | Year of construction | 1982 | | |
| 11 | Applicant letter No. | JMSV/588 dated 08.08.2018 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | As Per Old NOC | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | 6 mtr | 12m Provided | MR |
| | • Gate width | 5m | Provided | MR |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | Two | Two | MR |
| | ➤ Basement floor. | -NA- | -NA- | -NA- |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.5 m/0.90m | 1.30m & 1.28m | MR |
| | ➤ Basement floor | -NA- | -NA- | -NA- |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -NA- | -NA- | -NA- |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | -NA- | -NA- | -NA- |
| | e) Width of corridor | 1.5m | Provided | MR |
| | f) Door size | 1m | Provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | • Basement | 30 ACPH | -NA- | -NA- |
| | • Upper floors | 12 ACPH | -NA- | -NA- |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | 18 Nos | 18 Nos | MR |
| | • Types | ABC / CO2 | ABC & Co2 | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | Two | Provided | MR |
| | • Length of hose-reel hose. | 30m | Provided | MR |
| | • Nozzle Diameter | 5mm | Provided | MR |


| | | | | | |
|-----|---|--------------------------|---|------|------|
| 19. | Fire Control Room. | • Detector system panel. | -NA- | -NA- | -NA- |
| | | • Flow switch panel. | -NA- | -NA- | -NA- |
| | | • PA system panel. | -NA- | -NA- | -NA- |
| | | • Battery backup. | -NA- | -NA- | -NA- |
| | | • Building floor plan. | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | -NA- | ABC type fire extinguisher provided near electrical panel | -NA- | |


The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No. F.6/DFS/MS/School/2015/SZ/1510 dated 19/08/2015, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Mehmood
 Design: ADO (SJ)

DO (SD) 








24/9

CFD S/P M. scell FT/107
u/2579.

67/DFS
3/2/18

A. S. Delhi for my for signature please


 M. scell u/317.