

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/ 2343

Dated: 17/10/18

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Ram Jatan Public School at G-IV 116, Main Road, Sonia Vihar, Delhi -110094, comprised of ground plus one upper floor only owned / occupied by M/s Ram Jatan Public School was issued FSC vide letter No F.6/DFS/MS/School/2014/NDZ/1308 dated 20/10/2014. The school building was re-inspected by the officer concerned of this department on 04/10/18 in presence of Sh. Ram Dresh, Manager of the school and found that the school building have deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular Letter No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11 issued by Director of Education and observed that the school building is fit for occupancy class "B" 'Educational Building' with effect from 17.10.18.....for a period of three year, subject to conditions printed overleaf.

Issued on.....17.10.18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal  
M/s Ram Jatan Public School,  
G-IV 116, Main Road, Sonia Vihar,  
Delhi -110094.
2. The Joint Director of Education,  
(Land & Estate)  
Directorate of Education, Lucknow Road, Delhi- 54.



**- Conditions -**

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"



M/5

1. Name & address of the building : Ram Jatan Public School, G-IV 116, Main Road, Sonia Vihar, Delhi -110094.
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F.6/DFS/MS/School/2014/NDZ/1308 dated 20/10/2014.
6. Fire Safety direction letter No : F.16/Estate/CC/Fire Safety/2011/3298 to 3398 Dated 01/03/11
7. Date of Inspection : 04/10/2018
8. Name of the Inspecting officers : ADO Om Prakash
9. Name and designation of Officer from the building side : Sh. Ram Dresh (Manager)
10. Year of Construction : 2006-07
11. Applicant's letter No : Nil Dated – 24/09/2018

NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement Circular 01.03.11	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	06 Mtrs	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	01 no.	02 no.	MR
	• Basement	N/A	N/A	N/A
	b. Width of Staircases			
	• Upper Floor	1.5 mtr	1.25 m & 1.15 m	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01 no.	01 no.	MR
	e. Width of Corridor	1.5 m	1.5 m	MR
	f. Door Size	1.0 m	1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 nos.	04 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N/A	N/A	N/A
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terface Level			
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A



16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules, The Fire safety Certificate issued vide letter no F.6/DFS/MS/School/2014/NDZ/1308 dated 20/10/2014 has grant under circular no.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 Dated 01/03/2011 is recommended to renewal under rule 37 of the Delhi Fire Service Rule 2010.

*Om Prakash*  
5/10/18

Signature of the Inspecting Officer  
Name : - Om Prakash  
Designation : - ADO (Shahdara)

DO (East)

*[Signature]*  
5/10/18

DCFO/NDZ

*[Signature]*

727/CAO/NDZ  
10/10/18  
17/18

C.F.P.

M.SCELL

FT/10.

*[Signature]*  
9/18

FT letter is prepared and put up for district plan.

CFO/NDZ

*[Signature]*