

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6/DFS/MS/School/2018/SZ/ 2295

Dated: 11.10.18

**FIRE SAFETY CERTIFICATE**

Certified that SDMC Primary School located at Harijan Basti, Rajokri, New Delhi-110038 comprised of ground floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2015/SZ/1925 Dated 28-10-2015. The premises was re-inspected by officer concerned of this department on 29/09/2018 in the presence of Mrs. Lalit Rani (Principal) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi. and that building is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from the date of issue of this certificate for period of **Three years** subject to compliance of the conditions as mentioned below.

Issued 11/10/18 at New Delhi by

(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. Principal, SDMC Primary School located at Harijan Basti, Rajokri, New Delhi-110038.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non- functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	SDMC Primary School, Harijan Basti, Rajokri, New Delhi- 110038		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground floor only.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2015/SZ/1925 dated 28-10-2015		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	29-09-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Lalita Rani (Principal)		
10	Year of construction	1982		
11	Applicant letter No.	SDMC/Rajokri HB/D-47 Dated 01-09-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	6 mtr	School is 100m(3 length of hoses)away from road	MR (Old Case)
	• Gate width	4m	4m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	-NA-	-NA-	-NA-
	<b>e) Width of corridor</b>	-NA-	-NA-	MR
	<b>f) Door size</b>	1m	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	<b>Fire Extinguishers.</b>			
	• Total numbers	03 nos	03 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI mark	Provided	MR

<b>6.</b>	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Length of hose-reel hose.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Nozzle Diameter</li> </ul>	-NA-	-NA-	-NA-
<b>7.</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hooter's location</li> </ul>	-NA-	-NA-	-NA-
<b>8.</b>	<b>MOEFA</b>	-NA-	-NA-	-NA-
<b>9.</b>	<b>Public Address System</b>	-NA-	-NA-	-NA-
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Number of Hydrant per floor</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Head of main pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Number of main pumps.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Standby Pump output.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Standby Pump head.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Pump house access.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Head of pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Power supply.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump.</li> </ul>	-NA-	-NA-	-NA-
<b>14.</b>	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Draw-off connection.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>➤ Access to tank.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Overhead tank capacity.</li> </ul>	-NA-	-NA-	-NA-
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Pressurization of lift lobby.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Communication in lift car.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Fireman's switch.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• Lift signage.</li> </ul>	-NA-	-NA-	-NA-

17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular, the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/School/2015/SZ/1925 dated 28-10-2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Mehmood*  
8/10/18

Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

DO (SD)

*Anilash*  
5/10/18

*Dy. CEO (S2)*

*Handwritten signature*  
9/10

*CEO (S2)*

*M.Scell*

*FTM*  
*W/SX*

*9/2/18/18/11/X*  
*9/10/18/11/X*

A dth callus during for signature please

*Mehmood*  
10/10/18  
ADO (S2)

*10/10/18*

*M.Scell*

*W/SX*  
10/10/18

