

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2018/SZ/ 2282

Dated: 9/10/18

FIRE SAFETY CERTIFICATE

Certified that **St. Mary's Public School** (Junior Branch) at Khasra No-142, 150, Z-More, Neb Sarai, New Delhi-110068, comprised of ground plus three upper floors owned/occupied by St. Mary's School Management have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and verified by officer concern of this department on 27/08/2018 in the presence of Dr. Thomas George (Principal) of the school and that the premises is fit for occupancy class "**Educational, Group-B**" (School) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 9/10/18 at New Delhi by

VK
9/10/18
(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to: -

1. Principal, St. Mary's Public School (Junior Branch), 150, Z-More, Neb Sarai, New Delhi-68
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept unlocked and free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

N/7

INSPECTION REPORT

1	Name & Address of the Building	St. Mary's Public School (Junior Branch), Khasra No-142, 150, Z-More, Neb Sarai, New Delhi-68		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground + 3 upper floors.		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	27-08-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Dr. Thomas George (Principal)		
10	Year of construction	2009		
11	Applicant letter No.	Outdoor Diary No. 11466 dated 09-08-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	NBC / BBL requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	6 mtr	Provided	MR
	• Gate width	4.5 mtr	5.10, 3.70 & 2.68m	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	03 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.75m	1.24m, 0.90m to 1.05m and 1.50m (iron)	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	One	Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	08 Nos	17 Nos	MR
	• Types	ABC / CO2	CO2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

St. Mary's Public School (Junior Branch), Khasra No-142, 150, Z-More, Neb Sarai, New Delhi

19.	Fire Control Room.	-NA-	-NA-	-NA-
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	Provided 02 Nos ABC type fire extinguisher near electrical panel	-NA-

The Fire protection systems provided in the building/premises were test checked at random and found functional at the time of inspection. The shortcomings issued vide letter dated 07/01/2016 (C-14) found complied.

Keeping in view the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

Mehmood
22/9/18
Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

St. Mary's Public School (Junior Branch), Khasra No-142, 150, Z-More, Neb Sarai, New Delhi

DO (SD)

The Requirements in inspection note is derived from DDB circular, whereas the DFA is put up under DFA Act & Rules. Kindly clarify.

ADO
SJ

Prakash
20/9/18
DO (SD)

Completed DFA to go for approval please

Mehmood
25/9/18
ADO (SJ)

DO (SD)

Prakash
4/10/18

DO (SD)

3/cfo 52)
5/10/18 19/10/18



Mehmood
4/10

M. Scull

FTM.

VK
5/10/18