

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

Dated: 5/10/18

No. F6/DFS/MS/School/2018/NDZ/ 2242

FIRE SAFETY CERTIFICATE

Certified that the Central Public (Middle) School at 213, School Block, Shakarpur, Delhi-92, owned/occupied by Central Public (Middle) School, comprised of ground plus three upper floors was issued Fire Safety Certificate vide letter no. F.6/DFS/MS/School/2010/2271 dt-02/08/10. The school building was re-inspected by the officer concerned of this department on 07/09/18 in the presence of Manager of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.262-362 Dated 17.01.2005 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from 5/10/18 for a period of three years, subject to conditions printed overleaf.

Issued on 5/10/18 at New Delhi by

  
(Vipin Kantai)  
Chief Fire Officer  
Delhi Fire Service

To,  
The Manager,  
Central Public (Middle) School,  
213, School Block, Shakarpur, Delhi-92.

Copy to:-  
✓ The Dy. Director of Education  
Anand Vihar, Delhi.



- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building: Central Public (Middle) School at 213, School Block, Shakarpur, Delhi-92.
2. Building is comprised of : G+3 upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2010/2271 dt-02/08/10
6. Fire Safety direction letter No : Circular No.262-362 Dated 17.01.2005
7. Date of Inspection : 07/09/18
8. Name of the Inspecting officers: ADO R.K. Yadav
9. Name and designation of Officer from the building side : Manager
10. Year of Construction :
11. Applicant's letter No : Nil dated 10/08//18

N O.	Minimum Standards on fire prevention and fire safety U/R33	Old Circular Requirement	Provided at Site	Remarks
1	Access to building	06 M	06 M	MR
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos	02 Nos.	MR
	• Upper Floor	N/A	N/A	N/A
	• Basement			
	B. Width of Staircases	1.5 M	1.32 & .80 M	MR Old accepted
	• Upper Floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Pressurization	2 no.	2 Nos.	MR
	e. No. of continuous staircases to terrace	1.5 M	1.5 M	MR
	g. Width of Corridor	1.0 M	1.0 M	MR
	h. Door Size			
3	Compartmentation.	N/A	N/A	N/A
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers	10 Nos.	10 Nos.	MR
	• Total numbers	ABC & Co2	ABC & Co2	MR
	• Types	ISI marked	ISI marked	MR
	• IS marking			

\* Old accepted

124

6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 MM	100 MM	MR
	• Number of hydrants per floor	1 No.	1 No.	MR
	• Hose Box	1No.	1 No.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 Ltrs.	5,000 Ltrs.	MR

17/8

15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
17	• Lift Signage	N/A	N/A	N/A
18	Standby power supply	Required	Provided	MR
	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
19	• Location	N/A	N/A	N/A
	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
20	• Building Floor Plans	N/A	N/A	N/A
	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety Measures as required under the rules. The Fire Safety certificate issued vide letter no. F.6/DFS/MS/School/2010/2271 dt-02/08/10 renewal under the circular no.262- 362 dated 17.01.2005 is recommended.

*R. K. Yadav*  
17/8/2018

Signature of the Inspecting Officer  
Name:- R.K.Yadav  
Designation:- ADO(LN)

DO(ED)

*[Signature]*  
18/9  
DYC/DO/ND4

CFO. m.scill

FTD.  
*[Signature]*  
3/10

730/CFO/ND2  
4-10-18

FT letter is put up for signature pls

CFO(ND2)

m.scill *[Signature]*

*R. K. Yadav*  
4/10/2018