

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS; DELHI FIRE SERVICE, NEW DELHI-110001



No.F6/DFS/MS/2018/SZ/ 2240

Dated: 4/10/18

FIRE SAFETY CERTIFICATE

Certified that the Community Hall at Gram Sabha Land, Pocket 1,2,3, & 4, Nasirpur Dwarka, New Delhi, owned/ occupied by DDA, comprised of ground plus one upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules 2010 under DFS Act 2007 and verified by the officer concerned of fire service on 28.9.2018 in presence of Sh. Sh. Vinay Kumar AE (Electrical) & Sh. R C Chauhan AE (Civil) DDA, and that the building is fit for occupancy "Assembly building" with effect from4.10.18..... For a period of **Three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service, 2010, subject to conditions printed overleaf.

Issued on4/10/18.....at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to:-

1. The Executive Engineer, Electrical Division-10, B2B, Janakpuri-New Delhi-110058.
2. The Vice Chairman, DDA, Vikas Sadan, INA, New Delhi.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Community Hall, Gram Sabha Land, Pocket 1,2,3 & 4 Nasirpur, Dwarka, New Delhi.	
2	Type of Occupancy	Assembly	
3	Type of case	New	
4	Details of previous NOC	Nil	
5	Fire safety directives letter No	F6/DFS/MS/BP/2014/244 dated 5.9.2014	
6	Date of inspection	28.09.2018	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Vinay Kumar AE (Electrical) & Sh. R C Chauhan AE (Civil)	
9	Year of construction	2018	
10	Applicant's letter No.	F10(20) /EE/(E) E/D10/DDA 17-18/386 dated 10.9.2018	Ground Plus One upper floor

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement letter dated 5.9.2014	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	7.80 Mtrs.	MR
	2) Gate width	6 Mtrs.	6 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	Two	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	2 Mtrs.	Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	One	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 Mtr.	Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided	MR
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	Ground Floor		N/A	N/A
	upper floors		N/A	N/A
5	Fire Extinguishers			
	total numbers	5 Nos. Co2	Provided	MR
	Types	& ABC ISI	Provided	MR
	ISI marking	Marked	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 M	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	Smoke	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	Battery backup	N/A
	hooter's location	Near staircase	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	One	Provided	MR
	hose Box	Required	Provided	MR
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	2x180 LPM	N/A
	b. Head of main pump	N/A	40 Mtrs.	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	Provided	N/A
	pump house access	N/A	Provided	N/A
	2. Terrace level			
	a. Discharge of pump	900 LPM	450 (2 Nos.)	MR
	b. head of the pump	40 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	40,000 Lts.	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	Required	Provided	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	15000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

17	Standby power supply	Required	DG Set 62.5 KVA	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: Co2 Fire Extinguishers near electrical panel Provided			MR

The fire protection system provided in the building were checked and found functional at the time of inspection. Shortcomings vide letter no. F6/DFS/MS/2018/SZ3507 dated 27.12.2017 found rectified. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of fire safety Certificate under rules 35 of the Delhi Fire Service Rules 2010, is recommended. Accordingly DFA is put up for approval and signature please.

Sey 28/9/18
 S.P. Bhardwaj
 ADO (Dwarka)

~~DO/SW~~
dy 1/10/18

1094/DO/SW
 01/10/2018
 64/DFS2
 31X/ATX

~~DCFS(S)~~

~~DO/SW~~
 1/10

CFO ~~S~~

m.s cell

FT for
 3TX

FT for signature phase



~~DFS2~~

m.s cell

4TX

Sey 4/11/18