

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. F-6/DFS/MS/WZ/2018/ 2317

Dated: 12/10/2018

FIRE SAFETY CERTIFICATE

Certified that the M/s Grand Hospitality LLP, Banquet Hall (Ground Floor) Located at 1/5, Kirti Nagar Ind. Area, New Delhi-110015, in a building comprised of Basement + Ground + 2 Upper Floor owned/ occupied by M/s **Grand Hospitality LLP (Ground Floor)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 23/08/2018 in the presence of Sh. Harsimran Singh (Partner) and found that the said building that the premises is fit for occupancy class " Assembly" Group D (**Ground Floor only**) with effect from 12/10/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/10/18 at New Delhi by.

(Atal Garg)

Chief Fire Officer
Delhi Fire Service.

Copy to:-

1. The Grand Hospitality LLP (Ground Floor) Located at 1/5, Kirti Nagar Ind. Area, New Delhi-110015
2. Dy. Health Officer, Karol Bagh Zone, NDMC, Public Health Department, Karol Bagh, New Delhi.
(With a required to see that the upper floors and basement should not be used for any purpose)

Following fire safety directives must be adhered to:-

1. **The FSC is valid for ground floor only.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. **The other Floors shall not be used for any purpose & are sealed photo attached.**
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. Basement shall not be used for any purpose.
9. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
10. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

114
INSPECTION REPORT

1. Name & address of the building: M/s Grand Hospitality LLP, Banquet Hall
Located at (Ground Floor)1/5, Kirti Nagar Ind. Area, New Delhi-110015.
2. Type of Occupancy : Assembly Banquet Hall is located on **Ground Floor** of building serving Basement + Ground + 2 Upper Floors at
Temporary tin shed structure at terrace) Area GF = 320 m²
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/2018/2882 Dated-
03/07/2018(**For Basement + Ground + 2 Upper Floors**)
6. Date of inspection : 23-08-2018
7. Name of the Inspecting Officer : DO/W& ADO (WP)
8. Name and designation of Officer
from the building side : Sh. Harsimran Singh (Partner)
9. Year of Construction : Old building
10. Applicant's letter No. : Nil dated - 06-07-2018

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m & 6 m	Provided	MR
	• Gate width	5 m	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	2 Provided	NA
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	NA	205m & 1m	NA
	• Basements	1x2m & 1x1m	205cm & 120cm	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2m & 1m	GF-260cm & 115cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NR	NP	NR
	• Fire Rating of shaft door	NR	NP	NR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

N/S

4.	Smoke managements System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required	Provided	MR
		NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	nos. 5 ABC & CO ₂ ISI marked	8 Provided	MR
			Provided	MR
			Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
		NA	Provided	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		NR	Provided	NR
		NR	NP	NR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		1	Provided	MR
		1	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR	NR	NR
		NR	NR	NR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

N/6

14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNIL.....

Note :- The directive issued to the owner vide letter no. F6/DFS/MS/2018/2882 Dated-03/07/2018 for Basement + Ground + 2 Upper Floors. Now owner want to run the banquet at **Ground Floor only** and the others floors shall not be used for any purpose.

Mukesh 30/8/18
 Signature of the Inspecting Officer
 Name Sh, Mukesh Verma
 Designation DO/W

Udaivir Singh 30/8/18
 Signature of the Inspecting Officer
 Name Udaivir Singh
 Designation ADO/WP

Dy. CPO (W2)

21 spoke req. recommunication 5/9/18 & 1st floor & 2nd floor

efo

Do not work. spoken on 12/8/18.

Resubmitted please.

Recd on 4/10

Dy. CPO (W2)

Mukesh 13/9/18