

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. F.6/DFS/MS/2018/NDZ/ 2353

Dated 17/10/18

FIRE SAFETY CERTIFICATE

Certified that the M/s S.K. Mohit Party Hall at Plot No. B-17, Jhilmil Industrial Area, Delhi 32, comprised of ground plus one upper floor owned / occupied by M/s S.K. Mohit Party Hall a unit of SKM. Foods India . The Premises was re-inspected by the officer concerned of this department on 10.10.18 in presence of Sh. Vinay Maini (Director) and found that the Assembly building have deemed complied with the Fire prevention and Fire safety requirements in accordance with the Rule 33 of Delhi Fire Service Rules, 2010 and observed that the premises is fit for occupancy Group "D" Assembly Building with effect from 17.10.18...for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010. The conditions printed overleaf.

Issued on17.10.18..... at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

To,
M/s S.K. Mohit Party Hall,
Plot No. B-17, Jhilmil Industrial Area,
Delhi 32.

Copy to:-
Dy. Health Officer,
East Delhi Municipal Corporation, Health Department
Shahdara (south) Zone, Karkardooma, Shahdara, Delhi

CONDITIONS

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

1. Name & address of the building : M/s S.K. Mohit Party Hall at Plot No. B-17,
Jhilmil Industrial Area, Delhi 32.
2. Building is comprised of : Ground plus one upper floor,
3. Type of Occupancy : Assembly
4. Type of Case : **Renewal**
5. Details of Previous NOC : F.6/DFS/MS/2015/NDZ/2116 dated 01.12.15
6. Fire Safety direction letter No : F.6/DFS/MS/BP/2012/2728 dated 26/07/12
7. Date of Inspection : 10/010/18
8. Name of the Inspecting officers : Francis Brown (DO)
9. Name and designation of officer
from the building side : Vinay Maini (Director)
10. Year of construction : 2010
11. Applicant's letter No : Nil dated 28/09/18.

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	12 m N/A N/A	18 m N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	02 Nos. N/A	03 Nos. N/A	MR N/A
	b. Width of Staircases			
	<ul style="list-style-type: none"> Upper floor Basement 	1.5 M N/A	1.5 M, 1.79 M & 1.06 M N/A	MR N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of Continuous Staircases to Terrace	01 Nos.	01 Nos.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.0 M	(2.0 m x 2), (1.42 m x 2) (1.10 m x 2) & 0.94 m	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	Required Required N/A N/A N/A	Provided sealed N/A N/A N/A	MR MR N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A N/A	N/A Provided in Kitchen	N/A N/A
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	06 nos. ABC /CO ₂ ISI marked	10 Nos. ABC /CO ₂ ISI marked	MR MR MR

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	02 no.	03 no.	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	30 m	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of main panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Location of repeater panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooter's location 	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> upper floor 	N/A	Provided	MR
	<ul style="list-style-type: none"> sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer 	100mm	100mm	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	02 nos.	02 nos.	MR
	<ul style="list-style-type: none"> Hose box 	02 nos.	02 nos.	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto starting /manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump house access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 LPM	900 LPM	MR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40M	40M	MR
	<ul style="list-style-type: none"> ➤ Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Draw-off connection 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	N/A	provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	15000 Ltrs.	20000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	1500,kvs	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on Fire prevention and Fire safety measures as required under the Rules. The FSC issued vide letter no. F6/DFS/MS/2015/NDZ/2116 dated 01/12/2015 . And renewal under the rules 35, of the Delhi Fire Service Rule 2010 is recommended.

Francis Brown
15/10/18

Signature of the Inspecting Officer
Name: Francis Brown
Designation: DO (East)

submitted for approval plan.

DCFO (NDZ)

dh

.C.F.d. M.scell

F7/10.

15/X

Ft. Delhi is prepared and put up for 815nets plan.

CFO/NDZ

M.scell

17/X

Francis Brown
17/10/18

F7/10 / CFO/NDZ