

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/Hospital/2018/ 2289

Dated: 10/10/18

FIRE SAFETY CERTIFICATE

Certified that the Vivekanad Pratishthan Parishad, Vivekanand Hospital Yogashram located at Patparganj Road, Khureji, Delhi-110051, Comprised of basement, ground plus three upper floors owned/occupied by Vivekanad Pratishthan Parishad. was issued FSC vide letter No. F6/DFS/MS/Hospital/2012/1035 dated 23/03/12. The hospital building was re-inspected by a team of officers of this department in the presence of Acharya Vikrmaditya, Founder of the hospital and found that the hospital building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and found that the hospital building is fit for occupancy class "C" 'Institutional Building' for ground plus three upper floors with effect from 10/10/18.. for a period of **three** years, subject to conditions, printed overleaf.

Issued on 10/10/18 at New Delhi by

W
4/10
(Vipin Kental)
Chief Fire Officer

To,
Acharya Vikrmaditya,
Founder Vivekanad Pratishthan Parishad
Vivekanand Hospital Yogashram
Patparganj Road, Khureji,
Delhi-110051

Copy:-
The Directorate of Health Services
M.O. I/C Nursing Home Cell,
Govt. of NCT of Delhi,
F-17, Karkardooma
Delhi-110032

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : Vivekanad Pratishtan Parishad,
Vivekanand Hospital Yogashram
Patparganj Road, Khureji, Delhi-110051
2. Building is comprised of : Basement, Ground plus three upper floors
3. Type of Occupancy : Institutional (Without Bed)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/Hospital/2012/1035 dated 23/03/12
6. Fire Safety directive letter No. : F6/ MS/DFS/Hospital/2001/328 dated 23/02/2001
7. Date of Inspection : 01/08/2018
8. Name of the Inspecting officers : DO F. Brown & ADO Vijay Bahadur
9. Name and designation of Officer from the building side : Sh. Vikrmaditya
10. Year of Construction : Nil dated 04/07/2018
11. Applicant's letter No

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC/BBL Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	• Road width	06 mtr.	30 mtr.	MR
	• Gate width	N/A	3.50 mtr	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	01 nos	01 nos	MR
	• Basement	02 nos	02 nos	MR
	B. Width of Staircases			
	• Upper floor	02 mtr	02 mtr	MR
	• Basement	02 mtr	02 mtr & 1.24 mtr	MR
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 no.	01 no.	MR
	e. Width of Corridor	2.40 mtr	2.40 mtr	MR
	f. Door Size	01 mtr	01 mtr	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Exhaust Provided	MR
	• Upper floor	Required	Ventilated	MR
05.	Fire Extinguishers			
	• Total numbers	10 nos.	10 nos	MR
	• Types	ABC /CO ₂	ABC & CO ₂	MR
	• IS marking	ISI marked	Provided	MR


06	First-Aid-Hose Reels.			
	Total numbers on each Branch	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	Heat & Smoke	Smoke	MR
	• Location of main panel	Control room	Main Entrance	MR
	• Location of repeater panel	Security room	Provided	MR
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter	staircase	Provided (each floor)	MR
08	MOEFA	Required	Provided (each floor)	MR
09	Public Address System.	Required	Provided (each floor)	MR
10	Automatic Sprinkler System.	Required	Provided (each floor)	MR
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 nos.	01 nos.	MR
	• Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants.			
	• Total number of hydrants	01 nos	01 nos	MR
	• Hose box	01 nos	01 nos	MR
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	450 lpm	450 lpm	MR
	• Head of main pump	40 mtrs	40 mtrs	MR
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level	N/A	N/A	N/A
	• Discharge of pump	900 lpm	900 lpm	MR
	• Head of the pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
4	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	1,00,000 ltr	1,00,000 ltr	MR
	• Draw-off connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 ltr	25,000 ltr	MR
	Exit Signage.	Required	Provided	MR


16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection


Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, it is recommended to renew Fire Safety Certificate.


Signature of the Inspecting Officer
 Name : F Brown
 Designation : Divisional Officer (ED)


 Signature of the Inspecting Officer
 Name :- Vijay Bahadur
 Designation :- A.D.O (T.Pur)


 6/18/18

CFD/NDM
 DYCFD/NDM / ONELL

PI Break  29/8

DOHE 

AD/TP