

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225


No. F.6/DFS/MS/Petrol/2018/SZ/ 2290

Dated: 10/10/18

FIRE SAFETY CERTIFICATE

Certified that M/s Welcome Motors (Storage of I.O.C.L. Petroleum Products) located at Mandir Marg, District Centre, Saket, New Delhi-110017, comprised of Ground floor only was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2014/SZ/68 dated 16.01.2014. The premises was re-inspected by the officer concerned of this department on 27/09/2018 in the presence of Mr. Anurag Mishra (In-charge) of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Hazardous**" Group-J, as above with effect from the date of issue of this certificate for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 10/10/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer


Copy to: -

1. Addl. Commissioner of Police (Lic.), 1st Floor, PS Defence Colony, New Delhi-110049
2. M/s Welcome Motors (Storage of I.O.C.L. Petroleum Products) at Mandir Marg, District Centre, Saket, New Delhi-110017

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	M/s Welcome Motors (Storage of I.O.C.L. Petroleum Products), Mandir Marg, District Centre, Saket, ND		
2	Type of Occupancy	Hazardous Building "Group 'J'"		
3	Building Comprised of	Single Storey Building		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2014/SZ/68 Dated 16/01/2014		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	27-09-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Anurag Mishra (In-charge)		
10	Year of construction	1981		
11	Applicant letter No.	Outdoor Diary No. 10435 Dated 19-08-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	Required	9 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors.	-NA-	-NA-	-NA-
	➤ Basement.	-NA-	-NA-	-NA-
	b. Width of Staircase			
	➤ Upper floors	-NA-	-NA-	-NA-
	➤ Basement	-NA-	-NA-	-NA-
	c. Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	1m	Provided	MR
3.	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	Required	31 Nos	MR
	• Types	ABC, CO2, Foam	ABC, CO2 & Foam	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	-NA-	-NA-	-NA-
	• Length of hose-reel hose.	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-

M/s Welcome Motors at Mandir Marg, District Centre, Saket,, New Delhi

7.	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump.	-NA-	-NA-	-NA-
	➤ Head of pump.	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump.	-NA-	-NA-	-NA-
14.	Captive water storage for Fire Fighting.			
	• Underground tank capacity.	N/A	N/A	N/A
	• Draw-off connection.	N/A	N/A	N/A
	• Fire Service Inlet.	N/A	N/A	N/A
	• Access to tank.	N/A	N/A	N/A
	• Overhead tank capacity.	N/A	N/A	N/A
15.	'No Smoking' Signage.	Required	Displayed	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

M/s Welcome Motors at Mandir Marg, District Centre, Saket,, New Delhi

02/02/2017
1101
0000

N/15


19.	Fire Control Room.	<ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	-NA-	-NA-	-NA-
			-NA-	-NA-	-NA-
			-NA-	-NA-	-NA-
			-NA-	-NA-	-NA-
			-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	1. Provided fire buckets filled with loose dry sand. 2. No loose electrical wiring seen in the retail outlet area	MR	

The filling station was inspected by the undersigned on 27.09.2018 in the presence of Mr. Anurag Mishra (Incharge) and observed that filling station is comprised of ground floor (one room) only. The shortcomings issued by the department vide letter dated 16/05/2018 found complied. ✓

The fire protection system such as fire extinguishers of different type and capacity, fire buckets filled with loose dry sand provided at suitable places in the retail outlet area were test checked at random and found functional at the time of inspection. "NO SMOKING" sign boards were found displayed both in Hindi & English at conspicuous places. No loose electric wiring was seen in the premises.


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2014/SZ/68 dated 16/01/2014, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.


Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Mehmood
 Design: ADO (SJ)

M/s Welcome Motors at Mandir Marg, District Centre, Saket,, New Delhi


DO (SD)


 4/10/18



84/CFO/SZ
5/10/18







 4/10

m.scell

FTM

5/10

a. br. Delhi Sur of for Signature Sheet

 8/10/18

CFO (SP)

m.scell

9/10

anurag