

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F.6/DFS/MS/School/2018/NDZ/ 2223

Dated: 3/10/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Ahlcon International School, Mayur Vihar Ph-1, Delhi -110091, comprised of Basement, Ground plus three upper floors owned / occupied by Ahlcon International School, was issued FSC vide letter no. F6/DFS/MS/School/2015/NDZ/1628 dated 08/09/2015. The school building was re-inspected by the officer concerned of this department on 19/09/18 in presence of Sh. P.K. Bhatnagar, (Manager) and found that the school building have deemed complied with the Fire Prevention and Fire Safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 and the building is fit for occupancy Group B "Educational Building" with effect from ..3/10/18.....for a period of three years, subject to conditions printed overleaf.

Issued on.....3/10/18.....at New Delhi by

uc
28/9.
(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

o/c
ju

Copy to:-

1. The Manager,
Ahlcon International School, Mayur Vihar Ph-1,
Delhi -110091.
2. The Dy. Director of Education,
D-Block, Anand Vihar,
Delhi.

- Conditions -

- 1 All the means of escape shall be kept free of all type of obstruction all the time.
- 2 All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"

1. Name & address of the building : Ahlcon International School, Mayur Vihar Ph-1, Delhi -110091.
2. Building is comprised of : Basement, Ground +3
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC letter : F6/DFS/MS/School/2015/NDZ/1627 Dated: 08/09/2015.
6. Fire Safety direction letter No : F6/DFS/BP/2000/2270 dated 12.12.2000
7. Date of Inspection : 20/09/2018
8. Name of the Inspecting officers : DO F.Brown
9. Name and designation of Officer from the building side : Sh. P.K. Bhatnagar (Manager)
10. Year of Construction : 2001
11. Applicant's letter No : AIS/DFS/FSC/2018-19/2071 Dated - 27/08/18

NO.	Minimum Standards on fire prevention and fire safety U/R33	Directives	Provided at Site	Remark MR/NMR
1	Access to building			
	• Road width	06 Mtrs	15 Mtrs	M/R
	• Gate width	4.5 M	4.5 M	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	05 Nos.	05 Nos.	M/R
	• Basement	05 Nos.	05 Nos.	M/R
	b. Width of Staircases			M/R
	• Upper Floor	1.5 m	1.5 m	M/R
	• Basement	1.5 m	1.5 m	M/R
	c. Protection of exits			
	• Fire check door	Required	Provided	M/R
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 no	03 no	M/R
	e. Width of Corridor	1.5 m	1.70 m	M/R
	f. Door Size	1.0 m	1.0 m	M/R
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	Required	Provided	M/R
	• Upper floor	Required	Provided	M/R
5.	Fire Extinguishers			
	• Total numbers	24 nos.	30 nos.	M/R
	• types	ABC & Co2	ABC & Co2	M/R
	• ISI marking	ISI marked	ISI marked	M/R

6	First-aid-Hose Reels.			
	Total numbers of each floor	04 nos.	04 nos.	M/R
	• Length of hose reel hose	30 m	30 m	M/R
	• Nozzle diameter	5 mm	05 mm	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	Required in Auditorium	Provided	M/R
	• Location of main panel	Required	Provided	M/R
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Required	Provided	M/R
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	M/R
9	Public address System.	Required	Provided	M/R
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	M/R
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	M/R
	• Number of hydrants per floor	04 nos	04 nos	M/R
	• Hose Box	04 nos	04 nos	M/R
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 & 450 LPM	900 & 450 LPM	M/R
	➤ Head of the Pump	40 M	40 M	M/R
	➤ Power supply	Required	Provided	M/R
	➤ Auto Starting of pump	Required	Provided	M/R
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	50000 Ltrs	50000 Ltrs	M/R
	➤ Draw-off connection	Required	Provided	M/R
	➤ Fire service inlet	Required	Provided	M/R
	➤ Access to tank	Required	Provided	M/R
	• Overhead Tank capacity	20000 Liters	20000 Liters	M/R
15	Exit Signage.	Required	Provided	M/R

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	M/R
	• Firemen's grounding switch	Required	Provided	M/R
	• Lift Signage	Required	Provided	M/R
17	Standby power supply	N/A	Provided	M/R
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The Fire protection systems provided in the building were Tested / Checked and found functional, at the time of inspection.

Keeping in view, of the deemed compliance, of the minimum standards on Fire prevention and Fire safety measures as required under the rules. The Fire Safety Certificate issued vide letter no F6/DFS/MS/School/2015/NDZ/1628 Dated: 08/09/2015.

F. Brown
19/9/18

Signature of the Inspecting Officer
Name: F. Brown
Designation: DO (East)

submitted for approval plan.

DCFO/NDZ

[Signature]

FIM -

CFP -

m.scell

W 28/9.

*725/CF/NDZ
17/10/18*

F.t. letter is prepared and put up for signature plan.

CF/NDZ

[Signature]

m.scell

W 28/9.

[Signature]
27/9/18