

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2018/SZ/ 2 2 3 7

Dated: 4.10.18

FIRE SAFETY CERTIFICATE

Certified that M/s **Charak Palika Hospital** located at Moti Bagh, New Delhi-110021, comprised of basement, ground plus three upper floors owned/occupied by New Delhi Municipal Council was issued FSC by this department vide letter No. F6/DFS/MS/Hospital/2015/SZ/463 dated 27/03/2015. The premises was re-inspected by officers concerned of this department on 18/09/2018 in the presence of Sh. Sajjan Kumar (Fire Officer/NDMC) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Group-C" (Hospital) as above with effect from 4/10/2018 for period of **Three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010

Issued 4/10/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph. 011-23412225

Copy to: -

1. Sh. Sajjan Kumar (Fire Officer), New Delhi Municipal Council, Palika Kendra, N.Delhi-01

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	M/s Charak Palika Hospital, Moti Bagh, New Delhi-110021		
2	Type of Occupancy	Institutional building, "Group-C" (Hospital)		
3	Building Comprised of	Basement, Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/Hospital/2015/SZ/463 Dt. 27-03-2015		
6	Fire Safety Directives Letter No	F.6/DFS/MS/Hospital/98/337 dated 13-02-1998		
7	Date of Inspection	18-09-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Sajjan Kumar (Fire Officer/NDMC)		
10	Year of construction	1979		
11	Applicant letter No.	Outdoor Diary No. 11823 dated 05-07-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	12 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	03 Nos	02 nos. + 03 ramps	MR
	➤ Basement floor.	01 Nos	01 No ramp	MR (old case)
	b) Width of Staircase			
	➤ Upper floors	1.5m / 2m	1.5m, 1m & ramps- 2m, 1.5m, 1.5m	MR (old case)
	➤ Basement floor	2 mtr	2m x 2 nos.	MR
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	01 + 01 ramp	MR
	e) Width of corridor	2m	Provided	MR
	f) Door size	1.5m	Provided	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers.			
	• Total numbers	Required	50 Nos	MR
	• Types	ABC/W.CO2	ABC & W.CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	3 Nos	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7.	Automatic fire detection & alarming system.			
	• Type of detectors	Required	Heat & Smoke	MR
	• Location of Main Panel	Required	Ground floor	MR
	• Location of Repeater Panel	Required	Fire Control Room	MR
	• Alternate source of power	Required	Provided	MR
	• Hooter's location	Required	Each floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper floors.	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	Required	100 mm	MR
	• Number of Hydrant per floor	Required	03 Nos	MR
	• Hose box.	Required	03 Nos	MR
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump.	1620 LPM	1620 LPM	MR
	➤ Head of main pump.	60m	60m	MR
	➤ Number of main pumps.	One	One	MR
	➤ Jockey Pump output.	180 LPM	180 LPM	MR
	➤ Jockey Pump head.	60m	60m	MR
	➤ Standby Pump output.	1620 LPM	1620 LPM	MR
	➤ Standby Pump head.	60m	60m	MR
	➤ Auto Starting/Manual Stopping.	Required	Provided	MR
	➤ Pump house access.	Required	Provided	MR
	• Terrace Level			
	➤ Discharge of pump.	-NA-	900 LPM x 4 Nos	-NA-
	➤ Head of pump.	-NA-	40m each	-NA-
	➤ Power supply.	-NA-	Provided	-NA-
	➤ Auto starting of pump.	-NA-	Provided	-NA-
14.	Captive water storage for fire fighting.			
	• Underground tank capacity.	5,00,000 Ltr	Provided	MR
	➤ Draw-off connection.	Required	Provided	MR
	➤ Fire Service Inlet.	Required	Provided	MR
	➤ Access to tank.	Required	Provided	MR
	• Overhead tank capacity.	10,000 Ltr	15,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	Required	Provided	MR
	• Fireman's switch.	Required	Provided	MR
	• Lift signage.	Required	Provided	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	Fire Control Room. <ul style="list-style-type: none"> • Detector system panel. • Flow switch panel. • PA system panel. • Battery backup. • Building floor plan. 	Required	Provided	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	ABC type fire extinguishers provided for HT & LT panel	MR

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the Fire Safety Certificate issued vide letter No. F.6/MS/DFS/Hospital/2015/SZ/463 dated 27/03/2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Mehmood
25/9/18

Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

M/s Charak Palika Hospital at Moti Bagh, New Delhi-110021

DO (SD)

Mehmood
25/9/18

DO (SD)

Mehmood
25/9

53/cfo s2
28/9/18



Cfo (S.T)

m-scell

F.T. 101.

Mehmood
28/9.

A c.t. like put up for signature please

Mehmood
28/9/18
ADO (SJ)

DO (SD)

m-scell

Mehmood
28/9/18