

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**



NO. F6/DFS/MS/School/2018/SZ/2231

Dated: 3/10/18

FIRE SAFETY CERTIFICATE

Certified that the SDMC Primary School, Bharthal New Delhi-110077, Building comprised of ground plus one upper floor was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2015/SZ/1170 dated 03.07.2015. The said School building was re-inspected by the officer concerned of this department on 15.09.2018 in presence of Ms. Miny Tendon (In charge) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE GNCT of Delhi Circular no. 3298 to 3398 dated 01.03.2011 and that the building is fit for occupancy class B "Educational building" with effect from 3.10.18.... for a period of **three years** subject to compliance of the conditions printed overleaf.

Issued on ..... 3.10.18 ..... at New Delhi by

  
Vipin Kental  
Chief Fire Officer  


Copy to:-

1. The Director, (Education), SDMC, 23<sup>rd</sup> floor, Civic Centre, Minto Road, New Delhi.
2. The Principal SDMC Girls School, Bharthal, New Delhi-110077.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.



1	Name & address of the building	S.D.M.C. Girls Primary School, Bharthal, New Delhi-110077.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal G+1		
4	Details of previous NOC	F/6/DFS/MS/School/2015/SZ/1170 dated 3.07.2015		
5	Fire safety directives letter No	Edu. Circular. No. F.16/Estate/CC/Fire Safety/2011/3298 dated 01.03.2011.		
6	Date of inspection	15.09.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Ms. Vinay Tondon (Incharge)		
9	Year of construction	2010		
10	Applicant's letter No.	Nil Dated 6.7.2018	Ground plus one upper Floor.	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement DOE. Cir. No. dated 1.3.2011.	Provided at site	Remarks MR / NMR
--------	---	---	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct Accesible from road	MR
	3) Width of internal road	N/A	N/A	N/A

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	2 Nos.	Provided	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1.50 Mtrs.		Provided	MR
	1. Upper floors	N/A	N/A	N/A
	2. basements			
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	e. Width of corridor	1.50 Mtrs.	2.25 Mtrs.	MR
	f. Door size	1 Mtr.	1.08 Mtr.	MR

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Natural Vent.	MR

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	Two each floor per block CO2 OR ABC	7 Nos. ABC	MR MR




4/10

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC Fire Extinguisher Near Electric Panel	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety requirements as per DOE Circular dated 1.3.2011, renewal of fire Certificate issued vide letter no.F6/DFS/MS/School/2015/SZ/1170 dated 3.07.2015 is recommended.

Accordingly DFA is put up for approval and signature please.

  
 S.P. Bhardwaj  
 ADO Dwarka

DO/SW  
 1033/DO(SW)  
 dt. 17/09/18

DO/SW  
 8118/18

DCFO(S2)



demup  
 18/9

UFO sp m.scell FT/M.  
 20/9

FT is put up for signature please

63/CF/S2  
 3/X.

chrs2  
 M.scell 1/10

Say  
 26/9/18