

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2018/NDZ/ 2288

Dated: 10/10/18

FIRE SAFETY CERTIFICATE

Certified that M/s Green Venus Public School running on ground plus one upper floor of the building comprised of ground plus two upper floors located at Main Road Joharipur Delhi-110094, owned/occupied by Green Venus Public School was inspected by the officer concerned of this department in the presence of Mrs.Verma, Principal of the school and found that the school building have complied with the fire prevention and fire safety requirements in accordance with Circular Letter No 262- 362 dated 17/01/2005 issued by Director of Education and observed that ground plus one floor of the school building is fit for occupancy class "B" 'Educational Building' with effect from 10/10/18 for a period of **three** years, subject to conditions, printed overleaf.

Issued on 10/10/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

To,
The Chairman,
M/S Green Venus Public School
Main Road Joharipur
Delhi-110094

Copy:-
The Dy. Director of Education,
B-Block, Yamuna Vihar
Delhi-110053

CONDITIONS

1. Name & address of the building : Green Venus Public School at Gali No. 1, Bhagwan Budh Road, Johripur Extn, Delhi-94
2. Building is comprised of : G+2 (School is running on G+1 only)
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety directive letter No. : Circular 01/03/11 issued by DoE
7. Date of Inspection : 14/09/2018
8. Name of the Inspecting officers : ADO Vijay Bahadur
9. Name and designation of Officer from the building side : Mrs. Arti Verma, Manager
10. Year of Construction : 2003
11. Applicant's letter No :48/2018 dated 04/08/2018

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	06 mtr. N/A N/A	06 mtr. N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	01 nos. N/A	02 nos & 01 upto first floor N/A	MR N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> • Upper floor • Basement 	1.50 mtr N/A	1.05 mtr , 1.05 mtr & 1.20 mtr upto first floor N/A	MR N/A
	c. Protection of Exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of Continuous Staircases to Terrace	01 nos.	01 nos.	MR
	e. Width of Corridor	1.50 mtr.	1.50 mtr.	MR
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> • Basement • Upper floor 	N/A N/A	N/A N/A	N/A N/A
05.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 nos. ABC /CO ₂ ISI marked	04 nos ABC & CO ₂ Provided	MR MR MR

16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of lift shaft • Pressurization of lift lobby • Communication in lift car • Firemen's grounding switch • Lift signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	N/A
18	Refuge Area.			
	<ul style="list-style-type: none"> • Total area • Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building floor plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular No. F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated-01/03/11 issued by Director of Education, it is recommended to issue Fire Safety Certificate.

Vijay Bahadur
18/10/18

Signature of the Inspecting Officer
Name :- Vijay Bahadur
Designation :- A.D.O (T.Pur)

~~DO(ED)~~ *[Signature]*
19/9/18
DUCB/NDZ *[Signature]*

C.F.O. - M.Scell FT 10.
1/10/18.

74/CF NDZ As approved FT letter is put up for signature please.
4/x.

CFO (NDZ) M.Scell *[Signature]*
4/18

Vijay Bahadur
3/10/18