

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

NO. F6/DFS/MS2018/SZ/ 2241

Dated: 4/10/18

**FIRE SAFETY CERTIFICATE**

Certified that the Temple Building located at Plot No. HAF-7, Sec-12, Dwarka, New Delhi, comprised of basement, ground plus one upper floor, owned/occupied by M/s. M R Charitable Trust, was issued fire safety certificate by this department vide letter no. F6/DFS/MS/2012/3053 dated 23.08.2012. The premises was re-inspected by the officer concerned of this department on 27.9.2018 in the presence Sh. Sunil Gupta (Manager) and found that premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service 2010, and that the Premises/ building is fit for occupancy class Group-D Assembly "Building" with effect from ~~4/10/18~~-----for a period of **three years**, subject to compliance of the conditions printed overleaf.

Issued on .....4/10/18..... at New Delhi by

*W 4/10/18*  
(Vipin Kental)  
o/c Chief Fire Officer  
*Sun*

Copy to:-

1. Secretary M.R Charitable Trust, B-4/200, Safdarjung Enclave, New Delhi-110029.
2. The joint Director (L&C), Bldg. DDA Bldg Section, Vikas Sadan, INA, New Delhi.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

1	Name & address of the building	M.R Charitable Trust Temple at Plot No. HAF-7, Sec-12, Dwarka, New Delhi.		
2	Type of Occupancy	Group D, Sub Div-D-3		
3	Type of case	Renewal basement ground plus one upper floor		
4	Details of previous NOC	F/6/DFS/MS/School/2012/3053 dated 23.08.2012		
5	Fire safety directives letter No	F/6/DFS/MS/BP/2011/1017 dated 27.05.2011		
6	Date of inspection	27.09.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Sh. Sunil Gupta (Manager)		
9	Year of construction	2011-2012		
10	Applicant's letter No.	Nil Dated 31.8.2018	<b>Basement Ground plus one upper Floor.</b>	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR / NMR
--------	---	---------------------	------------------	------------------

<b>1</b>	<b>Access to building</b>			
	1) Road width	30 Mtrs.	Provided	MR
	2) Gate width	6 Mtrs.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A

<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	Two	Two	MR
	2. basements	Two	Two	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.50 Mtrs. each	Provided	MR
	2. basements	1.50 Mtrs. each	Provided	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	One	Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	N/A	N/A	N/A

<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A

<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	Exhaust fans Provided	MR
	upper floors		Natural Vent.	MR

<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	08 Nos.	Provided	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>				
	total numbers on each floor	One	Provided		MR
	Length of Hose reel hose	30 m	Provided		MR
	Nozzle Diameter	5 mm	Provided		MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>				
	Type of detectors	N/A	N/A		N/A
	location of Main Panel	N/A	N/A		N/A
	location of Repeater panel	N/A	N/A		N/A
	Alternate source of power	N/A	DG Set 62.5 KVA		N/A
	hooter's location	Near Staircases	Provided		MR
<b>8</b>	<b>MOEFA</b>	Required	Provided		MR
<b>9</b>	<b>Public Address System.</b>	Required	Provided		MR
<b>10</b>	<b>Automatic Sprinkler System.</b>				
	basement	N/A	N/A		N/A
	upper floors	N/A	N/A		N/A
	sprinkler above false ceiling	N/A	N/A		N/A
<b>11</b>	<b>Internal Hydrants</b>				
	Size of riser/down-corner	100 mm	Provided		MR
	Number of Hydrants per floor	One	Provided		MR
	hose Box	Required	Provided		MR
<b>12</b>	<b>Yard Hydrants.</b>				
	total number of hydrants	N/A	N/A		N/A
	hose box	N/A	N/A		N/A
<b>13</b>	<b>Pumping arrangements</b>				
	<b>1. Ground level</b>				
	a. Discharge of main Pump	N/A	N/A		N/A
	b. Head of main pump	N/A	N/A		N/A
	c. Number of main pumps	N/A	N/A		N/A
	d. jockey pump out put	N/A	N/A		N/A
	e. jockey pump head	N/A	N/A		N/A
	f. Standby Pump output	N/A	N/A		N/A
	g. Stanby Pump head	N/A	N/A		N/A
	h. Auto Starting/Manual stopping	N/A	N/A		N/A
	pump house access	N/A	N/A		N/A
	<b>2. Terrace level</b>				
	a. Discharge of pump	900 LPM, 180 LPM	Provided		MR
	b. head of the pump	30 Mtrs.	Provided		MR
	c. Power supply	Required	Provided		MR
	d. Auto starting of pump	Required	Provided		MR
<b>14</b>	<b>Captive water storage for fire fighting</b>				
	1. Underground tank capacity	N/A	N/A		N/A
	a. Draw-off connection	N/A	N/A		N/A
	b. fire service inlet	N/A	N/A		N/A
	c. Access to tank	N/A	N/A		N/A
	Over head tank Capacity	15000 Ltrs.	Provided		MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided		MR
<b>16</b>	<b>Provision of lifts.</b>				
	a. Pressurization of lift shaft	N/A	N/A		N/A
	b. pressurization of lift lobby	N/A	N/A		N/A
	c. communication in lift car	N/A	N/A		N/A
	d. Fireman's grounding switch	N/A	N/A		N/A
	e. Lift signage	N/A	N/A		N/A

N/A

17	Standby power supply	Required	DG Set 62.5 KVA	MR
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: CO2 Fire Extinguisher Near Electric Panel	MR		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the deemed compliance of minimum standards on fire prevention and fire safety requirements as under the rules, renewal of fire Certificate issued vide letter no.F6/DFS/MS/2012/3053 dated 23.08.2012 is recommended.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj  
ADO Dwarka

*Serial 28/8/18*

*DO/SW*  
*1100/DO(SW)*  
*dt. 28/09/2018*

*Original file is not trace out in M.S. cell. Renewal of FSC is put up in park file.*  
*28/8/18*

*72/cfo s2*  
*3/X. 14/11/18*

*DFO(S2)*

*keep*  
*11/X*



*CFO(S2) M.S. cell FT/10, 3/10*

*FT is put up for signature please.*

*cfo s2 m.s. cell 4/X*  
*Serial 41/11/18*