

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001  
Fax No. 011-23412593, Ph. 011-23412225

No. F6/DFS/MS/School/2018/SZ/ 2218

Dated: 3.10.18...

**FIRE SAFETY CERTIFICATE**

Certified that Sarvodaya Co-ED. Sr.Sec. School located at Kitchner Road (Malcha Marg), New Delhi-110021 comprised of ground plus two upper floors was granted Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2015/SZ/848 dated 26/05/2015. The premises was re-inspected by officer concerned of this department on 14/09/2018 in presence of Mr. S.P.Singh (Vice-Principal) and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 3/10/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. Principal, Sarvodaya Co-Ed. Sr. Sec. School, Kitchner Road (Malcha Marg), New Delhi-110021
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. This Certificate cannot be treated a located at s regularization of unauthorized construction, if any.
5. The Owner/Occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
6. The Owner/Occupier shall apply for renewal of this Fire Safety Certificate to the Director in the form 'J' [sub rule (1) of rule 37] along with copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

2117

**INSPECTION REPORT**

1	Name & Address of the Building	Sarvodaya Co-ED. Sr.Sec.School,Kitchner Road (Malcha Marg),New Delhi-110021		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	G+02 upper floor		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/School/2015/SZ/848 dated 26/05/2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	14-09-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. S.P.Singh (Vice-Principal)		
10	Year of construction	1982		
11	Applicant letter No.	SV/KR/2018 dated 10.08.2018		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>As Per Old NOC</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	6 mtr -NA- -NA-	Provided -NA- -NA-	MR -NA- -NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors.</li> <li>Basement floor.</li> </ul>	Three -NA-	Three -NA-	MR -NA-
	<b>b) Width of Staircase</b>			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	1.5 m/0.75m -NA-	1.15m,1.13m & 1.02m -NA-	MR -NA-
	<b>c) Protection of exits</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
	<b>d) No. of continuous staircase to terrace</b>	01 no	Provided	MR
	<b>e) Width of corridor</b>	1.5m	Provided	MR
	<b>f) Door size</b>	1m	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door.</li> <li>Sealing of electrical shafts.</li> <li>Fire rating of shaft door.</li> <li>Water curtain</li> <li>Fire dampers.</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	30 ACPH 12 ACPH	-NA- -NA-	-NA- -NA-
<b>5.</b>	<b>Fire Extinguishers.</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	15 Nos ABC / CO2 ISI marked	15 Nos ABC & Co2 Provided	MR MR MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> <li>Length of hose-reel hose.</li> <li>Nozzle Diameter</li> </ul>	Two 30m 5mm	03 no's Provided Provided Provided	MR MR MR

2/18

<b>7.</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
<b>8.</b>	<b>MOEFA</b>	-NA-	-NA-	-NA-
<b>9.</b>	<b>Public Address System</b>	-NA-	-NA-	-NA-
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
<b>11.</b>	<b>Internal Hydrants.</b>			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
<b>12.</b>	<b>Yard Hydrants.</b>			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
<b>13.</b>	<b>Pumping arrangements.</b>			
	<b>• Ground Level</b>			
	➤ Discharge of main pump.	-NA-	-NA-	-NA-
	➤ Head of main pump.	-NA-	-NA-	-NA-
	➤ Number of main pumps.	-NA-	-NA-	-NA-
	➤ Jockey Pump output.	-NA-	-NA-	-NA-
	➤ Jockey Pump head.	-NA-	-NA-	-NA-
	➤ Standby Pump output.	-NA-	-NA-	-NA-
	➤ Standby Pump head.	-NA-	-NA-	-NA-
	➤ Auto Starting / Manual Stopping.	-NA-	-NA-	-NA-
	➤ Pump house access.	-NA-	-NA-	-NA-
	<b>• Terrace Level</b>			
	➤ Discharge of pump.	450 LPM	450 LPM X2	MR
	➤ Head of pump.	40m	40 m each	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
<b>14.</b>	<b>Captive water storage for fire fighting.</b>			
	• Underground tank capacity.	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet.	-NA-	-NA-	-NA-
	➤ Access to tank.	-NA-	-NA-	-NA-
	• Overhead tank capacity.	10,000 Ltr	Provided	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby.	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage.	-NA-	-NA-	-NA-
<b>17.</b>	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
<b>18.</b>	<b>Refuge Area</b>			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

2119

19.	<b>Fire Control Room.</b>	• Detector system panel.	-NA-	-NA-	-NA-
		• Flow switch panel.	-NA-	-NA-	-NA-
		• PA system panel.	-NA-	-NA-	-NA-
		• Battery backup.	-NA-	-NA-	-NA-
		• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	ABC type fire extinguisher provided near electrical panel	-NA-	

The Fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Shortcoming issued by the department on 29/05/2018 have been compiled.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, FSC issued vide letter No. F.6/DFS/MS/School/2015/SZ/848 dated 26/05/2015, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Mehmood*  
28/9/18

Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

DO (SD)

*Anil Das*  
2-9/18

*Dy. Chf (S2)*



*deaf*  
24/9

*48/cfs2*  
25/9/18

*CFO S2 M. Scell*      *F7/M'*  
*25/9*

*D. O. of Delhi for us for Signature Please*

*Mehmood*  
28/9/18  
ADO (SJ)