

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F-6/DFS/MS/2018/ W2/2235

Dated: 4 /10/2018

FIRE SAFETY CERTIFICATE

Certified that the building of **ShriSatyaSai Baba Jaghira Foundation and Educational Trust Located at NS-27,BK-1, Shalimar BaghPoorvi, Behind Mother Dairy, Delhi** . comprised of Ground + 01 Upper Floors, owned and occupied by **ShriSatyaSai Baba Jaghira Foundation and Educational Trust** have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education/ NBC Part IV and verified by the officers concerned of Fire Service on 27-09-2018 in the presence of Smt. Adity (Employee) and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from ..4.10.18... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on4.10.18..... at New Delhi.

(AtulGarg)

Chief Fire Officer,
Delhi Fire Service

Copy to:

1. **The Principal,ShriSatyaSai Baba Jaghira Foundation and Educational Trust ,NS-27,BK-1, Shalimar BaghPoorvi, Behind Mother Dairy, Delhi .**
2. **Director of Education, Old Sectt. Delhi-110054.**

Condition for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviations with regard to construction etc shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. There shall be no more than 45 students in class rooms in any case.

1. Name & address of the building: **Shri Satya Sai Baba Jaghira Foundation and Educational Trust** Located at **NS-27,BK-1, Shalimar Bagh Poorvi, Behind Mother Dairy, Delhi .**
2. Type of Occupancy : Educational (Ground + 1 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : DOE F-6/DFS/MS/BP/931 dated 22/03/2005
6. Date of inspection : 27-09-2018
7. Name of the Inspecting Officer :Do/ W, ADO (WP)
8. Name and designation of Officer
from the building side :Smt. Monika Malik (Branch Head)
9. Year of Construction : 2006
10. Applicant's letter No. :Nil dated Nil

No. of Students=87 No. of class rooms=10 Plot area=900 m ² Covered area=6000 Sq.ft
--

S No	Minimum standards on fire prevention and fire safety U/R 33	Directive issued	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	13m Provided	MR
	• Gate width	Accessible	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2x150cm	2 x150cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 m	2x80cm	MR (As no. of students are only 15 in each class)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	02 nos.	04 Provided	MR

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Required 30m 5mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm one 1	Provided 01 Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA 450lpm 40m Required Required	NA NA NA NA NA NA NA NA NA NA 450 LPM 40m Provided Provided	NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10000lrs	NA NA NA NA 10000 ltr	NA NA NA NA Provided
15	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car 	NA NA NA	NA NA NA	NA NA NA

17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNIL.....

Note :- 1. The Total area of individual class Room is 24.75 M².

3. The number of students in any class are not more than 15.

4. Each Class Room having two Exits of 80 cm clear width. Thus it meets with Exit Requirement.

~~Signature of the Inspecting Officer
Name UdaiVir Singh
Designation ADO/WP~~

~~Signature of the Inspecting Officer
Name Shri Mukesh Verma
Designation DO/W~~

~~Signature of the Inspecting Officer
Name UdaiVir Singh
Designation ADO/WP~~

~~Signature of the Inspecting Officer
Name Shri Mukesh Verma
Designation DO/W~~

FTDS

Approved F.T. letter is put up for signature please.

~~Signature of the Inspecting Officer
Name UdaiVir Singh
Designation ADO/WP~~

~~Signature of the Inspecting Officer
Name Shri Mukesh Verma
Designation DO/W~~