

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No. F6/DFS/MS/EH/2018/WZ/ 2441

Dated: 31/10 /2018

FIRE SAFETY CERTIFICATE

Certified that the **Games of Legends (A unit of Timehouse Café Pvt. Ltd.)** located at **TF – 02A, City Square Mall, Shivaji Palace, III Floor, Raja Garden, New Delhi – 110027** was issued FSC vide Letter No. F6/DFS/MS/EH/2015/WZ/1125 dated 30/06/15. FSC issued to the mall has already been renewed by deptt vide letter no. F6/DFS/MS/2017/WZ/773 dated 30-05-2017. The premises was re inspected by the officers concerned of this department on 18-10-2018 in the presence of Mr. Surendra Dabas (Director) and found that the said building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 31/10/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/10/18..... at New Delhi by


(Atul Garg)
Chief Fire Officer
016/2
29/10/18

Copy to:

1. The Director,
Games of Legends (A unit of Timehouse Café Pvt. Ltd.)
TF-02 A, Third Floor, City Square Mall, Raja Garden, New Delhi.
2. The Dy. Health Officer, SDMC, Health Department,
West Zone, Rajouri Garden, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

1. Name & address of the building: **Game of Legends (A unit of Timehouse Café Pvt. Ltd.)**

Located at TF-02 A, Third Floor, City Square Mall, Raja Garden, New Delhi.

2. Type of Occupancy : Class D(Assembly)

3. Type of Case : Renewal

4. Details of previous NOC : Letter No. F6/DFS/MS/EH/2015/WZ/1125 dated 30/06/15

5. Fire Safety directives Letter No. : Nil (FSC issued to mall vide Letter No. F6/DFS/MS/2017/WZ/773 dated 30-05-2018).

6. Date of inspection : 18-10-2018

7. Name of the Inspecting Officer : DO (West)

8. Name and designation of Officer

from the building side : Sh. Surendra Dabas (Director)

9. Year of Construction : 2011

10. Applicant's letter No. : Nil dated 18.9.2018

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site | Remarks MR/NMR |
|------|---|----------------------|------------------|----------------|
| 1. | Access of building(For Mall) | | | |
| | • Road width | 09mtrs | 30 mtr | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits (For Mall) | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 3 | 3 | In mall/MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1.5 mtr | Provided by mall | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | MR |
| | • Pressurization | NR | NR | NR |
| | d. No of continuous staircase to terrace | 3 | 3 | MR |
| | e. Width Of Corridor | Required | Provided | MR |
| | f. Door Size | 2 mtrs & 1 m | Provided | MR |
| 3. | Compartmentation (For Mall) | | | |
| | • Fire check door | Required | Provided | MR |
| | • Sealing of electrical shafts | Required | Provided | MR |
| | • Fire Rating of shaft door | 4 hrs | Provided | MR |
| | • Water Curtain | NR | NR | MR |
| | • Fire Dampers | NR | NR | MR |
| 4. | Smoke managements System | | | |
| | • Basements | NA | NA | NA |
| | • Upper floors | Required | Provided | MR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 4 nos. | Provided | MR |
| | • Types | ABC, CO ₂ | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6. | First – Aid Hose Reels (For Mall) | | | |
| | • Total numbers on each floor | Required | Provided | MR |

| | | | | |
|-----|--|----------------------|--------------------------|-------------------|
| | Type of detectors | Smoke & Heat | Provided | MR |
| | • Location of Main Panel | Ground floor | Provided | MR |
| | • Location of Repeater Panel | Ground floor | Provided | MR |
| | • Alternate source of power | Required | 2 Generator 450 KVA each | MR |
| | • Hooters' Location | Required | Provided | MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | Required | Provided | MR |
| | • Upper Floor | Required | Provided | MR |
| | • Sprinkler above false ceiling | Required | Provided | MR |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down- comer | 150 mm | 150 mm | MR |
| | • Number of hydrants per floor | Required | Provided | MR |
| | • Hose Box | Required | Provided | MR |
| 12. | Yard Hydrants (For Mall) | | | |
| | • Total number of hydrants | 4 | Provided | MR |
| | • Hose Box | Required | Provided | MR |
| 13. | Pumping Arrangements (For Mall) | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | 2850LPM | Provided | MR |
| | ➤ Head of main pump | 60mtr | Provided | MR |
| | ➤ Number of main pumps | 1 | Provided | MR |
| | ➤ Jockey pump out put | 180 lpm | Provided | MR |
| | ➤ Jockey pump head | 60mtr | Provided | MR |
| | ➤ Standby Pump out put | 2850lpm | Provided | MR |
| | ➤ Standby Pump Head | 60 mtr | Provided | MR |
| | ➤ Auto Staring/Manual stopping | Required | Provided | MR |
| | ➤ Pump House Access | Required | Provided | MR |
| | • Terrace level | | | |
| | ➤ Discharge of pump | Common with the mall | | |
| | ➤ Head of the pump | 900 lpm | NP | MR for restaurant |
| | ➤ Power supply | 40 mtr | NP | MR for restaurant |
| | ➤ Auto starting of pump | Required | Provided | MR |
| | | Required | Provided | MR |
| 14. | Captive water Storage for fire fighting (For Mall) | | | |
| | • Under ground tank capacity | 1,00,000 litres | Provided | MR |
| | ➤ Draw of connection | Required | Provided | MR |
| | ➤ Fire service inlet | Required | Provided | MR |
| | ➤ Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | 30, 000 litres | Provided | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | Required | Provided | MR |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Pl | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |
|-----|--|----|----|----|

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/EH/2015/WZ/1125 dated 30/06/15 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Mukesh
22/11/18

Signature of the Inspecting Officer

Name Mukesh Verma

Designation DO (West)

~~Dy. CPO WZ/~~
~~CPO West/W~~
23/10/18
FT 74

[Signature]
23/10/18

DD/W F.T./FSL is put up for signature please.

~~CPO (WZ)~~
~~W~~
29/10/18

Mukesh
29/11/18

M