

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 2445

Dated: 31/10/18

FIRE SAFETY CERTIFICATE

Certified that the Uma Public School located at 170-A, Pusta Road, Purana Shiv Mandir, Village Aali, Sarita Vihar New Delhi-110076, comprised of Ground plus one upper floor Owned/Occupied by **Uma Educational Trust** was inspected by the officer concerned of this department on 12/10/2018 in presence of Mr. Kishan Kumar Mehto (Owner) of the school and found that said premises have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the school building is fit for occupancy class "**Educational Building**" Group-B, as above with effect from the date of issue of this certificate for a period of **Three years**, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/10/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, Uma Public School, 170-A, Pusta Road, Purana Shiv Mandir, Village Aali, Sarita Vihar New Delhi-110076.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.

INSPECTION REPORT

1	Name & Address of the Building	Uma Public School,170-A,Pusta Road, Purana Shiv Mandir, Village Aali, Sarita Vihar New Delhi-110076		
2	Type of Occupancy	Educational Building (School)		
3	Building Comprised of	Ground plus one upper floor.		
4	Type of Case	New		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of Inspection	12/10/2018		
8	Name of the Inspecting Officers	Mehmood ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Kishan Kumar Mehto (Owner)		
10	Year of construction	2011		
11	Applicant letter No.	Nil Dated 24/09/2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	DOE circular requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	6 mtr -N/A- -N/A-	7 mtr -N/A- -N/A-	MR -N/A- -N/A-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors ➤ Basement floor 	01 no -N/A-	02 Nos -N/A-	MR -N/A-
	b) Width of Staircase			
	<ul style="list-style-type: none"> ➤ Upper floors. ➤ Basement floor 	1.50m -N/A-	1.50 m & 0.77m -N/A-	MR -N/A-
	c) Protection of exits			
	<ul style="list-style-type: none"> ➤ Fire check door ➤ Pressurization 	-N/A- -N/A-	-N/A- -N/A-	-N/A- -N/A-
	d) No. of continuous staircase to terrace	01 No	Provided 02 nos	MR
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door. • Sealing of electrical shafts. • Fire rating of shaft door. • Water curtain • Fire dampers. 	-N/A- -N/A- -N/A- -N/A- -N/A-	-N/A- -N/A- -N/A- -N/A- -N/A-	-N/A- -N/A- -N/A- -N/A- -N/A-
4.	Smoke Management system.			
	<ul style="list-style-type: none"> • Basement • Upper floors 	-N/A- -N/A-	-N/A- -N/A-	-N/A- -N/A-
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> • Total numbers • Types • ISI Marking 	03 nos ABC / Co2 ISI Marked	04 No's ABC- 03,Co2-01 Provided	MR MR MR
6.	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor. • Length of hose-reel hose. • Nozzle Diameter 	-N/A- -N/A- -N/A-	-N/A- -N/A- -N/A-	-N/A- -N/A- -N/A-

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Location of Main Panel 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Location of Repeater Panel 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Alternate source of power 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Hooter's location 	-N/A-	-N/A-	-N/A-
8.	MOEFA	-N/A-	-N/A-	-N/A-
9.	Public Address System	-N/A-	-N/A-	-N/A-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Upper floors 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	-N/A-	-N/A-	-N/A-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Number of Hydrant per floor 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Hose box. 	-N/A-	-N/A-	-N/A-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Hose box. 	-N/A-	-N/A-	-N/A-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main pump. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Head of main pump. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Number of main pumps. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Jockey Pump output. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Jockey Pump head. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Standby Pump output. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Standby Pump head. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Auto Starting/Manual stopping. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Pump house access. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Terrace Level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Head of pump. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Power supply. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Auto starting of pump. 	-N/A-	-N/A-	-N/A-
14.	Captive water storage for firefighting.			
	<ul style="list-style-type: none"> Underground tank capacity. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Draw-off connection. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Fire Service Inlet. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> ➤ Access to tank. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Overhead tank capacity. 	-N/A-	-N/A-	-N/A-
15.	Exit Signage.	-N/A-	-N/A-	-N/A-
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Pressurization of lift lobby. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Communication in lift car. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Fireman's switch. 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Lift signage. 	-N/A-	-N/A-	-N/A-
17	Standby Power Supply	-N/A-	-N/A-	-N/A-
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	-N/A-	-N/A-	-N/A-
	<ul style="list-style-type: none"> Location 	-N/A-	-N/A-	-N/A-


2/14

19.	Fire Control Room.			
	• Detector System Panel.	-N/A-	-N/A-	-N/A-
	• Flow Switch Panel.	-N/A-	-N/A-	-N/A-
	• PA system Panel.	-N/A-	-N/A-	-N/A-
	• Battery backup	-N/A-	-N/A-	-N/A-
	• Building floor plan	-N/A-	-N/A-	-N/A-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-N/A-	-N/A-	-N/A-

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.



Signature of the Inspecting Officer
Name : Mehmood
Designation: ADO (SJ)

DO (SD)

Anilak
23/10/18

dy. CFO

154/cfo sr
29/X/31/X.

dy. CFO
20/X



CFO 27/1

M.Scell

FTD.

ve
26/X.

A. B.T letter has up for signature please

Mehmood
30/10/18
ADO (SJ)

CFO 22

M.Scell *ve*
30/X