

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2018/WZ/ 2472

Dated: 2 / 11 /2018

FIRE SAFETY CERTIFICATE

Certified that the Building at Aar Aay Products (Pvt.) Ltd. located at G-1, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041, comprised of Basement, Ground Floor, Mezzanine Floor & First Floor only owned / occupied by Aar Aay Products (Pvt.) Ltd., has already been issued Fire Safety Certificate vide letter No F6/DFS/MS/2015/WZ/677 dated 05/05/2015 The premises / Building was re-inspected by the officer concerned of Fire Service on 25.10.2018 in the presence of Sh. Avatar Singh Grover (Manager) and found that building / premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for occupancy class Industrial with effect from 2 / 11 /2018 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 2.11.18 at New Delhi.


(ATUL GARG)
CHIEF FIRE OFFICER

Copy to :-

1. Sh. Avatar Singh Grover (Manager), G-1, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. “The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form ‘J’ [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry”.
8. The owner / occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

1. Name & address of the building: Aar Aay Products (Pvt.) Ltd., G-1, Udyog Nagar, Industrial Area, Rohtak Road, New Delhi-110041.
2. Type of Occupancy : Industrial
3. Type of Case : Renewal
4. Details of previous NOC : Letter No F6/DFS/MS/2015/WZ/677 dated 05/05/2015
5. Fire Safety directives Letter No. : F.6/DFS/MS/BP/85/511 dated 25/05/1985
6. Date of inspection : 25.10.2018
7. Name of the Inspecting Officer : A.K. Jaiswal (A.D.O. JWP)
8. Name and designation of Officer from the building side : Sh. Avatar Singh Grover (Manager)
9. Year of Construction : 1990
10. Applicant's letter No. : Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL/ Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr.	6 Mtr.	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2	MR
	b. Width of staircases			
	• Upper floors	1.20 mtr	1.50 mtr x 1, 1.20 mtr x 1	MR
	• Basements	1.20 mtr	1.50 mtr x 1, 1.25 mtr x 1 2.10 mtr x 1	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	One	One	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.00 mtr	1.00 mtr	MR
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	Required	Exhaust Fan	MR
	• Upper floors	Required	Exhaust Fan	MR

	• Total numbers	12	15	MR
	• Types	ABC/CO ₂ /WCO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NR	NR
9.	Public Address System	NR	NR	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down- comer	Not Mentioned in previous NOC	150mm	MR
	• Number of hydrants per floor	NR	Provided	NR
	• Hose Box	NR	Provided	NR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level / Over Head			
	• Discharge of main pump	NR	NR	NR
	➤ Head of main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby Pump out put	NR	NR	NR
	➤ Standby Pump Head	NR	NR	NR

	• Terrace level			
	➤ Discharge of pump	Not Mentioned in previous NOC	900 LPM	MR
	➤ Head of the pump	Not Mentioned in previous NOC	40MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	➤ Under Ground Tank capacity	62,000 Ltr. Approx.	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 Ltr.	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Batter backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

Note: -1. MCB, ELCB, Electrical wiring concealed type were found provided in the premises.

2. Shortcomings issued by this department vide letter No.F6/DFS/MS/2018/2417 dated 08/06/2018 have been complied.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2015/WZ/677 dated 05/05/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O. / (rest)

[Signature]
26/8/18

[Signature]

[Signature]
26/8/18

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)