

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6/DFS/MS/School/2018/SZ/ 2463

Dated: ..... 01/11/18

**FIRE SAFETY CERTIFICATE**

Certified that the Delhi Police Public School located at B-4, Safdarjung Enclave, New Delhi-110029 comprised of basement, ground plus three upper floors (one block) and ground plus two upper floor (one block) was issued FSC by this department vide letter No. F6/DFS/MS/2015/SZ/948 dated 09-06-2015. The premises was re-inspection by officer concerned by this department on 22/10/2018 in the presence of Mr. Saleem (Admin Officer) and observed that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the school building is fit for occupancy class "Educational" Group-B (School upto Sr. Sec. Level) as above with effect from 01/11/2018 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 01/11/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225

Copy to: -

1. The HOS, Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi-110029
2. Directorate of Education, S.D.M.C, Dr. SPM Civic Centre, Minto Road, New Delhi-110002

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

**INSPECTION REPORT**

1	Name & Address of the Building	Delhi Police Public School, B-4, Safdarjung Enclave, New Delhi-110029		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	B+G+3 (One Block), G+2 (One Block)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2015/SZ/948 dated 09-06-2015		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	22-10-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Saleem (Admin Officer)		
10	Year of construction	1998		
11	Applicant letter No.	DPPS/466 dated 25-09-2018		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	6m	12 mtr	MR
	• Gate width	Required	5m	MR
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos each Bk	A Block-02 Nos B Block-05 Nos	MR
	➤ Basement floor.	02 Nos	05 Nos	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.50 mtr	A Block: 1,80m each & B Block-1.80, 1.31, 1.31, 1.08m & 1.08m	MR
	➤ Basement floor	1.50 mtr	2.3m,1.2m,2.8m,0.97m & 1.31m	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	-NA-	-NA-	-NA-
	<b>e) Width of corridor</b>	Required	1.50 mtr	MR
	<b>f) Door size</b>	Required	1 mtr	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust fan provided	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
<b>5</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	48 Nos	48 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	03 Nos	03 Nos	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8	<b>MOEFA</b>	-NA-	-NA-	-NA-
9	<b>Public Address System</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box.</li> </ul>	100mm 01 each Bk 01 each Bk	150 mm Provided Provided	MR MR MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box.</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
13	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b> <ul style="list-style-type: none"> <li>Discharge of main pump.</li> <li>Head of main pump.</li> <li>Number of main pumps.</li> <li>Jockey Pump output.</li> <li>Jockey Pump head.</li> <li>Standby Pump output.</li> <li>Standby Pump head.</li> <li>Auto Starting/Manual Stopping.</li> </ul> </li> <li><b>Terrace Level</b> <ul style="list-style-type: none"> <li>Discharge of pump.</li> <li>Head of pump.</li> <li>Power supply.</li> <li>Auto starting of pump.</li> </ul> </li> </ul>	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 900 LPM 40 mtr Required Required	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 450 + 450 LPM 40m each Provided Provided	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- MR MR MR MR
14	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity. <ul style="list-style-type: none"> <li>Draw-off connection.</li> <li>Fire Service Inlet.</li> <li>Access to tank.</li> </ul> </li> <li>Overhead tank capacity.</li> </ul>	-NA- -NA- -NA- -NA- 10,000 Ltr	-NA- -NA- -NA- -NA- 10000 + 5000 + 5000 Ltr	-NA- -NA- -NA- -NA- MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> <li>Pressurization of lift lobby.</li> <li>Communication in lift car.</li> <li>Fireman's switch.</li> <li>Lift signage.</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
17	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-
18	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-

Delhi Police Public School at B-4, Safdarjung Enclave, New Delhi-110029

N/14

19	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>			-NA-
<p>The fire protection systems provided in the premises were checked/ tested at random and found functional at the time of inspection.</p> <p>Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/2015/SZ/948 dated 09-06-2015, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p>				
<p><i>Mehmood</i> Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ)</p>				

Delhi Police Public School at B-4, Safdarjung Enclave, New Delhi-110029

DO (SD)

*Anilash*  
29/1/18

*dy. cfo (S)*



*dy. cfo*  
29/1/18

M.Scell *u* 30/1/18

157/CFO/SZ CFO/SJ  
30/1/18/1111

A. B.T. letter put up for signature please

*Mehmood*  
30/1/18  
Amroli S

*CFO (S)*  
M.Scell *u* 31/1/18