

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6/DFS/MS/School/2018/SZ/ 2444

Dated: 31/10/18

**FIRE SAFETY CERTIFICATE**

Certified that the Holy Child Auxilium School, located at Poorvi Marg, Vasant Vihar, New Delhi-110057 comprised of ground plus two upper floors was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/2015/SZ/1839 dated 13/10/2015. The premises was re-inspected by officer concerned of this department on 15/10/2018 in presence of Mrs. Anita (Incharge) and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational Building" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 31/10/18 at New Delhi by

(Vipin Kental)  
Chief Fire Officer

Copy to: -

1. The Principal, Holy Child Auxilium School, Poorvi Marg, Vasant Vihar, New Delhi-110057.
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

## INSPECTION REPORT

1	Name & Address of the Building	Holy Child Auxilium School, Poorvi Marg, Vasant Vihar, New Delhi-110057		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	Ground Plus Two Upper Floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/2015/SZ/1839 dated 13/10/2015.		
6	Fire Safety Directives Letter No	F6/MS/DFS/2005/420 Dated 04/07/2005		
7	Date of Inspection	15/10/2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Anita (Incharge)		
10	Year of construction	2006		
11	Applicant letter No.	Nil dated 25/09/2018		
<b>S. No.</b>	<b>Minimum standards on Fire Prevention and Fire Safety U/R 33</b>	<b>Old NOC requirements</b>	<b>Provided at Site</b>	<b>Remarks MR/NMR</b>
<b>1</b>	<b>Access to Building.</b>			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	5mtr	5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	03 Nos	03 Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5m/0.75m	1.50m, 1.50m & 1.45m	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	01 No	01 nos	MR
	<b>e) Width of corridor</b>	1.5m	Provided	MR
	<b>f) Door size</b>	1 mtr	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	12 Nos	20 Nos	MR
	• Types	ABC/CO2	ABC	MR
	• ISI Marking	ISI mark	Provided	MR

6.	<b>First Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor.</li> </ul>	02 nos	02 nos	MR
	<ul style="list-style-type: none"> <li>Length of hose-reel hose.</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>Nozzle Diameter</li> </ul>	5mm	5mm	MR
7	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Hooter's location</li> </ul>	-NA-	-NA-	-NA-
8.	<b>MOEFA</b>	-NA-	Provided	-NA-
9.	<b>Public Address System</b>	-NA-	Provided	-NA-
10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
11.	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	-NA-	100mm	-NA-
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	-NA-	02 nos	-NA-
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	-NA-	02 nos	-NA-
12.	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Hose box.</li> </ul>	-NA-	-NA-	-NA-
13.	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li><b>Ground Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Head of main pump.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Number of main pumps.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Jockey Pump output.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Jockey Pump head.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Standby Pump output.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Standby Pump head.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Auto Starting / Manual Stopping.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Pump house access.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li><b>Terrace Level</b></li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of pump.</li> </ul>	450 LPM	450 LPM & 180 LPM	MR
	<ul style="list-style-type: none"> <li>Head of pump.</li> </ul>	40 mtr	40 mtr each	MR
	<ul style="list-style-type: none"> <li>Power supply.</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Auto starting of pump.</li> </ul>	Required	Provided	MR
14.	<b>Captive water storage for firefighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Draw-off connection.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Fire Service Inlet.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Access to tank.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Overhead tank capacity.</li> </ul>	10,000 liter	10,000 liter	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Communication in lift car.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Fireman's switch.</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Lift signage.</li> </ul>	-NA-	-NA-	-NA-
17.	<b>Standby Power Supply</b>	-NA-	-NA-	-NA-

18.	Refuge Area	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>			
19.	Fire Control Room.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Detector system panel.</li> <li>Flow switch panel.</li> <li>PA system panel.</li> <li>Battery backup.</li> <li>Building floor plan.</li> </ul>	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F.6/DFS/MS/2015/SZ/1839 dated 13/10/2015., renewal under rule 37 of the Delhi Fire Service Rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

*Jamshed*  
22/10/18

Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

DO (SD)

*Jamshed*  
23/10/18

*Dr. CPD(S2)*

*Lamp*  
23/10



CFO S/P

M.Scell F.T.M.

*W*  
26/10

A. D.T. Lohia put up for signature please

*Jamshed*  
26/10/18  
ADDO(SJ)

169/CPD S2  
31/10

CPD S2/2 M.Scell *W*  
31/10