

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI


No. F6/DFS/MS/2018/WZ/ 2473

Dated: 2/11/18

**FIRE SAFETY CERTIFICATE**

Certified that the Maharaja Agrasen Model School, located at, C D Block, Pitampura, Delhi – 110034 comprised of Basement + Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2015/WZ/SCHOOL/1971 Dated 03-11-2015. The premises was re inspected by the officer concerned of this department on 22-10-2018 in the presence of Sh. R. K. Bansal (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 3298-3398 dated 01-03-2011 and that the premises is fit for occupancy class "Educational" Group B with effect from 2/11/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ... 2.11.18 ..... at New Delhi by.

  
(Atul Garg)  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Principal, Maharaja Agrasen Model School, C D Block, Pitampura, Delhi – 34.
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

- Name & address of the building: Maharaja Agrasen Model School, C D Block, Pitampura, Delhi – 110034.
- Type of Occupancy : Educational (Basement + Ground + 2 Upper Floor)
- Type of Case : Renewal
- Details of previous NOC : F6/DFS/MS/2015/WZ/SCHOOL/1971 Dated 03-11-2015
- Fire Safety directives Letter No. : DOE Circular3298-3398 dated 01-03-2011
- Date of inspection : 22-10-2018
- Name of the Inspecting Officer : Udai Vir singh, ADO (WP)
- Name and designation of Officer from the building side : Sh. R. K. Bansal (Manager)
- Year of Construction : 1985
- Applicant's letter No. : MAMS/2018-19/352 Dated 24-09-2018

Plot Area - 1209 M <sup>2</sup>
Covered Area -7099M <sup>2</sup>
No. or Class Rooms-63
No. of Student- 2492

S N o	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.3298-3398 dated 17-01-03-2011	Provided at site	Remarks
1.	Access of building			
	• Road width	Accessible	Provided >15m	MR
	• Gate width	Accessible	4m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4	4 Provided	MR
	• Basements	2	2 Provided	MR
	b. Width of staircases			
	• Upper floors	1.5m	3x135cm & 1x120cm	MR(Old case)
	• Basements	1.5m	1x130cm & 1x3m	MR(Old case)
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase terrace	2	Provided	MR
	e. Width Of Corridor	1.5m	290 cm Provided	MR
	f. Door Size	100cm	Provided(110cm)	MR



3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided (Exhaust fan)	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	32 nos. ABC & CO <sub>2</sub> ISI marked	Provided	MR
	• Types		Provided	MR
	• IS marking		Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA			
		NA	Provided	NA
9.	Public Address System			
		NR	Provided	MR
10	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA


13	Pumping Arrangements:			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		900lpm,220 lpm	Provided	MR
		40Mtr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	Provided	NA
		NA	NA	NA
		5,000Ltr	Provided (15000 ltrs)	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> <li>➤ Pressurization of Lift Shaft</li> <li>➤ Pressurization of lift lobby</li> <li>➤ Communication in lift Car</li> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	NA	Provided	NA
18	Refuge Area			
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Battery backup</li> <li>➤ Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA




20	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.


In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/WZ/SCHOOL/2015/1971 Dated 03-11-2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer   
 Name Uday Vir Singh  
 Designation ADDO/W P

Signature of the Inspecting Officer   
 Name \_\_\_\_\_  
 Designation \_\_\_\_\_

D/O  
Inspector 25/11/18  
Dy. CFO (WZ)  
CFO West 29/10/18

F705  
ADDO/W P

Sir AP letter is put up for  
 sign ple.   
CFO WZ 31/10