

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/EH/NDZ/2018 / 2471

Dated: 21/11/18

FIRE SAFETY CERTIFICATE

Certified that the M/s Maini's Green Leaf Restaurant (A Unit of SKM Food India) at Shop no.- 201 & 202, 2nd Floor, Aggarwal fun city mall of Unity group, at CBD Ground, Shahdara, Near Karkardooma court, Delhi, owned / occupied by SKM. Food India. was inspected by the officer concerned of this department on 14/10/2018 in the presence of Sh. Arun Maini, Owner of the premises and found that the Assembly building have complied with the Fire prevention and Fire safety requirements in accordance with the rules 33 of Delhi Fire Service Rules, 2010 and observed that the premises is fit for occupancy Group "D" Assembly Building with effect from ..21.11.18.....for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010. The conditions printed overleaf.

Issued on.....21.11.18.....at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Deputy Health Officer, Shahdara (South) Zone,  
East Delhi Municipal Corporation, M.C.D. Office,  
Karkardooma, Shahdara, Dehi.
2. M/s Maini's Green Leaf Restaurant(A Unit of SKM Food Inida),  
Shop no. - 201 & 202, 2nd Floor, Unity one Mall,  
CBD Ground, Shahdara, Near Karkardooma court, Delhi.

## CONDITIONS

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



## INSPECTION REPORT

1. Name & address of the building : M/s Maini's Green Leaf restaurant at 201, 202, 2<sup>nd</sup> Floor, Agarwal fun city of Unity Group  
CBD Ground, Shahdara, Near Karkardooma court, Delhi.
2. Building is comprised of : Basement, Ground plus Two upper floors
3. Type of Occupancy : Assembly (Eating House)
4. Type of Case : New
5. Details of Previous FSC : Nil
6. Fire Safety direction letter No : NBC Part IV
7. Date of Inspection : 14/10/18.
8. Name of the Inspecting Officers: : F.Brown (Do/East)
9. Name of the designation of Officer :  
from the building side : Sh. Arun Maini (Owner)
10. Year of Construction : 2005
11. Applicant's letter No : No.DHO/Shd/South/2018/2128 dated 04/10/18.

	Minimum Standards on fire prevention and fire safety U/R 33	Requirement under NBC IV	Provided at Site	Remarks
1	Access to building			MR/NMR
	Road width	12 m	26 m wide	MR
	Gate width	4.5 mtrs.	5 mtrs.	MR
	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.	Mall		
	a. Number of Staircases			
	Upper Floor (Mez Floor)	02 Nos.	03 Nos.	MR
	Basement	N/A	N/A	N/A
	B. Width of Staircases			
	Upper Floor	2.0 m	1.5 m x 3 & 1-esc G to II floor	MR
	Basement	N/A	Required	Provided
	c. Protection of exits			
	Fire check door	Required	Provided	MR
	Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	03	03	MR
g. Width of Corridor	N/A	N/A	N/A	
h. Door Size	2.0 m	2.0 m	MR	
i. No. of doors	02 no	02 no	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	MR
	Sealing of electrical shafts	Required	Provided	MR
	Fire rating of shaft door	Required	Provided	MR
	Water curtain	N/A	N/A	N/A
	Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	Basement	N/A	N/A	N/A
	Upper floor	N/A	Provided	MR
5.	Fire Extinguisher			
	Total numbers	04 Nos.	06 Nos.	MR
	types	ABC type & Co2	ABC type & Co2	MR
	ISI marking	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers on each floors	02 nos.	02 nos.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Required	Heat & smoke	MR
	Location of main panel	Control room	1st Bsement	MR
	Location of repeater panel	Security office	Provided	MR
	Alternate source of power	Required	Provided	MR
	Hooters	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	Provided	MR
10	Automatic Sprinkler System.			
	Basement	N/A	Provided in	MR
	Upper floor sprinkler above false ceiling	N/A	entire Basement	MR
		N/A	Provided	MR
		N/A	Provided	MR
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants each floor	03nos.	03 nos.	MR
	Hose box each floor	03 nos.	03 nos.	MR
12	Yard Hydrants.			
	Total number of hydrants	N/A	N/A	N/A
	Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	2280 LPM	MR
	➤ Head of Main Pump	N/A	60M	MR
	➤ Number of main pumps	N/A	01no's	MR
	➤ Jockey pump out put	N/A	450LPM	MR
	➤ Jockey pump head	N/A	60M	MR
	➤ Standby pump out put	N/A	2280 LPM	MR
	➤ Standby pump Head	N/A	60M	MR
	➤ Auto Starting /Manual stopping	N/A	Provided	MR
	➤ Pump House Access	N/A	Provided	MR
	• Terrace Level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the Pump	40 mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR



N/3

14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N/A	2,00000ltr	MR
	Draw-off connection	N/A	Provided	MR
	Fire service inlet	N/A	provided	MR
	Access to tank	N/A	provided	MR
	Overhead Tank capacity	10,000 Ltrs.	25,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
T h e	Pressurization of Lift Shaft	N/A	N/A	N/A
	Pressurization of Lift lobby	N/A	N/A	N/A
	Communication in lift car	N/A	N/A	N/A
	Firemen's grounding switch	N/A	N/A	N/A
	Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
r e	Total area	N/A	N/A	N/A
	Location	N/A	N/A	N/A
19	Fire Control Room			
r o t e c t i o n	Detector system panel	N/A	N/A	N/A
	Flow switch panel	N/A	N/A	N/A
	PA system panel	N/A	N/A	N/A
	Batter backup	N/A	N/A	N/A
	Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection system for protection of special Risks, if any	N/A	N/A	N/A

The Fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping In view compliance of the minimum standards of Fire prevention and Fire Safety measured as required under the rules & NBC Part IV. The Fire safety certificate to issue under rule 35, of the Delhi Fire Service Rules 2010 is recommended.

*Francis Brown*  
17/10/18

Signature of the Inspecting Officer  
Name: Francis Brown  
Designation: DO (East)

Approved Fun City mall clear by vide PSC no F-6/DPS  
MS/NDZ/2018/1208 dated 23/5/18

Dy. CFO (NDZ)

*dm*  
CFO. P1 speak  
22/10