

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/2018/ 22/2461

Dated 1/11/18

FIRE SAFETY CERTIFICATE

Certified that the MGK Printing Works Pvt. Ltd. located at Plot No. 14, Najafgarh Road, Moti Nagar, New Delhi- 110015 running on Ground & Mezz. Floor only in a building comprising Ground, Mezz., 1st Floor & 2nd Floor only owned/occupied by MGK Printing Works Pvt. Ltd., has already been issued Fire Safety Certificate vide letter No. F6/DFS/MS/2012/2802 Dated 27.07.2012. The premises/building was re-inspected by the officers concerned of Fire Service on 23.10.2018 in the presence of Sh. Vijay Kumar and found that building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **Industrial Group (G)(for Ground & Mezz. Only)** with effect from 1/11/2018 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on 1/11/18 at New Delhi by

(ATUL GARG)
CHIEF FIRE OFFICER

Copy to: 1. Sh. Vijay Kumar, MGK Printing Works Pvt. Ltd., Plot No. 14, Najafgarh Road, Moti Nagar, New Delhi – 110015.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. 1st & 2nd floor should not be used for any factory activities..
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

INSPECTION REPORT

N/15

1. Name & address of the building: MGK Printing Works Pvt. Ltd. Plot No.14, Najafgarh Road, Moti Nagar, New Delhi-110015.
2. Type of Occupancy : Industrial (Class-G)
3. Type of Case : Renewal (For Ground & Mezz.F. in a building comprising Ground, Mezz., 1st Floor & 2nd Floor)
4. Details of previous NOC : No.F6/DFS/MS/2012/2802 dated 27.07.2012
5. Fire Safety directives Letter No. : NBC (Part-IV)
6. Date of inspection : 23/10/2018
7. Name of the Inspecting Officer : D.O. (West) & A.D.O. (Jwala Puri)
8. Name and designation of Officer
from the building side : Sh. Vijay Kumar
9. Year of Construction : 2004-05
10. Applicant's letter No. : -Nil Dated 20/10/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	15 mtr.	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	1	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old Case	1.25 mtr	MR (Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Old Case	1	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	Old Case	1.10 mtr	MR (Old Case)
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	5	15	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR

(Handwritten Signature)

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater	N/A	N/A	N/A
	• Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	N/A	Provided	N/A
	• Hose Box	N/A	Provided	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level	N/A		
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 Lit/min.	900 Lit/min.	MR
	➤ Head of the pump	40 mtr.	40 mtr.	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	Required	Provided	M/R
	➤ Fire service inlet	Required	Provided	M/R

N17

15	Exit Signage	Required	Provided	M/R
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. MCB and Conduit Metal Wiring has also been provided.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. No.F6/DFS/MS/2012/2802 dated 27.07.2012 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Mukesh Verma
26/10/18

Signature of the Inspecting Officer
Name : Mukesh Verma
Designation : D.O. (West)

Ashok Kumar Jaiswal
26/10/18

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

D.O. (W)
29/10/18
DO/W
20/10/18
FF DC

DO/W
FT letter is put up for signature phase