

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

Fax No. 011-23412593, Ph. 011-23412225

No. F.6 DFS/MS/School/2018/SZ/ 2465

Dated: 01/11/18

FIRE SAFETY CERTIFICATE

Certified that the Navyug Sr. Sec. School located at Lodhi Road, New Delhi-110003 comprised of ground plus two upper floor only was issued FSC by this department vide letter No. F.6/DFS/MS/School/2015/1855 dated 16/10/2015. The said premises was re-inspected by officer concerned of this department on 17/10/2018 in presence of Mrs. Nirmal Jeet Kaur (Principal) and observed that the said School building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "**Educational Building**" Group-B, with effect from the date of issue of this certificate for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 01/11/18 at New Delhi by

(Vipin Kental)
Chief Fire Officer

Copy to: -

1. The Principal, Navyug Sr. Sec. School, Lodhi Road, New Delhi-110003.
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi.-110002

Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

23/110

INSPECTION REPORT

| | | | | |
|---------------|--|--|-------------------------|-----------------------|
| 1 | Name & Address of the Building | Navyug Sr. Sec. School, Lodhi Road, New Delhi-110003 | | |
| 2 | Type of Occupancy | Educational, Group-B (School) | | |
| 3 | Building Comprised of | Ground plus Two Upper floors | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F.6/DFS/MS/School/2015/1855 dated 16/10/2015 | | |
| 6 | Fire Safety Directives Letter No | Nil | | |
| 7 | Date of Inspection | 17/10/2018 | | |
| 8 | Name of the Inspecting Officers | Mehmood, ADO (SJ) | | |
| 9 | Name & Designation of Officers from the building side | Mrs. Nirmal Jeet Kaur (Principal) | | |
| 10 | Year of construction | 1983 | | |
| 11 | Applicant letter No. | Nil dated 17/09/2018 | | |
| S. No. | Minimum standards on Fire Prevention and Fire Safety U/R 33 | As Per Old NOC | Provided at Site | Remarks MR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | 6 mtr | 9 m | MR |
| | • Gate width | 3.5m | 3.5m | MR |
| | • Width of internal road | -NA- | -NA- | -NA- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | 02 No's | 02No's + 01 Ramp | MR |
| | ➤ Basement floor. | -NA- | -NA- | -NA- |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.50m/0.75m | 1.25meach, Ramp-1.05m | MR |
| | ➤ Basement floor | -NA- | -NA- | -NA- |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -NA- | -NA- | -NA- |
| | ➤ Pressurization | -NA- | -NA- | -NA- |
| | d) No. of continuous staircase to terrace | 01 No | Provided | MR |
| | e) Width of corridor | 1.5m | Provided | MR |
| | f) Door size | 1m | Provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | -NA- | -NA- | -NA- |
| | • Sealing of electrical shafts. | -NA- | -NA- | -NA- |
| | • Fire rating of shaft door. | -NA- | -NA- | -NA- |
| | • Water curtain | -NA- | -NA- | -NA- |
| | • Fire dampers. | -NA- | -NA- | -NA- |
| 4. | Smoke Management system. | | | |
| | • Basement | 30 ACPH | -NA- | -NA- |
| | • Upper floors | 12 ACPH | -NA- | -NA- |
| 5. | Fire Extinguishers. | | | |
| | • Total numbers | 12 Nos | 20 Nos | MR |
| | • Types | ABC / CO2 | ABC & Co2 | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| 6. | First Aid Hose Reels. | | | |
| | • Total numbers on each floor. | 02 nos | 02 nos | MR |
| | • Length of hose-reel hose. | 30m | 30m | MR |
| | • Nozzle Diameter | 5mm | 5mm | MR |

N/12

| | | | | |
|-----|--|------|------|------|
| 18. | Refuge Area | -NA- | -NA- | -NA- |
| | • Total area | -NA- | -NA- | -NA- |
| | • Location | | | |
| 19. | Fire Control Room. | -NA- | -NA- | -NA- |
| | • Detector system panel. | -NA- | -NA- | -NA- |
| | • Flow switch panel. | -NA- | -NA- | -NA- |
| | • PA system panel. | -NA- | -NA- | -NA- |
| | • Battery backup. | -NA- | -NA- | -NA- |
| | • Building floor plan. | -NA- | -NA- | -NA- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | | | |

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the DOE circular, FSC issued vide letter No. F.6/DFS/MS/School/2015/1855 dated 16/10/2015 renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Mehmood
22/10/18
Signature of the Inspecting Officer
Name: Mehmood
Design: ADO (SJ)

DO (SD)
Prakash
23/10/18

Dr. CB/SJ

153/cfo/sj
29/10/18



Kam
20/10

Ch...

M-scell

W
26/10

A. ...

... for

Signature please
Mehmood
20/10/18
ADO(SJ)

... m-scell ...