

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/School/2018/SZ/ 2470

Dated: 21/11/18

FIRE SAFETY CERTIFICATE

Certified that the St. Paul's School (Delhi Orthodox Syrian Church Society) located at Phase-VI, H-Block, Aya Nagar, New Delhi-110047, comprised of ground and first floor only was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2013/58 dated 13/03/2013. The school premises was re-inspected by the officer concerned of this department on 17/10/2018 in presence of Mr. Thomas P.T (Admin) of the school and observed that school management has added one upper floor. The school building now comprised of ground plus two upper floors have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Educational Building, Group-B" as above with effect from 21/11/2018 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the condition under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/11/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph. 011-23412225


Copy to: -

1. Head Mistress, St. Paul's School (Delhi Orthodox Syrian Church Society), H-Block, Phase-VI, Aya Nagar, New Delhi-110047.
2. Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002


Conditions for the validity of Fire Safety Certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	St. Paul's School at Phase-VI, H-Block, Aya Nagar, New Delhi-110047 (Delhi Orthodox Syrian Church Society)		
2	Type of Occupancy	Educational Building "Group-B" (School)		
3	Building Comprised of	Two interconnected blocks each G+2 upper floors.		
4	Type of Case	Renewal & Addition		
5	Details of Previous NOC	F6/DFS/MS/School/2013/58 Dt. 13/03/13 for G+1		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	17.10.2018		
8	Name of the Inspecting Officers	Mehmood ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. Thomas P.T (Admin)		
10	Year of construction	2008 & 2016		
11	Applicant letter No.	Outdoor diary No. 14656 dated 09-10-2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	BBL / NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	6 mtr	9 mtr	MR
	• Gate width	Required	4 mtr	NA
	• Width of internal road	NA	NA	NA
2	Number, width, type & arrangement of exits.			
	a. Number of Staircase			
	➤ Upper floors.	2 Nos	3 Nos	MR
	➤ Basement floor.	NA	NA	NA
	b. Width of Staircase			
	➤ Upper floors	1.5 mtr.	1.50m, 1.20m & 1.20m	MR
	➤ Basement floor	NA	NA	NA
	c. Protection of exits			
	➤ Fire check door	NA	NA	NA
	➤ Pressurization	NA	NA	NA
	d. No. of continuous staircase to terrace	Required	Two	MR
	e. Width of corridor	1.5 mtr	1.5 mtr	MR
	f. Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door.	NA	NA	NA
	• Sealing of electrical shafts.	NA	NA	NA
	• Fire rating of shaft door.	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire dampers.	NA	NA	NA
4.	Smoke Management system.			
	• Basement	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers.			
	• Total numbers	18 Nos	Provided	MR
	• Types	ABC / Co2	ABC- 18	MR
	• ISI Marking	Required	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	01 No	02 Nos	MR
	• Length of hose-reel hose.	30 mtr	provided	MR
	• Nozzle Diameter	5 mm	provided	MR



St. Paul's School at Aya Nagar, Phase-VI, H-Block, New Delhi-110047

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	NA	NA	NA
		NA	NA	NA
13.	Pumping arrangements.			
	A. Ground Level			
	➤ Discharge of main pump.	NA	NA	NA
	➤ Head of main pump.	NA	NA	NA
	➤ Number of main pumps.	NA	NA	NA
	➤ Jockey Pump output.	NA	NA	NA
	➤ Jockey Pump head.	NA	NA	NA
	➤ Standby Pump output.	NA	NA	NA
	➤ Standby Pump head.	NA	NA	NA
	➤ Auto Starting / Manual Stopping.	NA	NA	NA
	➤ Pump house access.	NA	NA	NA
	B. Terrace Level			
	➤ Discharge of pump.	450 LPM	Provided	MR
	➤ Head of pump.	40 mtr	Provided	MR
	➤ Power supply.	Required	Provided	MR
	➤ Auto starting of pump.	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> ➤ Draw-off connection. ➤ Fire Service Inlet. ➤ Access to tank. Overhead tank capacity. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby Power Supply	NA	NA	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	NA	NA	NA
		NA	NA	NA

19.	Fire Control Room.				
		• Detector system panel.	NA	NA	NA
		• Flow switch panel.	NA	NA	NA
		• PA system panel.	NA	NA	NA
		• Battery backup.	NA	NA	NA
	• Building floor plan.	NA	NA	NA	
20.	Special Fire Protection System for the Protection of special Risk, if any.			NA	
<p>The Fire protection systems provided in the building were checked/ tested at random and found functional at the time of inspection. The shortcomings communicated vide this department even letter dated 05/10/2018 (C-18) have been complied.</p> <p>Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the rule, it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules, 2010.</p> <p>Accordingly DFA is put up for approval and signature please.</p>					
 Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ)					

St. Paul's School at Aya Nagar, Phase-VI, H-Block, New Delhi-110047

DO (SD)


 25/10/18




 25/10

cfb 27/10

m. scell


FTM.
 29/10

A.O.M. letter put up for signature please



m. scell

29/10


 30/10/18
 ADO (SJ)



160/cfo-52

29/10/18