

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/2015/EH/WZ/2475

Dated: 2 / 11 / 2018

FIRE SAFETY CERTIFICATE

Certified that the Tippling Street (A Unit of D.K. Plaza) located at A-12 Vishal Enclave Rajouri Garden, New Delhi. Now running on 1st & 2nd Floor only in a building comprising Basement, Ground, 1st Floor & 2nd Floor & 3rd Floor only owned / occupied by D.K. Plaza Restaurant has already been issued Fire Safety Certificate Vide Letter No. F6/DFS/MS/EH/2015/WZ/1479 dated 14/08/2015 (for Ground & 2 Upper Floors only). The premises / building was re-inspected by the officer concerned of this department on 17/10/2018 in the presence of Mr. Kawal Jeet Singh (Partner) and found that the building / premises have deemed complied with the Fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building / premises is fit for the occupancy class "Assembly" (Group D) (For 1st & 2nd Floor Only) with effect from 2-11-18..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 2-11-18..... at New Delhi by.


(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to:

1. Kewaljeet Singh (Partner), Tippling Street (A Unit of D.K. Plaza), A-12 Vishal Enclave Rajouri Garden, New Delhi
2. Dy. Health Officer, SDMC, Vishal Enclave, Rajouri Garden, New Delhi-110027.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. **Fire Safety Certificate is valid for 1st & 2nd Floor only.**
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. Basement shall be used strictly as per BBL.

12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	NR	NR	NR
	➤ Head of Main pump	NR	NR	NR
	➤ Number of main pumps	NR	NR	NR
	➤ Jockey Pump out put	NR	NR	NR
	➤ Jockey pump head	NR	NR	NR
	➤ Standby pump out put	NR	NR	NR
	➤ Standby pump Head	NR	NR	NR
	➤ Auto Starting/Manual stopping	NR	NR	NR
	➤ Pump Hose Access	NR	NR	NR
	Terrace level			
	➤ Discharge of pump	450 LPM	450 LPM x 2	M.R
	➤ Head of the pump	40 MH	40 MH	M.R
	➤ Power supply	Required	Provided	M.R
	➤ Auto Starting of pump	required	Provided	M.R
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	NR	NR	NR
	➤ Draw -off connection	NR	NR	NR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	➤ Overhead Tank Capacity	10,000 ltr	10,000 ltr	MR
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	➤ Detector System Panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA system Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. No. F6/DFS/MS/EH/2015/WZ/1479 dated 14/08/2015 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

D.O (cust)

Ak Jaiswal
26/11/18

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

Mukherjee 26/11/18
Dy. Insp (12)
CFO
22/10/18
pls exp
Spoken with Dy Insp
on 1/11/18
helps syri. out of fi

INSPECTION REPORT

1. Name & address of the building : Tippling Street (A Unit of D.K. Plaza), A-12,
Vishal Enclave, Rajouri Garden, New Delhi-110027.
2. Type of Occupancy : Assembly / Restaurant (Eating House)
3. Type of Case : Renewal (Now **Restaurant at 1st & 2nd Floor only** in a building
comprising Basement, Ground & Three Upper Floors)
4. Details of previous NOC : F6/DFS/MS/EH/2015/WZ/1479 dated 14/08/2015
(Issued for Ground Floor, 1st Floor & 2nd Floor only)
5. Fire Safety directives letter No. : NBC (Part-IV)
6. Date of inspection : 17.10.2018
7. Name of the Inspecting Officers : A. K. Jaiswal (ADO JWP)
8. Name and designation of officers
From the building side : Sh. Kawal Jeet Singh
9. Year of Construction : 2004
10. Applicant's letter No. : Nil dated 11/09/2018

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC-2005 Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09mtr	On Main Road	M.R.
	• Gate width	On main road	On Main Road	MR
	• Width of internal road	N/A	N/A	N/A.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floor	2	2	MR
	• Basement	N/A	N/A	N/A
	b. Width of staircases			
	• Upper Floors	Old Case	0.85 mtr x 2	MR (Old Case)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	1	1	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door size	2.00m x 1 1.00m x 1	2.00m x 1 & 1.00m x 1	MR

3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System.			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	6	7	M.R.
	• Types	ABC & CO ₂ type	Provided	M.R.
	• IS marking	ISI marks required	provided	M.R.
6.	First-Aid Hose Reel.			
	• Total numbers on each floor	1	1	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	N/A	N/A	N/A
10.	Automatic Sprinkler system			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	Provided	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	1	1	MR
	• Hose Box	1	1	MR

QAS