

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No. F6/DFS/MS/2018/NDZ/ 2449

Dated: 31/10/18

FIRE SAFETY CERTIFICATE

Certified that the **Wood Apple Restaurant** running at ground floor of the building is comprised of basement, stilt floor; ground plus three upper floors at Plot no -3, Hargovind Enclave, Delhi-92, owned/occupied by M/s A Unit of Wood Apple Residency was granted fire safety certificate vide letter no. F6/DFS/MS/GH/2017/NDZ/743 dated 24/05/17 (for entire building). The premises was inspected by officer concerned of this department on 22/10/18 in the presence of **Sh. Anil Giri (GM)** and found that the Restaurant building have complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and that the building is fit for occupancy Group "Restaurant Building"(Eating House) with effect from ..31/10/18.... for a period of **three** years, subject to conditions printed overleaf.

Issued on31/10/18..... at New Delhi by


(Vipin Kental)
Chief Fire Officer

To,

The Deputy Health Officer,
Shahdara(South) Zone, Karkardooma, Delhi.

Copy to:-

1. M/s Wood Apple Restaurant,
Plot no -3, Hargovind Enclave, Delhi-92.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : M/s Wood Apple Restaurant Plot no -3,
Hargovind Enclave, Main Vikas Marg,
Karkardooma, Delhi-92.
2. Building is comprised of : Basement, Stilt+ground+3 floors (Restaurant
running at ground floor only)
3. Type of Occupancy : Restaurant (Eating House)
4. Type of Case : New
5. Details of Previous FSC letter : F6/DFS/MS/GH/2017/NDZ/743 Dated
24/05/17
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 22/10/18
8. Name of the Inspecting officers : ADO R.K.Yadav
9. Name and designation of officer
from the building side : Sh. Anil Giri (GM)
10. Year of construction : 2010
- 11 Applicant's letter No : DHO/Shah./S/2018/1897 dt-23/08/18

Sr No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 m	30 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper floor	02 No.	03 No.	MR
	• Basement	01 No	02 Nos.	MR
	B. Width of Staircases			
	• Upper floor	1.5 m & 1.25 m	1.50 M & .75 m (stilt to ground) & 1.15(stilt to terrace)	MR
	• Basement	1.25 m	1.15 m, 2.3 m	MR
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	01 No.	01 No.	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.0 m & 1.0 m	2.0 m & 1.0 m	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	30 a/c per hour	N/A	N/A
	• Upper floor	12 a/c per hour	N/A	N/A
5	Fire Extinguishers.			
	• Total numbers	10 nos.	Provided	MR
	• Types	ABC /CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

* All accepted

06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	1 No 30 m 05 mm	Provided Provided Provided	MR MR MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
08	MOEFA	N/A	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	Required N/A N/A	Provided N/A N/A	MR N/A N/A
11	Internal Hydrants Entire Building			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose box 	100 mm 01 No. 01 No.	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	N/A N/A	N/A N/A	N/A N/A
13	Pumping Arrangements. Entire Building			
	➤ Ground Level			
	<ul style="list-style-type: none"> Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby pump out put Standby pump head Auto starting /manual stopping Pump house access 	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A N/A N/A N/A N/A
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump Head of the pump Power supply Auto Starting of pump 	450 LPM 40 M Required N/A	450 LPM 40 M Provided N/A	MR MR MR N/A
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A N/A N/A N/A 5,000 Ltrs	N/A N/A N/A N/A 5,000 Ltrs	N/A N/A N/A N/A MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules. The FSC issued vide letter no F6/DFS/MS/GH/2017/NDZ/743 Dated 24/05/17 (for entire building) it is recommended to renew under rule 35 of the Delhi Fire Service Rule 2010.

R. K. Yadav
26/10/2018

Signature of the Inspecting Officer
Name: R.K. Yadav
Designation: ADO (LN)

DO (F) on leave
Dy CPO (NDZ) *ku*

756/CFONOR
26/X. 31/X.

- C.F.O.*
1. It is a five storeyed building. The height of the premise as per clause 2.11 of BR is required.
 2. The restaurant doesn't have direct access out side the bdy but through stair case + reception.

DCFONDZ

ku
26/X.