

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/NDZ/2018/ *CPG/2522*

Dated:-

*12/11/18*

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Jaspreet Gas Service site No. 1, Rajghat Power House, New Delhi comprised of **single story building**, owned/occupied by M/s Jaspreet Gas Service was granted NOC by this department vide letter No. F6/DFS/MS/LPG/88/194 dated 11/02/1988. The premises was re-inspected by the officer concerned of this department on 15/10/18 in the presence of Sh. Rajesh (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Hazardous Group J** with effect from -----for period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued -----at New Delhi by.

*V.K.*  
**(Vipin Kental)**  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Manager,  
M/s Jaspreet Gas Service,  
Site No. 1, Rajghat Power House, New Delhi.
2. The Chief Area Manager,  
Indian Oil Corporation Ltd.,  
6<sup>th</sup> floor, Surya Kiran Building, 19, K.G. Marg, New Delhi.

Condition for the validity of fire safety certificate

1. "No Smoking" and "Not to use Mobile Phone" sign board should be displayed in such a manner as to be easily readable by all persons.
2. No trade Susceptible to Cause Ignition Petroleum vapors by generating heat, mechanical/electric spark should be allowed within the premises and its vicinity.
3. 04 no's of co2 gas type ISI capacity of 4.5 kg. 02 no's of ABC stored pressure power type ISI capacity 05 kg and 01 numbers of AFFF type ISI capacity 50 ltrs provided should be maintained in proper working order all the time.
4. The working employed at the petrol pump must be taught the correct method of operation and maintenance of record of the extinguishers be ensured.
5. Overhead electric cable not passing across the licensed premises.
6. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

48  
**INSPECTION REPORT**

1. Name & address of the building M/s Jaspreet Gas Service site No. 1, Rajghat Power House, New Delhi
2. Type of occupancy:- Hazardous Group J  
Single story building
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/LPG/88/194 dated 11/02/1988.
5. Fire safety directives No.- N/A
6. Date of inspection:- 15/10/18
7. Name of the inspecting officer:- Sh. Manoj Kumar Sharma (ADO/CC)
8. Name & designation of officer From the building side:- Sh. Rajesh
9. Year of construction:-
10. Applicant's letter No:- No. Nil dated 17.05.18.

| S.No.     | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement Existing fire safety arrangements | Provided at site    | Remarks MR/NMR |
|-----------|---|---|---------------------|----------------|
| <b>1.</b> | <b>Access to Building</b>                                   |   |                     |                |
|           | 1) Road width   | 06 mtr.                                       | 15 mtr.             | MR             |
|           | 2) Gate width   | Accessible                                    | Accessible directly | MR             |
|           | 3) Width of internal road                                   | N/A   | N/A                 | N/A            |
| <b>2.</b> | <b>Number, Width Type &amp; Arrangement of Exits</b>        |   |                     |                |
|           | <b>A. Number of staircases</b>                              |   |                     |                |
|           | 1. Upper floors   | N/A   | N/A                 | N/A            |
|           | 2. Basements  | N/A   | N/A                 | N/A            |
|           | <b>B. Width of staircase</b>                                |   |                     |                |
|           | 1. Upper floors   | N/A   | N/A                 | N/A            |
|           | 2. Basements  | N/A   | N/A                 | N/A            |
|           | <b>C. Protection of exits</b>                               |   |                     |                |
|           | 1. Fire check door  | N/A   | N/A                 | N/A            |
|           | 2. Pressurization   | N/A   | N/A                 | N/A            |
|           | <b>D. No. of continuous staircase to terrace</b>            |   |                     |                |
|           | E. Width of corridor  | N/A   | N/A                 | N/A            |
|           | F. Door size  | N/A   | N/A                 | N/A            |
| <b>3.</b> | <b>Compartmentation</b>                                     |   |                     |                |
|           | 1) Fire check door  | N/A   | N/A                 | N/A            |
|           | 2) Sealing of electrical shafts                             | N/A   | N/A                 | N/A            |
|           | 3) Fire rating of shaft door                                | N/A   | N/A                 | N/A            |
|           | 4) Water curtain  | N/A   | N/A                 | N/A            |
|           | 5) Fire Dampers   | N/A   | N/A                 | N/A            |
| <b>4.</b> | <b>Smoke Management System</b>                              |   |                     |                |
|           | 1) Basements  | N/A   | N/A                 | N/A            |
|           | 2) Upper floors   | N/A   | N/A                 | N/A            |
| <b>5.</b> | <b>Fire Extinguishers</b>                                   |   |                     |                |
|           | 1) Total numbers  | 03  | 03                  | MR             |
|           | 2) Types  | Required                                      | Provided            | MR             |
|           | 3) ISI marking  | Required                                      | Provided            | MR             |
| <b>6.</b> | <b>First-Aid Hose Reel</b>                                  |   |                     |                |
|           | 1) Total number of each floor                               | N/A   | N/A                 | N/A            |
|           | 2) Length of hose reel hose                                 | N/A   | N/A                 | N/A            |
|           | 3) Nozzle diameter  | N/A   | N/A                 | N/A            |

m

|            |   |          |                          |     |
|------------|---|----------|--------------------------|-----|
| <b>7.</b>  | <b>Automatic Fire Detection &amp; Alarming System</b> |          |                          |     |
|            | 1) Type of detectors                                  | N/A      | N/A                      | N/A |
|            | 2) Location of main panel                             | N/A      | N/A                      | N/A |
|            | 3) Location of repeater panel                         | N/A      | N/A                      | N/A |
|            | 4) Alternate source of power                          | N/A      | N/A                      | N/A |
|            | 5) Hooter's Location                                  | N/A      | N/A                      | N/A |
| <b>8.</b>  | <b>MOEFA</b>  | N/A      | N/A                      | N/A |
| <b>9.</b>  | <b>Public Address System</b>                          | N/A      | N/A                      | N/A |
| <b>10.</b> | <b>Automatic Sprinkler System</b>                     |          |                          |     |
|            | 1) Basement   | N/A      | N/A                      | N/A |
|            | 2) Upper floors                                       | N/A      | N/A                      | N/A |
|            | 3) Sprinkler above false ceiling                      | N/A      | N/A                      | N/A |
| <b>11.</b> | <b>Internal Hydrants</b>                              |          |                          |     |
|            | 1) Size of riser/down-comer                           | N/A      | N/A                      | N/A |
|            | 2) Number of hydrants per floor                       | N/A      | N/A                      | N/A |
|            | 3) Hose box   | N/A      | N/A                      | N/A |
| <b>12.</b> | <b>Yard Hydrants</b>                                  |          |                          |     |
|            | 1) Total number of hydrants                           | N/A      | N/A                      | N/A |
|            | 2) Hose box   | N/A      | N/A                      | N/A |
| <b>13.</b> | <b>Pumping Arrangement</b>                            |          |                          |     |
|            | 1) Ground level                                       | N/A      | N/A                      | N/A |
|            | a) Discharge of main pump                             | N/A      | N/A                      | N/A |
|            | b) Head of main pump                                  | N/A      | N/A                      | N/A |
|            | c) Number of main pump                                | N/A      | N/A                      | N/A |
|            | d) Jockey pump output                                 | N/A      | N/A                      | N/A |
|            | e) Jockey pump head                                   | N/A      | N/A                      | N/A |
|            | f) Stand by pump output                               | N/A      | N/A                      | N/A |
|            | g) Stand by pump head                                 | N/A      | N/A                      | N/A |
|            | h) Auto starting/Manual stopping                      | N/A      | N/A                      | N/A |
|            | 2) Terrace level                                      |          |                          |     |
|            | a) Discharge of pump                                  | N/A      | N/A                      | N/A |
|            | b) Head of pump                                       | N/A      | N/A                      | N/A |
|            | c) Power supply                                       | N/A      | N/A                      | N/A |
|            | d) Auto starting of pump                              | N/A      | N/A                      | N/A |
| <b>14.</b> | <b>Captive Water Storage for Fire Fighting</b>        |          |                          |     |
|            | 1) Under ground tank capacity                         | N/A      | N/A                      | N/A |
|            | a) Draw-off connection                                | N/A      | N/A                      | N/A |
|            | b) Fire service inlet                                 | N/A      | N/A                      | N/A |
|            | c) Access to tank                                     | N/A      | N/A                      | N/A |
|            | d) Over head tank capacity                            | N/A      | N/A                      | N/A |
| <b>15.</b> | <b>No Smoking Signage English &amp; Hindi</b>         | Required | Provided English & Hindi | MR  |
| <b>16.</b> | <b>Provision of Lifts.</b>                            |          |                          |     |
|            | a) Pressurization of lift shaft                       | N/A      | N/A                      | N/A |
|            | b) Pressurization of lift lobby                       | N/A      | N/A                      | N/A |
|            | c) Communication in                                   | N/A      | N/A                      | N/A |

N/10

|     |   |     |     |     |
|-----|---|-----|-----|-----|
|     | lift car  |     |     |     |
|     | d) Fireman's switch   | N/A | N/A | N/A |
|     | e) Lift signage   | N/A | N/A | N/A |
| 17. | Stand by Power Supply   | N/A | N/A | N/A |
| 18. | Refuge Area   | N/A | N/A | N/A |
|     | Total area location   | N/A | N/A | N/A |
| 19. | Fire Control Room   | N/A | N/A | N/A |
|     | a) Detector system panel  | N/A | N/A | N/A |
|     | b) Flow switch panel  | N/A | N/A | N/A |
|     | c) PA system panel  | N/A | N/A | N/A |
|     | d) Battery backup   | N/A | N/A | N/A |
|     | e) Building floor plan  | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckers with sand. |     |     | MR  |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. No. No. F6/DFS/MS/LPG/88/194 dated 11/02/1988 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

*M.K. Sharma*

Name: - M.K. Sharma  
Designation: - ADO (CC)

Dy. CFO/NDZ

*[Signature]*

*ETC.*

*m.scell*

*FTM.*

*W  
11/x1.*

*R.T. letter is put up for sign. pl*

*821/cfo d/102  
8/11*

*CFO(NDZ)*

*m.scell*

*W  
6/x1.*

*M.K. Sharma  
5/11*