

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F-6/DFS/MS/Banq/2018/ 2523

Dated: 12 /11/2018

FIRE SAFETY CERTIFICATE

Certified that the M/s **Wedding Opera (A Unit of S.G. Hospitality) Banquet Hall**, located at **B – 9, Ground Floor, Industrial Area, Lawrence Road Delhi -110035**, in a building comprised of Basement + Ground Floor owned/ occupied by **M/s Wedding Opera** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of this department on 30-10-2018 in the presence of Sh. Gurmeet Singh (Owner) and found that the said building that the premises is fit for occupancy class "Assembly" Group D (**Ground Floor Only**) with effect from 12/11/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on12/11/18... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

- Copy to: 1. M/s Wedding Opera (A Unit of S.G. Hospitality) Banquet Hall, B – 9, Ground Floor Industrial Area, Lawrence Road Delhi -110035.
2. The Dy Health Officer, A-1 Block, Keshav puram Zone, Public Health Department, Keshav Puram, Delhi.

Following fire safety directives must be adhered to:-

1. **The FSC is valid for Ground Floor only**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. **Basement shall be kept closed as seen during the inspection.**
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: **M/s Wedding Opera (A Unit of S.G. Hospitality) Banquet Hall** Located at **B - 9, Ground Floor, Indi Area Lawrence Road Delhi -110035.**

2. Type of Occupancy : **Assembly at Ground Floor** (In a building comprised of Basement (**Closed by brick wall**) + Ground Floor, Basement shall not be used)

Covered Area = 2058m²

3. Type of Case : New

4. Details of previous NOC : Nil

5. Fire Safety directives Letter No. : F-6/DFS/MS/BP/2018/4254 Dated 09/10/2018

6. Date of inspection : 30-10-2018

7. Name of the Inspecting Officer : DO/W & ADO (WP)

8. Name and designation of Officer

from the building side : Sh. Gurmeet Singh (Owner)

9. Year of Construction : 2010-11

10. Applicant's letter No. : DHO/KPZ/2018/805 Dated-01/10/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	09 m	12mtrs	MR
	• Gate width	5 m	On Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	Closed By Brick Wall	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	4x2m	4x230cm, 1x295cm, 1x355cm 1x137cm	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	07 nos.	07 Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	4	Provided	MR
	• Length of hose reel	30m	Provided	MR
	• Hose diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided(Smoke Detectors)	NA
	• Location of Main Panel	NA	Ground floor	NA
	• Location of Repeater Panel	NA	Provided	NA
	• Alternate source of power	NA	Ground floor	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	Provided	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	Required	Provided	MR
	• Number of hydrants per floor	Required 4	Provided	MR
	• Hose Box	Required 4	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	25,000 ltrs	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area	NA	NA	
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNIL.....

Signature of the Inspecting Officer
Name Sh Mukesh Verma
Designation DO/W

Signature of the Inspecting Office
Name Udai Vir Singh
Designation ADO/WP

Sh Mukesh Verma
31/12/18
Udai Vir Singh
21/1/18

is put up for signature place