

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/GH/2018/SZ/ 2490

Dated: 8.11.18

**FIRE SAFETY CERTIFICATE**

Certified that M/s Anutham Guest House located at E-147, Saket New Delhi-110017, comprised of Basement, Ground and three upper floors (basement and ground floor others property, 1<sup>st</sup> floor- reception & 07 guest rooms, 2<sup>nd</sup> floor- 08 guest rooms and 3<sup>rd</sup> floor-02 guest rooms total-17 guest rooms) was issued Fire Safety Certificate by this department vide letter No. F6/MS/DFS/GH/2015/SZ/1929 dated 28/10/2015. The premises was re-inspected by officer concerned of this department on 16/10/2018 in the presence of Mr. Madan ( Manager) of the guest house and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that premises is fit for occupancy class "**Residential, Group-A**" (Lodging & Rooming House) as above with effect from the date of issue of this certificate for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 8/11/18 at New Delhi by

(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to: -

1. The Addl. Commissioner of Police (Lic.), 1<sup>st</sup> Floor, P.S. Defence Colony, New Delhi-110049
2. M/s Anutham Guest House located at E-147, Saket New Delhi-110017

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	M/s Anutham, GH, E-147, Saket New Delhi		
2	Type of Occupancy	Residential, "Group-A" (Guest House)		
3	Building Comprised of	Basement, Ground + 03 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F.6/DFS/MS/GH/2015/SZ/1929 Dated 28-10-2015		
6	Fire Safety Directives Letter No	NIL		
7	Date of Inspection	16-10-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Madan (Manager)		
10	Year of construction	2009	basement and ground floor others property, 1 <sup>st</sup> floor-reception & 07 guest rooms, 2 <sup>nd</sup> floor-08 guest rooms and 3 <sup>rd</sup> floor-02 guest rooms total-17 guest rooms	
11	Applicant letter No.	4337/Addl. C.P.(h) dated New Delhi the 17/09/2018		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
<b>1</b>	<b>Access to Building.</b>			
	• Road width	12 mtr	Provided	MR
	• Gate width	-NA-	-NA-	MR
	• Width of internal road	-NA-	-NA-	-NA-
<b>2</b>	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	01 Nos	Provided 01Nos	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	<b>b) Width of Staircase</b>			
	➤ Upper floors	Required 90 cms	01 mts (Old case)	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	<b>c) Protection of exits</b>			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	01 nos	01 nos	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1 mtr	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
<b>4.</b>	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	Exhaust Fan	MR
<b>5.</b>	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	12 Nos	MR
	• Types	ABC / CO2	CO2 & ABC	MR
	• ISI Marking	ISI marked	Provided	MR
<b>6.</b>	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	01	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR




N/13

M/s Anutham GH E-147 Saket New Delhi

19.	<b>Fire Control Room.</b>			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-	-NA-

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, renewal of the FSC issued vide letter No.F6/MS/DFS/GH/2015/SZ/1929 dated 28/10/2015, renewal under rule35 of the Delhi Fire Service rules 2010, is recommended.

Accordingly DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name: Mehmoed  
 Design: ADO (SJ)

M/s Anutham GH E-147 Saket New Delhi

DO (SD)

*Anilak*  
*29/11/18*

*dy. CPO (S2)*

*dehp*  
*29/11*

*CPO (S2)*

*M. scell*

*FTM.*

*30/X*

*A. B-T. letter put up for signature please*

*CPO (S2)*

*M. scell*

*30/X*

*Mehmoed*  
*30/11/18*  
*ADO (S2)*



*172/cfo-12*  
*30/11/18*