

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI-110001**

No. F.6/DFS/MS/Bldg./2018/SZ/ 2489

Dated: 8/11/18

**FIRE SAFETY CERTIFICATE**

Certified that the **Community Centre** located at Praduman Singh Marg, Asiad Village Complex, New Delhi-110049, comprised of basement, ground plus two upper floors was issued FSC by this department vide letter No. F6/DFS/MS/2012/2118 dated 12/06/2012. The premise was re-inspected by officer concerned of this department on 06/10/2018 in the presence of Capt. Krishan Sharma (Retd.) and found that said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "**Assembly**" (Community Hall) with effect from 8/11/2018 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued on 8/11/18 at New Delhi by

  
(Vipin Kental)  
Chief Fire Officer  
Ph: 011-23412225

Copy to:

1. Secretary, Asiad Village Society (Regd.), Praduman Singh Marg, Asiad Village Complex, New Delhi-110049
2. Ex. Engineer (Bldg), South M.C.D, Building Department, Green Park, New Delhi-110016

**Conditions for the validity of Fire Safety Certificate: -**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of DFS Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT				
1	Name & Address of the Building	Community Centre at Praduman Singh Marg, Asiad Village Complex, New Delhi-110049		
2	Type of Occupancy	Group-D "Assembly Building"		
3	Building Comprised of	Basement, Ground + 02 upper floors.		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2012/2118 Dated 12-06-2012		
6	Fire Safety Directives Letter No	F6/DFS/MS/BP/2004/1228 Dated 10-06-2004		
7	Date of Inspection	06-10-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Capt. Krishan Sharma (Retd.)		
10	Year of construction	2009		
11	Applicant letter No.	Outdoor diary No. 13444 dated 19-09-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to Building.</b>			
	• Road width	06 mtr	12 mtr	MR
	• Gate width	4.5 mtr	2 gates of 2m each	MR (old case)
	• Width of internal road	-NA-	-NA-	-NA-
2	<b>Number, width, type &amp; arrangement of exits.</b>			
	<b>a) Number of Staircase</b>			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	03 Nos	MR
	<b>b) Width of Staircase</b>			
	➤ Upper floors	1.5 mtr	1.5m & 1..25m	MR (old case)
	➤ Basement floor	1.5 mtr	1.5m, 1.5m & 1..25m	MR
	<b>c) Protection of exits</b>			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	<b>d) No. of continuous staircase to terrace</b>	One	Provided	MR
	<b>e) Width of corridor</b>	-NA-	-NA-	-NA-
	<b>f) Door size</b>	1.5 mtr	Provided	MR
3	<b>Compartmentation.</b>			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	<b>Smoke Management system.</b>			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors.	12 ACPH	Natural ventilation	MR
5	<b>Fire Extinguishers.</b>			
	• Total numbers	Required	12 Nos	MR
	• Types	CO2 / ABC	CO2 & W.CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	<b>First Aid Hose Reels.</b>			
	• Total numbers on each floor.	One	Provided	MR
	• Length of hose-reel hose.	30 mtr	Provided	MR
	• Nozzle Diameter	5 mm	Provided	MR

Community Centre at Praduman Singh Marg, Asiad Village Complex, New Delhi-110049



<b>7</b>	<b>Automatic fire detection &amp; alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's location</li> </ul>	Smoke & Heat	Provided	MR
		Required	Ground Floor	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Each floor	MR
<b>8</b>	<b>MOEFA</b>	-NA-	-NA-	-NA-
<b>9</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floors</li> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
<b>11</b>	<b>Internal Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Size of Riser/Down-comer</li> <li>• Number of Hydrant per floor</li> <li>• Hose box.</li> </ul>	100 mm	Provided	MR
		01 No	Provided	MR
		01 No	Provided	MR
<b>12</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants.</li> <li>• Hose box.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
<b>13</b>	<b>Pumping arrangements.</b>			
	<ul style="list-style-type: none"> <li>• <b>Ground Level</b></li> <li>➤ Discharge of main pump.</li> <li>➤ Head of main pump.</li> <li>➤ Number of main pumps.</li> <li>➤ Jockey Pump output.</li> <li>➤ Jockey Pump head.</li> <li>➤ Standby Pump output.</li> <li>➤ Standby Pump head.</li> <li>➤ Auto Starting/Manual Stopping.</li> <li>➤ Pump house access.</li> </ul>	900 LPM	900 LPM	MR
		35m	35m	MR
		One	One	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		900 LPM	900 LPM	MR
		35m	35m	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>• <b>Terrace Level</b></li> <li>➤ Discharge of pump.</li> <li>➤ Head of pump.</li> <li>➤ Power supply.</li> <li>➤ Auto starting of pump.</li> </ul>	450 & 180 LPM	450 & 180 LPM	MR
		35m	35m	MR
		Required	Provided	MR
		Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity.</li> <li>➤ Draw-off connection.</li> <li>➤ Fire Service Inlet.</li> <li>➤ Access to tank.</li> <li>• Overhead tank capacity.</li> </ul>	50,000 Ltr	25,000 Ltr	MR (old case)
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		10,000 Ltr	35,000 Ltr	MR
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of lift shaft.</li> <li>• Pressurization of lift lobby.</li> <li>• Communication in lift car.</li> <li>• Fireman's switch.</li> <li>• Lift signage.</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
<b>17</b>	<b>Standby Power Supply</b>	Required	Provided	MR
<b>18</b>	<b>Refuge Area</b>			
	<ul style="list-style-type: none"> <li>• Total area</li> <li>• Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-

19	<b>Fire Control Room.</b>		Required	Provided	MR
		• Detector system panel.	-NA-	-NA-	-NA-
		• Flow switch panel.	Required	Provided	MR
		• PA system panel.	Required	Provided	MR
		• Battery backup.	-NA-	-NA-	-NA-
20	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	• Building floor plan.	-NA-	-NA-	-NA-
					-NA-

The Fire protection systems provided in the premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter No. F6/DFS/MS/2012/2118 dated 12/06/2012, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

*Mehmood*  
Signature of the Inspecting Officer  
Name: Mehmood  
Design: ADO (SJ)

Community Centre at Praduman Singh Marg, Asiad Village Complex, New Delhi-110049

DO (SD)

*[Signature]*  
29/10/18

*[Signature]*  
dy. CPO (S2)

*[Signature]*  
29/10

CFO S/P m-scem F7101  
u  
30/10

A. B. T. Delhi for up for signature please

*[Signature]*  
21/11/18  
AD001857

*[Signature]*  
CBO (S2) m-scem u  
5/11



166/CFO SL

31/10/18