

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No. F.6/DFS/MS/School/2018/SZ/ 2566

Dated: 28.11.18

FIRE SAFETY CERTIFICATE

Certified that the Delhi Public School located at Sec-12, R.K. Puram, New Delhi-110022 was issued NOC by this department for Science/Adm block vide letter No.F6/DFS/MS/91/School/1938 dated 11/11/1991. The premises was re-inspection by officer concerned by this department on 20/10/2018 in the presence of Sh. A.S. Bhati (Admin) of the school and observed that the school complex having nine academic blocks namely A, B, C (Interconnected) & Circular Block: Each G+02, D, F & Blossom Block (D Block interconnected with Circular & Blossom Blocks): Each B+G+03, E & Health Block: Each B+G+02 have complied with the fire prevention and fire safety requirements in accordance with rule Directorate of Education Circular No F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational" Group-B (School) as above with effect from 28/11/2018 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 28/11/18 at New Delhi by

Ventel
(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225

Copy to: -

1. The Principal, Delhi Public School at Sector-12, R.K. Puram, New Delhi-110022
2. The Director of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Girls Hostel, Delhi Public School, Sector-12, R.K. Puram, New Delhi-110022		
2	Type of Occupancy	Residential, Group-A (Hostel)		
3	Building Comprised of	B+G+5 (5 th floor sealed and undertaking submitted)		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/91/School/1938 Dated. 11-11-91		
6	Fire Safety Directives Letter No.	Nil		
7	Date of Inspection	20-10-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mr. AS Bhati (Admin)		
10	Year of construction	1980-2002		
11	Applicant letter No.	Outdoor diary No. 12739 dated 06-09-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	9 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	6 mtr	Provided	MR
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos	Provided	MR
	➤ Basement floor.	02 Nos	Provided	MR
	b) Width of Staircase			
	➤ Upper floors	Required	1.78m & 1.03m	MR (old case)
	➤ Basement floor	Required	1.77, 1.28 & 1.22m	MR (old case)
	c) Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	02 Nos	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	Exhaust fan provided	MR
	• Upper floors	12 ACPH	Natural Ventilation	MR
5	Fire Extinguishers.			
	• Total numbers	Required	10 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

Girls Hostel, Delhi Public School located at Sector-12, R.K. Puram, New Delhi

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	Required	100 mm	MR
		Required	01 No	MR
		Required	01 No	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	Required	11 Nos	MR
		Required	11 Nos	MR
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. 	Fire fighting arrangements are common for entire complex		
		900 LPM	1200 LPM	MR
		45m	45m	MR
		One	One	MR
		240 LPM	Provided	MR
		45m	Provided	MR
		900 LPM	Provided	MR
		45m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Terrace Level Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	900 LPM	900 LPM x 2	MR
		40m each	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water storage for fire fighting.	Fire fighting arrangements are common for entire complex		
	<ul style="list-style-type: none"> Underground tank capacity. Draw-off connection. Fire Service Inlet. Access to tank. 	1,00,000 Ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
	<ul style="list-style-type: none"> Overhead tank capacity. 	15,000 Ltr	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-


Girls Hostel, Delhi Public School located at Sector-12, R.K. Puram, New Delhi

19	Fire Control Room.			
	• Detector system panel.	-NA-	-NA-	-NA-
	• Flow switch panel.	-NA-	-NA-	-NA-
	• PA system panel.	-NA-	-NA-	-NA-
	• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-
20	Special Fire Protection System for the Protection of special Risk, if any.			-NA-

The shortcomings communicated vide letter dated F6/DFS/MS/2014/School/219 dated 30-01-2014 found complied.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/91/School/1938 dated 11/11/1991, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Mehmood
 Design: ADO (SJ)

Girls Hostel, Delhi Public School located at Sector-12, R.K. Puram, New Delhi

DO (SD)

Amilak
6/10/18

1911/dose
8/11

Dy. ADO (SD)

[Signature]
8/11



CFO (SD)

M-SCM

F 7/11

[Signature]
8/11

A. P.T. Delhi put up for signature please