

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/School/2018/NDZ/ 2560

Dated: 27/11/18

FIRE SAFETY CERTIFICATE

Certified that the Lavkush Public Secondary School at A-281, Gharauli ExtnMayur Vihar, Phase-III, Delhi-96, owned/occupied by Lavkush Public Secondary School, comprised of ground plus two upper floor was issued NOC vide letter No. F6/DFS/MS/school/09/1723 dated 21/08/09. The school building was inspected by the officer concerned of this department on 30/10/18 in the presence of Mrs. Swati Kaushik (Vice-Principal) of the school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular no. 262-362 Dated 17/01/2005 and the school building is fit for occupancy class "B" 'Educational Building' with effect from 27.11.18..... for a period of three years, subject to conditions, printed overleaf.

Issued on..... 27/11/18..... at New Delhi by

V
26/11
(Vipin Kental)
Chief Fire Officer

9ep

To,

The Principal,
Lavkush Public Secondary School
A-281, Gharauli ExtnMayur Vihar, Phase-III, Delhi-96.

Copy to:-

The Dy. Director of Education,
Yamuna Vihar Delhi-53.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building : Lavkush Public Secondary School at A-281, Gharauli Extn Mayur Vihar, Phase-III, Delhi-96.
2. Building is comprised of : Ground +2 Upper floor
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous NOC letter : F6/DFS/MS/school/09/1723 dated 21/08/09
6. Fire Safety direction letter No : Circular No.262-362 Dated 17/01/2005
7. Date of Inspection : 30/10/18
8. Name of the Inspecting officers : A DO R.K.Yadav
9. Name and designation of Officer
- 10: from the building side : Mrs. Swati Kaushik (Vice-Principal)
11. Year of Construction : 2000
12. Applicant's letter No : LKPSS/Fire/396/2018 Dated 22/09/18

N O.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	06 M	06 M	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 no.	3 No.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.5 M	1.15 M, 1.0 M & .75 M	MR old accepted
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	2 no.	2 No.	MR
	g. Width of Corridor	1.5 M	1.5 M	MR
	h. Door Size	1.0 M	1.0 M	MR
3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	08 Nos.	08 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	1 no.	Provided	MR
	• Length of hose reel hose	30 M	30 M	MR
	• Nozzle diameter	5 mm	5 mm	MR

N/B

7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 M	40 M	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
15	• Overhead Tank capacity	5000 Ltrs.	5000 Ltrs.	MR

16	Exit Signage.	N/A	N/A	N/A
	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
17	• Lift Signage	N/A	N/A	N/A
18	Standby power supply	N/A	N/A	N/A
	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
19	• Location	N/A	N/A	N/A
	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
20	• Building Floor Plans	N/A	N/A	N/A
	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of deemed compliance of the minimum standards of fire prevention and fire Safety measured as required under the rules. The fire safety certificate issued vide letter no. F6/DFS/MS/school/09/1723 dated 21/08/09 renewal under the circular no.262-362 dated 17/01/2005 is recommended.

R. K. Yadav
29/10/2018

Signature of the Inspecting Officer
Name:-R.K.Yadav
Designation:-ADO(LN)

DO(ED) *[Signature]*
11/11/18

725/cf/NM2
9/11-27-11-18

DY LFO/MDM

[Signature]

~~CFO~~

miscell. FTM.
u/gt xl.

Sta, FT letter is put up for sign for

R. K. Yadav
20/11/2018