

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F.6/DFS/MS/WZ/2018/ 2550

Dated: 26/11/2018

FIRE SAFETY CERTIFICATE

Certified that the building of **Nigam Pratibha Vidyalaya** Located at, **Satyawati Nagar (School ID-1354140) Delhi. 110052** comprised of Ground + 02 Upper Floors, owned and occupied by **Nigam Pratibha Vidyalaya** have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education/ NBC Part IV and verified by the officer concerned of Fire Service on 29-10-2018 in the presence of **Smt. Sheela Jain (Principal)** and that the building / premises is fit for the occupancy class "Educational" Group B Sub Division B – 1 with effect from 26/11/18.... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/11/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service.

Copy to:

1. The Principal, Nigam Pratibha Vidyalaya, Satyawati Nagar (School ID-1354140) Delhi- 52.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: **Nigam Pratibha Vidyalaya** Located at, **Satyawati Nagar (School ID-1354140) Delhi. 110052.**
2. Type of Occupancy : Educational (Ground + 2 Upper Floor)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : 3298-3398 dated 01-03-2011
6. Date of inspection : 29/10/2018
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side : Smt. Sheela Jain (Principal)
9. Year of Construction : 1991
10. Applicant's letter No. : Nil Dated 26/09-2018

| |
|--|
| Plot Area - 3452M ² Covered Area -544 M ² No. or Class Rooms-20 No. of Student- 219 |
|--|

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Cr.No.3298-3398 dated 01-03-2011 | Provided at site | Remarks MR/NMR |
|------|---|----------------------------------|----------------------------|----------------|
| 1. | Access of building | | | |
| | • Road width | Accessible | 5m Provided | MR |
| | • Gate width | Accessible | 380cm Provided | MR |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 1 | Provided | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 1x1.50 mtr | 2x143cm | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | • Fire check door | NR | NR | NR |
| | • Pressurization | NR | NR | NR |
| | d. No of continuous staircase to terrace | | | |
| | e. Width Of Corridor | NA | NA | NA |
| | f. Door Size(Class room) | 1mtr | 110cm & 93cm (Double Door) | MR |

| | | | | |
|-----|--|-----------------------|------------|----|
| 3. | Compartmentation | | | |
| | • Fire check door | NA | NA | NA |
| | • Sealing of electrical shafts | NA | NA | NA |
| | • Fire Rating of shaft door | NA | NA | NA |
| | • Water Curtain | NA | NA | NA |
| | • Fire Dampers | NA | NA | NA |
| 4. | Smoke managements System | | | |
| | • Basements | NR | NR | NR |
| | • Upper floors | NR | NR | NR |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 8 nos. | 8 Provided | MR |
| | • Types | ABC & CO ₂ | Provided | MR |
| | • IS marking | ISI marked | Provided | MR |
| 6. | First – Aid Hose Reels | | | |
| | • Total numbers on each floor | one | Provided | MR |
| | • Length of hose reel hose | 30m | Provided | MR |
| | • Nozzle diameter | 5mm | Provided | MR |
| 7. | Automatic fire detection and alarming system | | | |
| | • Type of detectors | NA | NA | NA |
| | • Location of Main Panel | NA | NA | NA |
| | • Location of Repeater Panel | NA | NA | NA |
| | • Alternate source of power | NA | NA | NA |
| | • Hooters' Location | NA | NA | NA |
| 8. | MOEFA | NA | NA | NA |
| 9. | Public Address System | NA | NA | NA |
| 10. | Automatic Sprinkler System | | | |
| | • Basements | NA | NA | NA |
| | • Upper Floor | NA | NA | NA |
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11. | Internal Hydrants: | | | |
| | • Size of riser/down-comer | NA | NA | NA |
| | • Number of hydrants per floor | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 12. | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |


| | | | | |
|-----|--|-----------|----------|----|
| 13. | Pumping Arrangements: | | | |
| | • Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | ➤ Head of main pump | NA | NA | NA |
| | ➤ Number of main pumps | NA | NA | NA |
| | ➤ Jockey pump out put | NA | NA | NA |
| | ➤ Jockey pump head | NA | NA | NA |
| | ➤ Standby Pump out put | NA | NA | NA |
| | ➤ Standby Pump Head | NA | NA | NA |
| | ➤ Auto Staring/Manual stopping | NA | NA | NA |
| | ➤ Pump House Access | | | |
| | • Terrace level | 450 lpm | Provided | MR |
| | ➤ Discharge of pump | 40Mtr | Provided | MR |
| | ➤ Head of the pump | Required | Provided | MR |
| | ➤ Power supply | Required | Provided | MR |
| | ➤ Auto starting of pump | | | |
| 14. | Captive water Storage for fire fighting: | | | |
| | • Under ground tank capacity | NA | NA | NA |
| | ➤ Draw off connection | NA | NA | NA |
| | ➤ Fire service inlet | NA | NA | NA |
| | ➤ Access to tank | NA | NA | NA |
| | • Overhead Tank capacity | 10,000Ltr | Provided | MR |
| 15 | Exit Signage | Required | Provided | MR |
| 16. | Provision of Lifts | | | |
| | ➤ Pressurization of Lift Shaft | NA | NA | NA |
| | ➤ Pressurization of lift lobby | NA | NA | NA |
| | ➤ Communication in lift Car | NA | NA | NA |
| | ➤ Fireman's Grounding Switch | NA | NA | NA |
| | ➤ Lift Signage | NA | NA | NA |
| 17. | Standby power supply | NA | NA | NA |
| 18. | Refuge Area | | | |
| | ➤ Total area | NA | NA | NA |
| | ➤ Location | NA | NA | NA |
| 19. | Fire control room | | | |
| | ➤ Detector system panel | NA | NA | NA |
| | ➤ Flow Switch Panel | NA | NA | NA |
| | ➤ PA System Panel | NA | NA | NA |
| | ➤ Battery backup | NA | NA | NA |
| | ➤ Building Floor Plans | NA | NA | NA |

| | | | | |
|-----|--|----|----|----|
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | NA | NA | NA |
|-----|--|----|----|----|

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNIL.....


Signature of the Inspecting Officer


Signature of the Inspecting Officer

Name Uday Vir Singh
Designation ADSO/WP

Name
Designation

DO/W 12/11/18
Dy. CEO 12/11/18
CEO 12/11/18
FTPLS.

ADSO/WP Sir FY letter is put up
Jan Sir for ple. 12/11/18
CEO 12/11/18
m