

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001



No. F6/DFS/MS/2018/ W2/2559

Dated: 27 /11/2018

FIRE SAFETY CERTIFICATE

Certified that the M/S R. K. Banquets Located at 7/16, Ground Floor Kirti Nagar Industrial Area New Delhi-110015, in a building comprised of Basement + Stilt + Ground + First Floors owned/ occupied by M/S R. K. Banquets have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 30-10-2018 in the presence of Sh. R.K. Bharti (Owner) and found that the said building / premises is fit for occupancy class " Assembly" Group D (Ground Floor only) with effect from 27/11/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on27.11.18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,


Copy to:-1. Sh. R.K. Bharti (Owner), M/S R. K. Banquets, 7/16, Ground Floor Kirti Nagar Industrial Area New Delhi-110015.
2. Dy. Health Officer, Karol Bagh Zone, Anand Parbat NDMC, Public Health Department, New Delhi.110005.

Following fire safety directives must be adhered to:-

1. **The FSC is valid for Ground Floor only.**
2. **Upper Floors shall be kept sealed by brick wall as shown in the photo graph enclosed.**
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. **Basement shall not be used for any purpose.**
9. The entire/ exit shall be kept free from any obstruction.
10. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
11. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

2. Name & address of the building: M/S R. K. Banquets Located at 7/16, Ground Floor, Kirti Nagar Industrial Area New Delhi-110015.
3. Type of Occupancy : Assembly (Basement + Stilt + Ground + First Floors Only)
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives Letter No. : F6/DFS/MS/2018/2834 Dated – 02/07/2018
7. Date of inspection : 30-10-2018
8. Name of the Inspecting Officer : ADO (WP)
9. Name and designation of Officer
from the building side : Sh. R.K. Bharti (Owner)
10. Year of Construction : 2018
11. Applicant's letter No. : DHO/KBZ/2018/446 Dated-06/06/2018

Covered Area=GF =661 M ² FF=449M ² (Closed) Total Plot Area= 668 M ² Basement=Storage, Stilt=Parking UGF = Banquet Hall

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	16 Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	2	2 Provided	MR
	b. Width of staircases			
	• Upper floors	2X2m,	Stilt To GF=2x200cm	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NR	NR	NR
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	Hall	NA
	f. Door Size	2m	Stilt =274cm & 242cm GF =200 cm & 150cm	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NA	NA	NA
	• Fire Damper	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	8nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	NA	Provided	NA
	• Location of Repeater Panel	NA	Provided	NA
	• Alternate source of power	NA	Provided	NA
	• Hooters' Location	NA	Provided	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	Required	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	2280lpm	NA
	➤ Head of main pump	NA	70m	NA
	➤ Number of main pumps	NA	1	NA
	➤ Jockey pump out put	NA	180 lpm	NA
	➤ Jockey pump head	NA	60m	NA
	➤ Standby Pump out put	NA	2280lpm	NA
	➤ Standby Pump Head	NA	70m	NA
	➤ Auto Staring/Manual stopping	NA	Required	NA
	➤ Pump House Access	NA	Provided	NA
	• Terrace level			
	➤ Discharge of pump	900lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Reuired	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	30, 000 ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts ;-Lift shall run from Ground to Upper Floors			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNIL.....

Signature of the Inspecting Officer

Name Shri Mukesh Verma

Designation DO/W

Signature of the Inspecting Officer

Name Uday Vir Singh

Designation ADO/WP

Handwritten notes:

about about shortcomings. Communicated on Sat. 9/10/18

2/11/18

5/11/18

ADO/WP

Sir earlier the shortcomings were communicated for B+stilt+A+FF, but now the PSC is recommended for C floor only.

Submitted Ple.

12/11/18

16/11/18