

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI


No.F.6/DFS/MS/WZ/2018/ 2565

Dated: 28/11/2018

FIRE SAFETY CERTIFICATE

Certified that the **Tagore Modern Public School** Located at, Ground and 1st Floor, **BN (Paschimi) Shalimar Bagh Delhi - 110088** comprised of Basement +Ground + 02 Upper Floors was issued FSC vide Letter No. **F6/DFS/MS/09/3495 Dated-20/11/2009**. The premises was re inspected by the officer concerned of this department on 09/10/2018 in the presence of **Sh R S Jain (Hony Secretary)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B (Ground and 1st Floor only) with effect from 28/11/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28.11.18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Principal, Tagore Modern Public School,, Ground and 1st Floor, BN (Pashimi) Shalimar Bagh Delhi – 110088.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-


1. **2nd Floor shall not be used for any purpose.**
2. **Basement shall be used strictly as per BBL.**
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Tagore Modern Public School Located at, BN (Pashimi) Shalimar Bagh Delhi - 110088.
2. Type of Occupancy : Educational (Basement + Ground + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/09/3495 Dated-20/11/2009
5. Fire Safety directives Letter No. : DOE 262-362 dated 17-01-2005
6. Date of inspection : 09-10-2018
7. Name of the Inspecting Officer : Udai vir singh, ADO (WP)
8. Name and designation of Officer
from the building side : Sh. R. S. Jain (Hony. Secretary)
9. Year of Construction : 1991
10. Applicant's letter No. : Nil dated 24/09/2018

No. of Students=140
No. of class rooms=20
Plot area=800 m ²
Covered area=960m ²

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No. 262-362 dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	370cm Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2 Provided	MR
	• Basements	2	3 Provided	MR
	b. Width of staircases			
	• Upper floors	150cm	156 cm (Including Railing) 70cm (Up to FF)	MR (Old case)
	• Basements	150cm	132cm, 150cm, & 105cm	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 mtr	100cm	MR



3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	07nos.	8 Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	Required	Provided	MR
		30m	Provided	MR
	• Length of hose reel hose	5mm	Provided	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	Required	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA

Handwritten signature and initials.

13	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head			
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lmm & 220lpm	Provided	MR
	➤ Head of the pump	40m	Provided	MR
➤ Power supply	Required	Provided	MR	
➤ Auto starting of pump	Required	Provided	MR	
14. Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10000 Ltrs	Provided	MR
15	Exit Signage	NA	NA	NA
16. Provision of Lifts				
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18. Refuge Area				
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19. Fire control room				
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/09/3495 Dated-20/11/2009 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

~~10/15/18~~
Signature of the Inspecting Officer
Name Uday Vir Singh
Designation ADOLWP

Signature of the Inspecting Officer
Name
Designation

~~DPTA~~
~~Dy. CFO (W2)~~
~~CFO West~~
25/11/18
29/11/18

Ask them to send Dtd Ptn by mail
20/11/18

ADOLWP

Sir, 2nd floor has been closed
Photograph is placed opposite at c/o.
Submitted for approval Plc. 10/20/18

CFO
20/11/18