

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/H/SZ/2018/ 2552

Dated: 26/11/18

**FIRE SAFETY CERTIFICATE**

Certified that the **Ware House namely Air Cargo Logistics Center (ALCLC II)** situated at IGI Airport, New Delhi-110037 (for M/s Shrishti Cargo Warehouse Pvt. Limited), comprised of Ground Floor (Shed) only was inspected by the officer concerned of this department on 16/11/2018 in the presence of Sh. M. D. Kala (COO of M/s Shrishti Cargo Warehouse Pvt. Limited) and found that the said building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that these building blocks is deemed fit for occupancy class "**Group- H (Storage)**" with effect from 26/11/2018 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010.

Issued on.....26/11/18.....at New Delhi by.

  
(Vipin Kental)  
Chief Fire Officer  
Tel: 011-23412225

Copy to:-

1. Sh. Ritesh Yarlagadda (CEO), M/s Shrishti Cargo Warehouse Pvt. Limited, D-2, Southern Park, Saket Place, Saket, New Delhi-110017
2. The CEO, DIAL, Udaan Bhawan, IGI Airport, New Delhi-110037

**Conditions for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration **every year** in **Form 'K'** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [http://delhi.gov.in/wps/wcm/connect/doit\\_fire/FIRE/Home/Forms](http://delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry."

## INSPECTION REPORT

1. Name & address of the building : Ware House namely Air Cargo Logistics Center (ACLC II) at IGI Airport, New Delhi-110037 (for M/s Shrishti Cargo Warehouse Pvt. Limited)
2. Type of Occupancy : Group-H (Storage Building)
3. Type of Case : New [Ground Floor (Shed)]
4. Details of Previous NOC : -NA-
5. Fire Safety directives letter No : F6/DFS/MS/2018/3614 dated 23/08/2018
6. Date of inspection : 16/11/2018
7. Name of Inspecting Officer : A. K. Malik
8. Name and designation of officer from the building side : Mr. M. D. Kala (COO of M/s Shrishti Cargo Warehouse Pvt. Limited)
9. Year of Construction : 2018
10. Applicant's letter No. : outdoor diary 14/11/2018

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	UBBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	6m 4.5m As per plan	Provided Provided 6m	MR MR MR
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floor</li> <li>Basements</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	28 x 1.5m	Provided	MR
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain/Roof Screen/Curtain Boards</li> <li>Fire Dampers</li> </ul>	-NA- -NA- -NA- Required -NA-	-NA- -NA- -NA- Provided -NA-	-NA- -NA- -NA- MR -NA-
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Ground/Upper floors</li> </ul>	NA Annex. M	NA Provided	NA MR
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	Required ABC/W.CO <sub>2</sub> /CO <sub>2</sub> /Foam Required	80 Nos 25/25/15/15 Yes	MR MR MR
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Required 30m 6mm	16 Nos Provided Provided	MR MR MR
7.	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	Smoke & Heat Ground Floor -NA- Required All Area	Provided Provided -NA- Provided Provided	MR MR -NA- MR MR
8.	<b>MOEFA</b>	Required	Provided	MR
9.	<b>Public Address System</b>	Required	Provided	MR

10.	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		Required as per clause 3.1.2 of UBBL-2016(Annexure-XIII)	Provided	MR
		-NA-	-NA-	-NA-
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	Required	100mm	MR
		Required	16 Nos	MR
		Required	16 Nos	MR
12.	<b>Yard Hydrants</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	28 Nos	Provided	MR
		28 Nos	Provided	MR
13.	<b>Pumping Arrangements</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/Manual Stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>			
		2850 LPM	2280 LPM	MR
		70m	Provided	MR
		One	Two	MR
		180LPM	Provided	MR
		70m	Provided	MR
		2850 LPM	Provided	MR
		70m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		450 LPM	Provided	MR
		40m	Provided	MR
		Required	Provided	MR
Required		Provided	MR	
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	2,00,000	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10,000 Lts	Provided	MR
Required	Provided	MR		
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	Required	Provided	MR	
17.	<b>Standby power supply</b>			
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>Total Area</li> <li>Location</li> </ul>	NA	NA	NA
		NA	NA	NA
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>			
	i) Manual gas flooding/linear heat sensitive tubes with	Provided	MR	

		& LT panels	
--	--	-------------	--

The shortcomings communicated vide letter no. F6/DFS/MS/SZ/2018/3796 dated 07/09/2018 found complied. The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. Keeping in view of the above substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35(3) of the Delhi Fire Service Rules 2010.

Accordingly form "H" in shape of DFA is put up for approval under rule 35(4).

*A. K. Malik*  
16/11/18

Signature of Inspecting Officer  
Name: A. K. Malik  
Designation: DO (SD)

Dy. CFO (SZ)



*[Signature]*  
16/11

*CFO, SZ*

*M-Scell*

*FTM*

*U*  
22/11

*SDM FT-28 put up for sig. please*

*[Signature]*  
26/11/18  
DO(SD)

*[Signature]*

*M-Scell*

*U*  
26/11

*208/CFO SZ*  
26/11