

FORM H:
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F-6/DFS/MS/WZ/2018/ 2575

Dated-29 /11/2018

FIRE SAFETY CERTIFICATE

Certified that the **D Mall (Mera Baba Reality Pvt. Ltd.) located at Plot No- A-1, Netaji Subhash Place Pitampura, Delhi- 110034** comprised of Three Basement + Ground +12 upper Floor only was issued FSC vide Letter No. F6/DFS/MS/WZ/2015/1331 dated 23-07-15. The premises was re inspected by the officers concerned of this department on 22-11-2018 in the presence of Sh. Harish Raj (G.M) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class " Assembly" Group D with effect from 29/11/18 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ..29/11/18..... at New Delhi by.


(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to: Sh. Harish Raj (G.M), D Mall (Mera Baba Reality Pvt. Ltd.) Plot No- A-1, Netaji Subhash Place pitampura, Delhi- 110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

No- A-1, Netaji Subhash Place Pitampura, Delhi- 110034.

2. Occupancy : Class-F (Mercantile)(3B+G+12UF)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/WZ/2015/1331 dated 23-07-15.
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2005/1792 Dated 30/08/2005
6. Date of inspection : 22/11/2018
7. Name of the Inspecting Officer : DO/W & ADO (WP)
8. Name and designation of Officer
from the building side : Sh.Harish Raj (G.M)
9. Year of Construction : 2006/07
10. Applicant's letter No. : Nil Dated 15-10-2018

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 m	30m Provided	MR
	• Gate width	6 m	Provided	MR
	• Width of internal road	8.5m	6m Provided	MR
2.	Number, width, Type & Arrangements of exits)			
	a. Number of staircases			
	• Upper floors	4	4	MR
	• Basements	4	5+2 Ramp	MR
	b. Width of staircases			
	• Upper floors	2x1.25 m, 2x1.5 m	2x1.5 m & 2x1.25 m	MR
	• Basements	2x1.25 m 2x1.5 m	2x1.5 mtr & 3x1.25 m	MR
	c. Protection of exits	&1x1.2 m (Ramp)	Ramp	
	• Fire check door			
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
		Required	Provided	MR
	e. Width Of Corridor	Required	Provided	MR
	f. Door Size	1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	55 nos.	Provided	MR
	• Types	ABC, CO2 & WCO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each	4	Provided	MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	MR
		Ground Floor	Provided	MR
		Ground Floor	Provided	MR
		Required	Provided	MR
		All area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	150 mm	Provided	MR
		4	Provided	MR
		4 Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	4	Provided	MR
		4	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual stopping ➤ Pump House Access Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	4500lpm	Provided	MR
		65m	Provided	MR
		2	Provided	MR
		180lpm	Provided	MR
		65m	Provided	MR
		4500lpm	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14.		Captive water Storage for fire fighting		
	<ul style="list-style-type: none"> Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	2500000ltr	Common with the mall	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		50, 000 litres	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	Required	Provided	MR
		4,6 & 9 th floor	Provided	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR

	<ul style="list-style-type: none"> Alternate source of power Hooters' Location 	Required	Provided	MR
		All area	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements 	Required	Provided	MR
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer 	150 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	4	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	4 Required	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants 	4	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	4	Provided	MR
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	4500lpm	Provided	MR
	<ul style="list-style-type: none"> Head of main pump 	65m	Provided	MR
	<ul style="list-style-type: none"> Number of main pumps 	2	Provided	MR
	<ul style="list-style-type: none"> Jockey pump out put 	180lpm	Provided	MR
	<ul style="list-style-type: none"> Jockey pump head 	65m	Provided	MR
	<ul style="list-style-type: none"> Standby Pump out put 	4500lpm	Provided	MR
	<ul style="list-style-type: none"> Standby Pump Head 	Required	Provided	MR
	<ul style="list-style-type: none"> Auto Staring/Manual stopping 	Required	Provided	MR
	<ul style="list-style-type: none"> Pump House Access 	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level 	NA	NA	NA
	<ul style="list-style-type: none"> Discharge of pump 	NA	NA	NA
	<ul style="list-style-type: none"> Head of the pump 	NA	NA	NA
	<ul style="list-style-type: none"> Power supply 	NA	NA	NA
	<ul style="list-style-type: none"> Auto starting of pump 	NA	NA	NA
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity 	2500000ltr	Common with the mall	MR
	<ul style="list-style-type: none"> Draw of connection 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	Provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	Provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	50, 000 litres	Provided	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization of lift lobby 	Required	Provided	MR
	<ul style="list-style-type: none"> Communication in lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> Lift Signage 	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area 	Required	Provided	MR
	<ul style="list-style-type: none"> Location 	4,6 & 9 th floor	Provided	MR
19.	Fire control room			
	<ul style="list-style-type: none"> Detector system panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Flow Switch Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> PA System Panel 	Required	Provided	MR
	<ul style="list-style-type: none"> Battery backup 	Required	Provided	MR
	<ul style="list-style-type: none"> Building Floor Plans 	Required	Provided	MR

20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 Flooding system	MR
-----	--	----------	---------------------	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection. In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter no F6/DFS/MS/WZ/2015/1331 dated 23-07-15 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note:- All the shortcomings communicated earlier has been complied.

Signature of the Inspecting Officer
 Name Udaivir Singh
 Designation ADO/WP

Signature of the Inspecting Officer
 Name
 Designation

DO/WZ *[Signature]* 26/11/18

~~DO/WZ~~ *[Signature]* 27/11/18

~~ADO/WP~~ *[Signature]* 28/11/18

FIPS

~~ADO/WP~~

Sir FY letter is put up for

sign ple. *[Signature]* 28/11

~~ADO/WP~~ *[Signature]* 29/11/18

Museep