

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/BH/WZ/2018/ 2579

Dated: 30/11/18

FIRE SAFETY CERTIFICATE

Certified that the Le Paradise Banquet Hall at Khasra No.523/2 (0-09), 528/2(1-0), Opp. Metro Pillar No.511, Main Rohtak Road, Mundka, Delhi-110041 comprised of Basement, Ground Floor & Two Upper Floors only owned / occupied by Le Paradise Banquet Hall has already been issued Fire Safety Certificate by this department vide letter No. F6/DFS/BH-2015/WZ/682 dated 06/05/15. The premises was re-inspected by the officer concerned of this department on 16.11.2018 in the presence of Sh. Lalit (Manager) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the Fire Prevention and Fire Safety Requirements in accordance with rule 33 of the Delhi Fire Service Rule 2010 and that the Building /Premises is fit for occupancy class "Assembly" (Group-D) with effect from 30.11.2018/2018 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 30.11.18..... at New Delhi.


(ATUL GARG)

CHIEF FIRE OFFICER.

Copy to :-

1. Authorized Signatory, Le Paradise Banquet Hall at Khasra No.523/2 (0-09), 528/2(1-0), Opp. Metro Pillar No.511, Main Rohtak Road, Mundka, Delhi-110041.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Le Paradise Banquet Hall at Khasra No.523/2 (0-09), 528/2(1-0), Opp. Metro Pillar No.511, Main Rohtak Road, Mundka, Delhi-41.
2. Type of Occupancy : Assembly (Banquet Hall)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/BH-2015/WZ/682 dated 06/05/15
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2014/2062 dated 02/09/2014
6. Date of inspection : 16/11/2018
7. Name of the Inspecting Officer : A.D.O. (JWP)
8. Name and designation of Officer from the building side : Sh. Lalit (Manager)
9. Year of Construction : 2014-15

Basement + Ground + Two Upper Floors Only

10. Applicant's letter No. : -Nil Dated 05/08/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtr	12 mtr	MR
	• Gate width	4.5 mtr	4.5 mtr	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	2	2 Stairs & 1Ramp	MR
	b. Width of staircases			
	• Upper floors	2.00 mtr.	2.00 mtr	MR
	• Basements	2.00 mtr	2.00 mtr & 3.50mtr (Ramp)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	2	2	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	2.00 mtr	2.00 mtr	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	10	15	M/R
	• Types	ISI marked ABC/CO ₂	Provided	M/R
	• IS marking	Required	Provided	M/R



6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	2	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Alternate Floor	Provided	NMR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Ground Floor	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NR	NR	NR
	• Sprinkler above false ceiling	NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	150 mm	MR
	• Number of hydrants per floor	One	One	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 LPM	2280 LPM	MR
	➤ Head of main pump	40 MH	40 MH	MR
	➤ Number of main pumps	One	One	MR
	➤ Jockey pump out put	180 LPM	180 LPM	MR
	➤ Jockey pump head	40 MH	40 MH	MR
	➤ Standby Pump out put	2280LPM	2280LPM	MR
	➤ Standby Pump Head	40 MH	40 MH	MR
	➤ Auto Starting/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900LPM	900LPM	MR
	➤ Head of the pump	40MH	40MH	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under Ground Tank capacity	50,000 Ltr	50,000 Ltr	MR
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank	10,000ltr	10,000ltr	MR

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/BH-2015/WZ/682 dated 06/05/15 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DO/CPD
 26/11/18
 27/11/18
 20/11/18
 CPD West
 FPPI

Ashok Kumar Jaiswal
 22/11/18

Signature of the Inspecting Officer
 Name : Ashok Kumar Jaiswal
 Designation : A.D.O. (Jwala Puri)

AND/CP
 FT letter is put up for sign please