

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2018/ 2577

Dated: 30/11/2018

FIRE SAFETY CERTIFICATE

Certified that the **Shopping Mall, Community Centre** Located at **Block- A Shalimar Bagh New Delhi-110088** comprised of Lower Basement & Upper Basement & Ground + 5 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2015/WZ/1035 dated 18/06/2015. The premises was re inspected by the officers concerned of this department on 25-10-2018 in the presence of **Mr. Abhishek Sharma** of the shopping mall and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Mercantile & Assembly Building" Group F & Group D with effect from 30/11/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...30/11/18..... at New Delhi by.

(Atul Garg)
Chief Fire Officer,
Delhi Fire Service

Copy to:

1. The Authorized Person, Shopping Mall, Community Centre, Block- A Shalimar Bagh New Delhi-110088

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. All the doors, Exits and internal roads must be kept free from any obstruction.

INSPECTION REPORT

1. Name & address of the building: Shopping Mall, Community Centre Located at Block- A Shalimar Bagh New Delhi-110088
2. Type of Occupancy : Class F (Mercantile)
3. Type of Case : Renewal
4. Details of previous FSC : L. No. F6/DFS/MS/2015/WZ/1035 dated 18-06-15
5. Fire Safety directives Letter No. F6/DFS/MS/BP/2004/2443 dated 14-10-2004
6. Date of inspection : 29/10/2018
7. Name of the Inspecting Officer : ADO (WP) & DO/W
8. Name and designation of Officer
from the building side : Sh. Abhishek Sharma
9. Year of Construction : 2006
10. Applicant's letter No. : Nil Dated-Nil

S N o	Minimum standards on fire prevention and fire safety U/R 33	Requirements As N/23	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	24mtr	MR
	• Gate width	4.5 m	5m Provided	MR
	• Width of internal road	6 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	10	Provided	MR
	• Basements	16	Provided	MR
	b. Width of staircases			
	• Upper floors	2x2m & 8x1.5m	Provided (Old case)	MR (Old case)
	• Basements	2x2m & 14x1.5m	Provided (Old case)	MR (Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	Required	Provided	MR
	f. Door Size	1.5m	Provided	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	Required	Provided	MR
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	50	Provided	MR
	• Types	ABC, CO2 & WCO2	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	4	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Ground floor	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11	Internal Hydrants			
	• Size of riser/down- comer	150 mm	Functional	MR
	• Number of hydrants per floor	4	Provided	MR
	• Hose Box	4	Provided	MR
12	Yard Hydrants			
	• Total number of hyds	6	Provided	MR
	• Hose Box	6	Provided	MR
13	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	4500lpm	Functional	MR
	➤ Head of main pump	60 m	Provided	MR
	➤ Number of main pumps	3	Provided	MR
	➤ Jockey pump out put	Two180 lpm	Functional	MR
	➤ Jockey pump head	60 m	Provided	MR
	➤ Standby Pump out put	4500 lpm	Functional	MR
	➤ Standby Pump Head	60 mtr	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14	Captive water Storage for fire fighting			
	• Under ground tank cpty	3,00,000 litres	Provided	MR
	➤ Draw of connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30, 000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided in basment	MR
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR

17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 Flooding in DG Room	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/2015/WZ/1035 dated 18-06-15 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer



Signature of the Inspecting Officer



Name

Udai Vir Singh

Name

Sh Mohesh Verma

Designation

ADD/WP

Designation

DO/W

~~DD/W~~

~~CD/W~~

26/11/18
FT PG

ADD/WP
Sir FT letter is put up for

Sign Ple. 22/11