

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6 / DFS / MS / 2018 / *w2/2583*

Dated: *30/11/2018*

FIRE SAFETY CERTIFICATE

Certified that the **Sum Smile Public School** located at **A-442, Inder Enclave Ph-II, Delhi-110086** comprised of **ground floor only** owned/ occupied by owned/ occupied by **Sum Smile Public School** have complied with the fire prevention and safety requirements in accordance with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **19.11.2018** in the presence of **Sh. R.B. Sharma (Principal)** and that the building/premises is fit for occupancy Group B Educational for ground and first floor only with effect from *30.11.18*..... for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on*30.11.18*..... at New Delhi

(Signature)
(Atul Garg)

Chief Fire Officer

Ph:-011-23414250

Copy to :-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.
2. The Principal, Sun Smile Public School, A-442, Inder Enclave, Ph-II,, Delhi-110086.

N/S

INSPECTION REPORT

1. Name & address of the building : Sun Smile Public School, A-442, Inder Enclave, Ph-II,, Delhi-86.
 2. Type of Occupancy : Educational (Ground floor only)
 3. Type of Case : New Case
 4. Details of previous NOC : Nil
 5. Fire Safety directives letter No : Director of Education Letter dated 01.03.2011
 6. Date of inspection : 19.11.2018
 7. Name of the Inspecting Officers : ADO (RN)
 8. Name and designation of officers
 from the building side : Sh. R.B Sharma (Principal)
 9. Year of Construction :
 10. Applicant's letter No. : Nil Dairy No-12783 Dated 05.09.2018

Plot Area-547 Sq.y Covered area ----300 sq.y, No of student—60 nos, Total class room --06nos

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Education	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	06m	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1m	1m	MR

3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5	Fire Extinguishers			
	• Total numbers	03nos	04 nos	MR
	• Types	ABC/Co2	ABC--04	MR
	• ISI marking	Yes	Yes	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA

	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> Hose Box 	NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	NA	NA	NA
	3. Draw-off connection	NA	NA	NA
	4. Fire service inlet	NA	NA	NA
	5. Access to tank	NA	NA	NA
	<ul style="list-style-type: none"> Overhead Tank capacity 	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pressurization of Lift lobby 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Communication In lift Car 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Lift Signage 	N/A	N/A	N/A


N/R

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A


The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

The school management has complied all the observations issued & communicated by this department vide letter of even no. 3100 dated 19.07.2018


Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in director of education Circular dated 01.03.2011, fire safety certificate is recommended.


Signature of the Inspecting Officer
Name :- Rajesh Kumar

Designation:- ADO/RN

Dy. Chd. W. 2
Cfo West

27/11/18
FTPI/S

ADO RN As approved, G.T. letter is
being for your signature P1

Cfo W. 2

27/11/18
M

1/4
29/11