

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/^{BNET}CH/2018/NDZ/ 2603

Dated 04/12/18

FIRE SAFETY CERTIFICATE

Certified that M/s S.K. Wedding Bell, Banquet hall (G. floor) and M/S Green Palms on (First floor) at Plot No. B-17 (Part-A) Jhilmil Industrial Area, Delhi 32. comprised of ground plus one upper floor owned / occupied by Aromatic Veggies Pvt. Ltd. having Banquet hall, on ground floor and 28 guest room on first floor respectively . The Premises was inspected by the team of officers of this department in presence of Sh. Arun Maini (Director) and Mr. Mohit and found that the Assembly building have complied with the Fire prevention and Fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010, and observed that the building is fit for Assembly occupancy wef. 04/12/18 for a period of three years in accordance with Rule 36 unless renewed under rule 37, or sooner cancelled under Rule 40, and subject to compliance of the conditions under Rule 38, of the Delhi Fire Service Rule 2010, subject to conditions printed overleaf.

Issued on 04/12/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Deputy Health Officer,
Shahdara South zone, Karkardooma,
East Delhi Municipal Corroboration Delhi-32
2. Arun Maini
Aromatic Veggies Pvt. Ltd.
S.K. Wedding Bells
B-17 Part- A Green Palms
1 st Floor Jhilmil Ind. Area,

01c
fu

CONDITIONS

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. Land use /Conversion of occupancy shall be ensured by the concerned local/ building authority.

1. Name & Address of the building : M/s S.K. Wedding Bell, Banquet Hall at Plot No. B-17 (Part-A), and M/S Green plams at Jhilmil Industrial Area, Delhi-32.
2. Building is comprised of : Ground plus one upper floor, (height-10M)
3. Type of Occupancy : Assembly, (Banquet hall & Rooms)
4. Type of Case : New
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F.6/DFS/MS/2018/BP/3595, Dated 23/8/2018
7. Date of Inspection : 20. 11.2018
8. Name of the Inspecting officers : DO F.BROWN, VIJAY BHADUR (ADO)
9. Name and designation of officer from the building side : Mr. Arun Maini , Mr. Mohit (Director)
10. Year of construction : 2016,
- 11 Applicant's letter No :DHO/Shd.(s)/2018/1640 dated 05/7/18.&5/11/18.

S.No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	Directive Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m N/A N/A	18 m N/A N/A	MR N/A N/A
2	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases <ul style="list-style-type: none"> Upper floor Basement 	04 N/A	04 N/A	MR N/A
	B. Width of Staircases <ul style="list-style-type: none"> Upper floor Basement 	02Mx3 & 01x1.2M N/A	02M (03nos) & 1.3 M (01) N/A	MR N/A
	c. Protection of Exits <ul style="list-style-type: none"> Fire check door Pressurization 	Required at Kitchen N/A	Provided N/A	MR N/A
	d. No. of Continuous Staircases to Terrace	03	03	MR
	e. Width of Corridor	02M	02.M	MR
	f. Door Size	02 m	03 mx3 & 02 m x 1, 1.2 m x1	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire dampers 	Required N/A N/A N/A N/A	Provided N/A N/A N/A N/A	MR N/A N/A N/A N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A Required	N/A Provided	N/A MR
5.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	20 nos. ABC /CO ₂ ISI marked	22 Nos. ABC /CO ₂ ISI marked	MR MR MR


06	First-Aid-Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04 No.	04 No.	MR
		30 m	30 m	MR
		5 mm	5 mm	MR
07	Automatic Fire Detection and Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of main panel Location of repeater panel Alternate source of power Hooter's location 	N/A	provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	MR
		N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement upper floor sprinkler above false ceiling 	N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> size of riser/down-comer Number of hydrants per floor Hose box 	100mm	Provided	MR
		04	Provided	MR
		04	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose box 	NA	N/A	N/A
		NA	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> Discharge of main pump 	2280 LPM	2280 LPM	MR
	<ul style="list-style-type: none"> Head of main pump 	60M	60 M	MR
	<ul style="list-style-type: none"> Number of main pumps 	01	01	MR
	<ul style="list-style-type: none"> Jockey pump out put 	180LPM	180 LPM	MR
	<ul style="list-style-type: none"> Jockey pump head 	60M	60M	MR
	<ul style="list-style-type: none"> Standby pump out put 	2280 LPM	2280 LPM	MR
	<ul style="list-style-type: none"> Standby pump head 	60M	60 M	MR
	<ul style="list-style-type: none"> Auto starting /manual stopping 	Required	provided	MR
	<ul style="list-style-type: none"> Pump house access 	N/A	provided	MR
	➤ Terrace Level			
	<ul style="list-style-type: none"> Discharge of pump 	450 lpm	450 lpm	MR
	<ul style="list-style-type: none"> Head of the pump 	40M	40M	MR
	<ul style="list-style-type: none"> Power supply 	Required	provided	MR
	<ul style="list-style-type: none"> Auto Starting of pump 	Required	provided	MR
14	Captive Water Storage for Fire Fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	1,00,000Ltr.	1,00,00 Ltr.	MR
	<ul style="list-style-type: none"> Draw-off connection 	Required	provided	MR
	<ul style="list-style-type: none"> Fire service inlet 	Required	provided	MR
	<ul style="list-style-type: none"> Access to tank 	Required	provided	MR
	<ul style="list-style-type: none"> Overhead Tank capacity 	5,000litter	5,000	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.	(Only 02 lift are Installed)		
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	provided	MR
	• Firemen's grounding switch	Required	provided	MR
	• Lift Signage	Required	provided	MR
17	Standby power supply	Required	1500,kvs	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A


The Fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on Fire prevention and Fire safety measures as required under the Rules, it is recommended to grant the Fire Safety Certificate under the rules 35, of the Delhi Fire Service Rule 2010.


Accordingly DFA is prepared in the shape of FSC and submitted for your kind perusal and approval please.


22/11/18

Signature of the Inspecting Officer
Name: F.BROWN
Designation DO


22/11/18

Signature of the Inspecting Officer
Name: Vijay Bhadur
Designation: ADO


DCFO (NDZ) 

CFO M. SELL FTB. Ue 29/XI

F.T. Bellu is prepared and put up for signats ph.

CFO/NDZ

M. SELL Ue 4/XII


5/12/18

787/CFO NDZ
2/12