

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No. F6(DFS/MS) 2018/WZ/2625

Dated: 6/12/18

FIRE SAFETY CERTIFICATE

Certified that the **Lavanya Orchid Banquet Hall** located at **Plot No. 15, Nazafgarh Road, Shivaji Marg, New Delhi - 110015** in a building comprised of Basement + Ground + 2 Upper Floors was issued NOC/FSC vide this office letter No. F6/DFS/MS/Banquet/2014/WZ/1510 dated 03/12/2014. The premises was re-inspected by the officers concerned of this department on **03/12/2018** in the presence of Sh. Vijay Pal Singh Bisht (Proprietor) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service Rule 2010 and the building/premises is fit for **Class-D Assembly** occupancy with effect from....6/12/18.....for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Issued on 6/12/18..... at New Delhi by.

(Atul Garg)
Chief Fire Officer,

Copy to:

1. The Authorised Signatory,
Lavanya Orchid Banquet Hall, Plot No. 15, Nazafgarh Road, Shivaji Marg, New Delhi.
2. Dy. Health Officer, Karol Bagh Zone, NDMC, Public Health Department, Karol Bagh, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per Building Bye Laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

N/30

Re-Inspection to see the compliance of shortcomings communicated vide letter no.F6/DFS/MS/BNQT/2018/WZ/1928 dated 10/05/2018. In this connection the Proprietor/Occupier has provided a 2 mtr wide sprinkler corridor from basement to ground floor. Also stand by pump has been provided.

INSPECTION REPORT

1. Name & address of the building: Lavanya Orchid Banquet Hall, 15 Main Road, Nazafgarh Road, Industrial Area, Moti Nagar, New Delhi – 110015.
2. Type of Occupancy : Assembly (Basement + Ground + 2 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/ Banquet/2014/WZ/1510 dated 03/12/2014
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 03-12-2018
7. Name of the Inspecting Officer : MukeshVerma, DO (West)
8. Name and designation of Officer
from the building side : Sh. Vijay Pal Singh Bisht (Proprietor)
9. Year of Construction : 2008
10. Applicant's letter No. : nil dated 30/11/2018

Plot Area = 669 m² Covered
Area Basement=432m²,
GF=441 m², FF= 441 m²,
SF=302 m²

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	5 m	On Main Road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	03 Provided	MR
	b. Width of staircases			
	• Upper floors	2 m & 1m	1.97 m & 1.55 mtr	MR being old case
	• Basements	2 m & 1m	5.5 mtr, 1.97 m & 1.55mtr	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	d. No of continuous staircase to terrace	Required	Provided	MR
	e. Width Of Corridor	02 mtr	Provided in basement	MR
	f. Door Size	2m	GF=155, 137 & 106 cm FF=106 & 237cm	MR being old case

3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	Provided	MR
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NR	NR	NR
	• Hose Box	NR	NR	NR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 lpm	Provided	MR
	➤ Head of main pump	40 m	Provided	MR
	➤ Number of main pumps	1	Provided	MR
	➤ Jockey pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	40 m	Provided	MR
	➤ Standby Pump out put	2280 lpm	Provided electrical pump connected with generator	MR
	➤ Standby Pump Head	40 m	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	900 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 litres	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10, 000 litres	Found Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC vide letter No. F6/DFS/MS/ Banquet/2014/WZ/1510 dated 03/12/2014 renewal under rule 35 of the Delhi Fire Service rule 2010 is recommended.

Signature of the Inspection Officer

Name MukeshVerma

Designation DO (West)

Mukesh
3/12/18

Dy. GPO WZ
3/12/18