

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/2018/ 2667

Dated: 10/12/2018

FIRE SAFETY CERTIFICATE

Certified that the **Community Hall** Located at **Sainik Vihar & Rishi Nagar(Rani Bagh) New Delhi**. comprised of Basement + Ground + 3Upper Floors owned/occupied by **DDA** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **25.10.2018** in the presence of Mr. M. K. Gulati (EE DDA) and that the building/premises is fit for occupancy **Assembly** with effect from ...10/12/18.... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....10/12/18.....at New Delhi by


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The EE(electrical) DDA, 21 Floor , Vikash Minar, ITO, New Delhi-110002
2. The Community Hall, Sainik Vihar & Rishi Nagar(Rani Bagh) New Delhi.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used only as per NBC part-IV.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs. Delhigovt. Nic.in](http://www.dfs.Delhigovt.Nic.in)
- 8) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building: **Community Hall** Located at **Sainik Vihar & Rishi Nagar(Rani Bagh) New Delhi.**
2. Type of Occupancy : Assembly (Basement + Ground + 3Upper Floors)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F6/DFS/MS/BP/2012/1212 dated 04-04-2012
6. Date of inspection : 25-10-2018
7. Name of the Inspecting Officer : Do/W & ADO (WP)
8. Name and designation of Officer
from the building side : Mr. M. K. Gulati (EE DDA)
9. Year of Construction : 2015-16
10. Applicant's letter No. : F-6(60)/Eld.8/DDA/2018/717 dated 12/09/2018

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 m 5 m 6m	13m Provided 2x583cm 6m	MR MR MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	2	Provided	MR
	b. Width of staircases			
	• Upper floors	2 X2 m	2x2m	MR
	• Basements	2X2 m + 1 ramp	2x2m & Ramp=6m	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2x 2 m	2 m (Including door frame)	MR
3.	Compartmentation			
	• Fire check door	Required	provided	MR
	• Sealing of electrical shafts	Required	provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	provided	MR
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	12 nos. Water co2 & CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	Basement =2 Upper Floors=1 36 m 5 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke Required Required Required Required	Provided Provided Provided Provided Provided	MR MR MR MR MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	Required Required NA	provided provided NA	MR MR NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm Basement=2,U. Floor=1 Required	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	2 Required 2 Required	provided provided	MR MR
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	2280 lpm 40 m 1 180 lpm 40 m 2280 lpm 40 m Required Required 900 lpm 40 m Required Required	provided provided provided provided provided provided provided provided provided provided provided provided provided	MR MR MR MR MR MR MR MR MR MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	75000 litres Required Required Required 10000 litres	provided provided provided provided provided	MR MR MR MR MR

15	Exit Signage	Required	provided	MR
16.	Provision of Lifts (Pressurization is not required as per NBC however the architect has been asked to provide pressurization by the directive issued)			
	➤ Pressurization of Lift Shaft	NA	Provided	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	provided	MR
	➤ Fireman's Grounding Switch	Required	provided	MR
	➤ Lift Signage	Required	provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbersNil.....

~~Signature of the Inspecting Officer~~ *Do 28/10*

Name *Uday Vir Singh*

Designation *ADDO/WP*

~~Signature of the Inspecting Officer~~ *Sh Mohesh Verma 28/10*

Name *Sh Mohesh Verma*

Designation *DO/W*

~~Signature~~ *27/11/18*

~~Signature~~ *28/11/17 FTPI*

~~Signature~~ *29/11/18*