

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No: F6/MS/DFS/School/2018/ 2668

Dated: 10/12/2018

FIRE SAFETY CERTIFICATE

Certified that the building of **DAV Public School**, Located at **Ashok Vihar, Phase- IV, Delhi.110052** comprised of Ground + 03 Upper Floors(**2nd Block Abandoned**) owned and occupied by **DAV Public School** was issued FSC vide Letter No. **F6/MS/DFS/08/2064 Dated 18/11/2018** The premises was re inspected by the officer concerned of this department on 16/11/2018 in the presence of **Mr Ramesh Kumar (Estate Officer)** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 Dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 10/12/18 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 10/12/18 at New Delhi.


(Atul Garg)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal, DAV Public School, Located at Ashok Vihar, Phase- IV, Delhi.110052
2. Directorate of Education Old Secretariat Delhi – 110054

Following fire safety directives must be adhered to:-

1. **The small tin shed at terrace shall not be used for school activities.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. **2nd Block shall not be used for school activities.**

INSPECTION REPORT

1. Name & address of the building: DAV Public School, Located at Ashok Vihar, Phase- IV, Delhi.110052.
2. Type of Occupancy : Educational Two Blocks(1st Block of Ground + 3 Upper+ Tin shed above 2 or 3 rooms & 2nd Block Ground Floor only,) (Except Abandoned 2nd Block)
3. Type of Case : Renewal
4. Details of previous NOC: F6/MS/DFS/school//2015/2064 Dated 18/11/2015
5. Fire Safety directives Letter No. : DOE Cr 262-362 Dated 17-01-2005
6. Date of inspection : 16-11-2018
7. Name of the Inspecting Officer : ADO (WP)
8. Name and designation of Officer
from the building side :Mr. Ramesh (Estate Officer)
9. Year of Construction : 2005-06
10. Applicant's letter No. : DAVPSAV/PH-IV/6927 dated 05-10-2018

Total Area = 1.5acre
(6069.66 sqmt)
Covered Area = 4903.53 M²
(all floor).
Class rooms = 55
No. of students = 2600

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular 262-362 Dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	12m Provided	MR
	• Gate width	Accessible	4m Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	2 X1.5m	2x136 cm	MR(Being Old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1x1 m	Provided(110 cm) the class Room Having less than 45 students	MR

3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	NA	NA	NA
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	18 nos.	Provided	MR
	<ul style="list-style-type: none"> • Types 	ABC & CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	2	Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Main Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	NA	NA	NA
	<ul style="list-style-type: none"> • Hooters' Location 	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper Floor 	NA	NA	NA
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NA	NA	NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	2	Provided	MR
	<ul style="list-style-type: none"> • Hose Box 	2	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> • Total number of hydrants 	NA	NA	NA
	<ul style="list-style-type: none"> • Hose Box 	NA	NA	NA

13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> • Ground Level • Discharge of main pump ➤ Head of main pump ➤ Number of main pumps ➤ Jockey pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Staring/Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm&180 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	30000 ltrs	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		5000 litres	Provided(10000 ltrs)	MR
		Required	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
-----	--	----	----	----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/school/2015/2064 Dated 18-11-2015 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note;-The small tin shed at terrace (above 2 or 3 class rooms) and 2nd abandoned block shall not be used for school activities.

[Signature]
 20/11/18
 Signature of the Inspecting Officer
 Name Udai Vir Singh
 Designation ADO/WP

[Signature] 26/11/18
[Signature] 27/11/18
[Signature] 28/11/18
 CTO work

1- Ask them to maintain
 2- Check it was G+2 & now
 G+3, Pls explain

[Signature] 28/11/18
 on 3/12/18
 Pubk P

[Signature]
 28/11/18

[Signature] RY letter is put up for info plc.
[Signature] 28/11/18