

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

No. F.6/DFS/MS/School/2018/SZ/ 2650

Dated: ... 10/12/18

FIRE SAFETY CERTIFICATE

Certified that the Delhi Kannada Senior School No-3 at Lodhi Estate, New Delhi-110003, having two blocks, A-Block (Secondary) comprised of ground plus three upper floors and B-block (Primary) comprised of ground plus two upper floors Owned/Occupied by Delhi Kannada Education Society (Regd.) was issued NOC by this department vide letter No. F6/DFS/MS/08/2486 dated 01/09/2008. The premises was re-inspected by officer concerned by this department on 27/11/2018 in the presence of Mrs. Vijaya Kumari (Principal) of the school and observed that the school premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" Group-B (School) as above with effect from 10/12/2018 for period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of conditions mentioned below.

Issued 10/12/18 at New Delhi by


(Vipin Kental)
Chief Fire Officer
Ph: 011-23412225


Copy to: -

1. Principal, Delhi Kannada Senior School No-3 at Lodhi Estate, New Delhi-110003
2. Directorate of Education, South M.C.D., Civic Centre, Minto Road, New Delhi-110002

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT

1	Name & Address of the Building	Delhi Kannada Senior School No-3, Lodhi Estate, New Delhi-110003		
2	Type of Occupancy	Educational, Group-B (School)		
3	Building Comprised of	A Block- G+3 and B Block- G+2		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/2008/2486 Dated 01-09-2008		
6	Fire Safety Directives Letter No	DOE Circular No. 262-362 dated 17-01-2005		
7	Date of Inspection	27-11-2018		
8	Name of the Inspecting Officers	Mehmood, ADO (SJ)		
9	Name & Designation of Officers from the building side	Mrs. Vijaya Kumari (Principal)		
10	Year of construction	1995		
11	Applicant letter No.	Outdoor diary No. 15306 dated 22-10-2018		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1.	Access to Building.			
	• Road width	06 mtr	12 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors.	02 Nos each Bk	Provided	MR
	➤ Basement floor.	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1.5m / 0.90m	A Bk- 1.55m each B Bk- 1.2m, 1.5m iron	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	01 each block	Provided	MR
	e) Width of corridor	1.5m	Provided	MR
	f) Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door.	-NA-	-NA-	-NA-
	• Sealing of electrical shafts.	-NA-	-NA-	-NA-
	• Fire rating of shaft door.	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers.	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	Required	22 Nos	MR
	• Types	ABC / CO2	ABC & CO2	MR
	• ISI Marking	ISI marked	Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor.	01 each Bk	Provided	MR
	• Length of hose-reel hose.	30m	Provided	MR
	• Nozzle Diameter	5mm	Provided	MR

7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	100mm 01 each block 01 each block	Provided Provided Provided	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA- -NA-	-NA- -NA-	-NA- -NA-
13	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 01 each block 450 LPM 40m Required Required	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- A-Bk-01, B-Bk-02 A Bk-450 LPM, B Bk-450 & 180 LPM 40m each Provided Provided	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- MR MR MR MR MR
14	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA- -NA- -NA- -NA- 10,000 Ltr	-NA- -NA- -NA- -NA- 10,000 Ltr each	-NA- -NA- -NA- -NA- MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	-NA- -NA-	-NA- -NA-	-NA- -NA-

19	Fire Control Room.		-NA-	-NA-	-NA-
		• Detector system panel.	-NA-	-NA-	-NA-
		• Flow switch panel.	-NA-	-NA-	-NA-
		• PA system panel.	-NA-	-NA-	-NA-
		• Battery backup.	-NA-	-NA-	-NA-
	• Building floor plan.	-NA-	-NA-	-NA-	
20	Special Fire Protection System for the Protection of special Risk, if any.				-NA-
<p>The shortcomings communicated by this department vide letter No. F6/DFS/MS/2017/2276 dated 01/09/2017 found complied.</p> <p>The fire protection systems provided in the premises were test checked at random and found functional at the time of inspection. Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the DOE circular, the NOC issued vide letter No. F6/DFS/MS/2008/2486 dated 01/09/2008, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.</p> <p>Accordingly DFA is put up for approval and signature please.</p>					
					<p><i>[Signature]</i> 28/11/18 Signature of the Inspecting Officer Name: Mehmood Design: ADO (SJ)</p>

Delhi Kannada Senior School No-3, Lodhi Estate, New Delhi-110003

DO (SD)

[Signature]
30/11/18

[Signature]

[Signature]
4/12

FT/10

CFO/ST M.Scell

[Signature]
5/12



231/CFO/523
6/12/18

A. P.T. Letter sent up for signature
[Signature]
6/12/18

[Signature]
M.Scell 7/12

[Signature]