

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001


No.F.6/DFS/MS/School/2018/NDZ/ 2645

Dated: 07/12/18

FIRE SAFETY CERTIFICATE

Certified that the **EDMC Primary Co-ed Vidyalaya, Mayur Vihar Phase-III, Pocket B-5, Delhi**, comprised of ground plus one upper floor owned/occupied by EDMC Primary Co-ed Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the circular no. F-16/Estate/CC/FS/2011/3298 to 3398 dated 01/03/11 issued by the Director of Education and verified by the officer concerned of this department on 30/10/18 in the presence of **Mrs. Sangeeta (Incharge)** of the school and found that the school building is fit for occupancy class B 'Educational Building' for with effect from ...07/12/18... for a period of **three** years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overlea

Issued on.....07/12/18.....at New Delhi by


(Vipin Kental)
Chief Fire Officer



To,

1. The Principal,
EDMC Primary Co-ed Vidyalaya,
Mayur Vihar Phase-III, Pocket B-5, Delhi.

Copy to :-

The Director of Education,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area, Delhi-110092.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1. Name & address of the building :EDMC Primary Co-ed Vidyalaya at Mayur Vihar Phase-III, Pocket B-5,Delhi.
2. Building is comprised of : G+1
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous FSC : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.11
7. Date of Inspection : 30/10/18
8. Name of the Inspecting Officers : R.K. Yadav (ADO)
9. Name of the designation of Officer from the building side : Mrs. Sangeeta (Incharge)
10. Year of Construction : 2017
11. Applicant's letter No : letter no. Nil dated 14/09/18

S.No	Minimum Standards on fire safety requirements as per circular no. 3298 to 3398 Dated. 01.03.11	Requirement <i>as per BOE at dt 1.3.11</i>	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	10 m	MR
	Gate width	N.A	N.A	N.A
	Width of internal road	N.A	N.A	N.A
2	Number, Width, Type and Arrangement of Exits			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization d. No. of continuous staircases to terrace e. Width of Corridor f. Door Size				
	2no.	3 no.		MR
	N.A	N.A		N.A
	1.5 m	1.5 m each		MR
	N.A	N.A		N.A
	N.A	N.A		N.A
	N.A	N.A		N.A
	N.A	N.A		N.A
	02 no.	02 no.		MR
	1.5 m	1.5 m		MR
	1 m	1.0 m		MR
	3	Compartmentation.		
Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers	N.A	N.A		N.A
	N.A	N.A		N.A
	N.A	N.A		N.A
	N.A	N.A		N.A
	N.A	N.A		N.A
4	Smoke Management System.			
Basement Upper floor	N.A	N.A		N.A
	N.A	N.A		N.A
5.	Fire Extinguisher	06 nos.	06 nos.	MR
	Total number of fire extinguishers	CO ₂ & ABC	CO ₂ & ABC	MR
		ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor	N.A	N.A	N.A
	Length of hose reel hose	N.A	N.A	N.A
	Nozzle diameter	N.A	N.A	N.A
7	Automatic fire detection and alarming system.			
	Type of detectors	N.A	N.A	N.A
	Location of main panel	N.A	N.A	N.A
	Location of repeater panel	N.A	N.A	N.A
	Alternate source of power	N.A	N.A	N.A
	Hooters	N.A	N.A	N.A
8	MOEFA	N.A	N.A	N.A
9	Public address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	basement	N.A	N.A	N.A
	upper floor	N.A	N.A	N.A
	sprinkler above false ceiling	N.A	N.A	N.A
11	Internal Hydrants			
	size of riser/down-comer	N.A	N.A	N.A
	Number of hydrants per floor	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
12	Yard Hydrants.			
	Total number of hydrants	N.A	N.A	N.A
	Hose Box	N.A	N.A	N.A
13	Pumping Arrangements.			
	Ground Level	N.A	N.A	N.A
	Discharge of main Pump	N.A	N.A	N.A
	Head of Main Pump	N.A	N.A	N.A
	Number of main pumps	N.A	N.A	N.A
	Jockey pump out put	N.A	N.A	N.A
	Jockey pump head	N.A	N.A	N.A
	Standby pump out put	N.A	N.A	N.A
	Standby pump Head	N.A	N.A	N.A
	Auto Starting /Manual stopping	N.A	N.A	N.A
	Pump House Access	N.A	N.A	N.A
	Terrace Level	N.A	N.A	N.A
	Discharge of pump	N.A	N.A	N.A
	Head of the Pump	N.A	N.A	N.A
	Power supply	N.A	N.A	N.A
	tarting of pump	N.A	N.A	N.A
14	Captive Water Storage for Fire Fighting.			
	Underground tank capacity	N.A	N.A	N.A
	Draw-off connection	N.A	N.A	N.A
	Fire service inlet	N.A	N.A	N.A
	Access to tank	N.A	N.A	N.A
	Overhead Tank capacity	N.A	N.A	N.A
15	Exit Signage.	N.A	N.A	N.A

16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A	N.A	N.A
	Pressurization of Lift lobby	N.A	N.A	N.A
	Communication in lift car	N.A	N.A	N.A
	Firemen's grounding switch	N.A	N.A	N.A
	Lift Signage	N.A	N.A	N.A
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	Total area	N.A	N.A	N.A
	Location	N.A	N.A	N.A
19	Fire Control Room			
	Detector system panel	N.A	N.A	N.A
	Flow switch panel	N.A	N.A	N.A
	PA system panel	N.A	N.A	N.A
	Batter backup	N.A	N.A	N.A
	Building Floor Plans	N.A	N.A	N.A
20	Special Fire Protection systems for protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were tested/checked at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the circular no.F16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/11, it is recommended to grant Fire Safety Certificate.

Signature of the Inspecting officer

Name-

R.K.Yadav

Designation-

ADO(LN)

R.K. Yadav
31/10/2018

776/cfo NM
9/11/18/2/12

DO(East)

[Signature]
31/11/18

DY CPO/NDM

[Signature]

[Signature]

M.Scull

FT 101

9/11/18

Say FF letter is put up for signature please

R.K. Yadav