

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001



NO.F6/DFS/MS/School/2018/SZ/ 2627

Dated: 6/12/18

FIRE SAFETY CERTIFICATE

Certified that the J.B.M Public School, Nasir Pur, New Delhi-110045, building comprised of ground plus two upper floors was issued Fire Safety Certificate vide this department letter no. F6/DFS/MS/School/2016/SZ/180 dated 28.01.2016. The said school building was re-inspected by the officer concerned of this department on 14.11.2018 in presence of Dr. Joginder Singh (Manager) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from.....6/12/18.. for a period of **three** years subject to compliance of the conditions printed overleaf.

Issued on6/12/18..... at New Delhi by


Vipin Kental
Chief Fire Officer


Copy to:-

1. Deputy Director (Education) GNCT of Delhi, Old Secretariat, New Delhi-110054.
2. Principal, J.B.M Public School, Nasir Pur, New Delhi-110045.

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	J.B.M Public School, Nasir Pur, New Delhi-110045.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal (G+2)		
4	Details of previous NOC	F6/DFS/MS/School/2016/SZ/180 dated 28.01.2016		
5	Fire safety directives letter No	Edu. Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01.03,2011		
6	Date of inspection	14.07.2018		
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Dr. Joginder Singh (Manager)		
9	Year of construction	2002 & 2015		
10	Applicant's letter No.	Jbmps/009/fire/18 dated 10.102018	Ground plus two upper floors (3 Rooms at 3rd floor are under construction)	
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Edu. Cir. Dated 1.3.2011	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	Provided	MR
	2) Gate width	4.5 Mtrs.	Direct accessible from road	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4 Nos.	4 Nos.	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.50 Mtrs. If less than 1.50 mtrs. Additional staircase of .75 Mtr. Is required	2 Nos. 1.25 Mtrs. each 1 No. 1.20 Mtrs. & 1 No. 1.40 Mtrs. + 1 Ramp (1.5 Mtr.) G to 1st Floor.	MR being old case
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace			
		Two	Provided	MR
	e. Width of corridor			
		N/A	N/A	N/A
	f. Door size			
		1 Mtr.	Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	N/A	N/A	N/A
	upper floors	12 a/c per hour	Natural Ventilation	MR

5 Fire Extinguishers				
	total numbers	2 Nos. each Floor	12 Nos.	MR
	Types	CO2 & ABC	Provided	MR
	ISI marking	ISI Marked	Provided	MR
6 First-Aid Hose Reels.				
	total numbers on each floor	One	Two	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7 Automatic fire detection and alarming system				
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	Provided	N/A
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants				
	Size of riser/down-corner	100 mm	100 mm	MR
	Number of Hydrants per floor	One	Two	MR
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13 Pumping arrangements				
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 LPM	Provided	MR
	b. head of the pump	40 Mtrs.	Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14 Captive water storage for fire fighting				
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	10000 Ltrs.	Provided	MR
15	Exit Signage.	Required	Provided	MR

16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any: ABC fire extinguisher provided near electric panel			MR

The fire protection systems provided in the building were checked and found functional at the time of inspection. Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements as per DOE Cir. dated 1.3.2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/2016/SZ/180 dated 28.01.2016 is recommended.

Accordingly DFA is put up for approval and signature please.

Sey
15/11/18
S.P. Bhardwaj
ADO (Dwarka)

~~DO/SW~~
108/DO/SW
22/11/18

Key
20/11/2018

219/cfo S2
30/11/6/14

DO/S2 - on leave
cfo (S2) m/s cell

FT/M,
29/11/18

F.T.S put up for signature plan

cfo S2
m/s cell 4/11/18

Sey
31/11/18